

Alameda International Jr./Sr. High School - Sampled 9/8/16				Resampled** 1/26/17		Resampled† 5/3/19	
SampleNumber	Description	Lead Result	Unit	Lead Result	Unit	Lead Result	Unit
71000-110H-DF	Hallway Drinking Fountain across from Counseling Offices	0.6	ppb			0.7	ppb
71000-106H-DFL	Hallway Drinking Fountain across from Classroom 106/Left	2.6	ppb			1.0	ppb
71000-106H-DFR	Hallway Drinking Fountain across from Classroom 106/Right	13.7	ppb			24.4***	ppb
71000-106-S	Sink in Classroom 106	0.3	ppb				
71000-105-S4	Sink in Social Studies Classroom 105 (4th sink from main room entrance, counting clockwise)	19.4	ppb	18.4	ppb		
71000-P103H-DFL	Hallway Drinking Fountain near Classroom 123/Left	1.0	ppb			0.8	ppb
71000-P103H-DFR	Hallway Drinking Fountain near Classroom 123/Right	1.0	ppb			0.7	ppb
71000-117-S1	Sink in Science Classroom 117 (on left in row of 3 on hallway wall)	14.7	ppb				
71000-117-S2	Sink in Science Classroom 117 (in middle in row of 3 on hallway wall)	13.9	ppb				
71000-117-S3	Sink in Science Classroom 117 (on right in row of 3 on hallway wall)	11.4	ppb				
71000-117-S4	Sink in Science Classroom 117 (on left in row of 3 on wall backing up to Rooms 118/119)	25.9	ppb	12.9	ppb		
71000-117-S5	Sink in Science Classroom 117 (in middle in row of 3 on wall backing up to Rooms 118/119)	330.7	ppb	38.3	ppb		
71000-117-S6	Sink in Science Classroom 117 (on right in row of 3 on wall backing up to Rooms 118/119)	82.1	ppb	46.5	ppb		
71000-117-S7	Sink in Science Classroom 117 (on demo station in front/center of room)	3.4	ppb			3.9	ppb
71000-B16A-S	Sink in Science Prep Room B16A	16.8	ppb	4.8	ppb		
71000-119AX-S	Sink in Restroom 199AX-S (near Clinic Room 119)	0.7	ppb				
71000-P106-S	Sink in Foreign Language Storage Room 115A (Room P106 on Facilities Floor Plan)	16.2	ppb	5.1	ppb		
71000-P109H-DFL	Hallway Drinking Fountain across from Student Store D112/Left	3.9	ppb			4.1	ppb
71000-P109H-DRF	Hallway Drinking Fountain across from Student Store D112/Right	1.7	ppb			1.8	ppb
71000-128-S	Sink in Principal's Office Room 128	0.3	ppb			0.3	ppb
71000-122X-S	Sink in Restroom 122X in Main Office Area	2.3	ppb				
71000-124-S	Sink in Assistant Principal's Office Room 124	6.0	ppb			8.5	ppb
71000-124H-DF	Hallway Drinking Fountain across from Assistant Principal's Office	1.7	ppb			3.0	ppb
71000-101-S3	Sink in Science Classroom 101	1.1	ppb				
71000-101-S2	Sink in Science Classroom 101	6.8	ppb				
71000-101A-S	Sink in Science Prep Room 101A	2.0	ppb				
71000-102-S3	Sink in Science Classroom 102 (on demo station)	11.7	ppb				
71000-103-S1	Sink in Science Classroom 103 (on demo station)	14.0	ppb				
71000-104-S3	Sink in Science Classroom 104 (on demo station)	10.8	ppb				
71000-021-S	Sink in First Restroom (Room 021) in Clinic 115X	0.9	ppb				
71000-D111-S	Sink in Office Area D111 in Student Dining Area	0.8	ppb			1.3	ppb
71000-D110-DF	Drinking Fountain in Student Dining Area	0.3	ppb			0.2	ppb
71000-D110-WBFS	Water Bottle Filling Station in Student Dining Area	0.2 ‡	ppb				
71000-D102-S1	Food Service Sink - Food Prep Sink	2.6	ppb			1.3	ppb
71000-D102-S2	Food Service Sink - Hand Sink	2.7	ppb				
71000-D102-S3	Food Service Sink - Wash/Rinse/Sanitize Sink	3.4	ppb				
71000-D102-S4	Food Service Sink - Wash/Rinse/Sanitize Sink	1.9	ppb				
71000-D102-S5	Food Service Sink - Wash/Rinse/Sanitize Sink	1.6	ppb				
71000-A134-S	Sink in Teachers' Lounge	0.9	ppb			0.5	ppb
71000-AD111H-DFL	Hallway Drinking Fountain outside the Auditorium/Left	0.5	ppb			0.5	ppb
71000-AD111H-DFR	Hallway Drinking Fountain outside the Auditorium/Right	0.3	ppb			0.9	ppb
71000-S114-S1	Sink in Art Classroom S114	7.3	ppb				
71000-S114-S2	Sink in Art Classroom S114	5.0	ppb				
71000-S114-S3	Sink in Art Classroom S114	4.6	ppb				
71000-S114-S4	Sink in Art Classroom S114	1.2	ppb				
71000-S112-S1	Sink in Art Classroom S112	1.0	ppb				
71000-S112-S2	Sink in Art Classroom S112	2.1	ppb				
71000-S115-S1	Sink in Art Classroom S115	0.9	ppb				
71000-S115-S2	Sink in Art Classroom S115	0.9	ppb				
71000-S134-S1	Sink in Technology Lab S134	10.5	ppb				
71000-S134-S2	Sink in Technology Lab S134	2.3	ppb				
71000-S125-S	Sink in Band Room S125	1.2	ppb			1.1	ppb
71000-S139A-S1	Sink in CCTV Lab Storage Room S139A	6.6	ppb				
71000-S139A-S2	Sink in CCTV Lab Storage Room S139A	6.8	ppb				
71000-S139A-S3	Sink in CCTV Lab Storage Room S139A	6.0	ppb				
71000-S139A-SWB	Sink with Bubbler in CCTV Lab Storage Room S129A	2.9	ppb			8.1	ppb
71000-A112A-S	Sink in Science Prep Room A112A	1.1	ppb				
71000-A111-S	Sink in Auditorium A111	0.8	ppb			0.3	ppb
71000-A113-S	Sink in Classroom A113	2.0	ppb				
71000-A117-S	Sink in Classroom A117	1.2	ppb				
71000-A116A-S	Sink in Office A116A (between Classrooms A116 and A118)	1.0	ppb				
71000-A118H-DFL	Hallway Drinking Fountain across from Room A118/Left	< 0.1*	ppb			< 0.1*	ppb
71000-A118H-DFR	Hallway Drinking Fountain across from Room A118/Right	< 0.1*	ppb			0.1	ppb
71000-A121-S	Sink in Classroom A121	1.0	ppb				
71000-A120-S1	Sink in Family and Consumer Science Kitchen Room A120	2.2	ppb			0.7	ppb
71000-A120-S2	Sink in Family and Consumer Science Kitchen Room A120	1.4	ppb			0.7	ppb
71000-A120-S3	Sink in Family and Consumer Science Kitchen Room A120	1.5	ppb			1.6	ppb
71000-A120-S4	Sink in Family and Consumer Science Kitchen Room A120	2.5	ppb			1.3	ppb
71000-A120-S5	Sink in Family and Consumer Science Kitchen Room A120	2.6	ppb			0.9	ppb
71000-A120-S6	Sink in Family and Consumer Science Kitchen Room A120	2.8	ppb			0.7	ppb
71000-A127-S	Sink in Classroom A127	1.0	ppb				
71000-A205-S	Sink in Office A205 (near Room A210)	0.9	ppb				
71000-A205H-DFL	Hallway Drinking Fountain near Room A210/Left	< 0.1*	ppb			0.1	ppb
71000-A205H-DFR	Hallway Drinking Fountain near Room A210/Right	< 0.1*	ppb			0.1	ppb
71000-A212-S	Sink in Science Prep Area A212	0.5	ppb				
71000-A211-S	Sink in Science Prep Area A211	1.6	ppb				
71000-A217-S	Sink in Science Prep Area A217	1.3	ppb				
71000-A218-S	Sink in Science Prep Area A218	1.5	ppb				
71000-A140-DF	Drinking Fountain in Vocal Classroom A140	0.2	ppb			0.3	ppb
71000-AD111-S	Sink in Concession Area near Auditorium	78.1	ppb	2.7	ppb		

71000-G112H-DFL	Hallway Drinking Fountain near Concession Area near Auditorium/Left	0.8	ppb		0.5	ppb
71000-G112H-DFR	Hallway Drinking Fountain near Concession Area near Auditorium/Right	0.6	ppb		0.4	ppb
71000-201H-DF	Hallway Drinking Fountain near Classroom 201	3.0	ppb		0.9	ppb
71000-201H-WBFS	Hallway Water Bottle Filling Station near Classroom 201	0.9 ‡	ppb			
71000-201A-S	Sink in Business Lab Classroom 201A	16.9	ppb	4.4	ppb	
71000-206H-DFL	Hallway Drinking Fountain near Classroom 206	7.3	ppb		10.3	ppb
71000-L001AX-S	Sink in Library Processing Room L001AX	4.9	ppb			
71000-L005-S	Sink in Library Planning Room L005	2.0	ppb			
71000-L009H-DFL	Hallway Drinking Fountain across from Classroom 208/Left	3.7	ppb		9.4	ppb
71000-L009H-DFR	Hallway Drinking Fountain across from Classroom 208/Right	3.2	ppb		5.6	ppb
71000-213H-DFL	Hallway Drinking Fountain across from Classroom 213/Left	2.1	ppb		4.1	ppb
71000-213H-DFR	Hallway Drinking Fountain across from Classroom 213/Right	1.9	ppb		3.1	ppb
71000-216-S	Sink in Computer Classroom 216	3.1	ppb			
71000-G012H-DF	Hallway Drinking Fountain near Gym	< 0.1*	ppb		0.2	ppb
71000-G012H-WBFS	Hallway Water Bottle Filling Station near Gym	0.2 ‡	ppb			
71000-G011H-DFR	Hallway Drinking Fountain near Gym	0.9	ppb			
71000-G011H-DFL	Hallway Drinking Fountain near Gym	0.6	ppb			
71000-G029H-DFL	Hallway Drinking Fountain near Gym	0.1	ppb		0.1	ppb
71000-G029H-DFR	Hallway Drinking Fountain near Gym	0.1	ppb		0.3	ppb
71000-G050-S	Sink in Training Room near Gym	1.0	ppb		0.9	ppb
71000-G050-IM	Ice Machine in Training Room near Gym	0.3	ppb		0.2	ppb
71000-103A-S	Sink in Classroom 103A	0.7***	ppb			
71000-138-SWB	Sink with Bubbler in Classroom 138	36.7***	ppb		17.1***	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.						
** Resampling results after elevated fixtures were repaired, or removed and replaced.						
*** This fixture was sampled on 1/26/17.						
† Resampling results were from samples collected on 5/3/19 as part of an ongoing rotation of lead testing.						
‡ This fixture was sampled for the first time on 5/3/19.						
***This fixture is signed "Do not Drink, No Food Prep, For Hand Washing Only"						