

Coronado Elementary School		Sampled 5/3/2022	Status
CustomerSampleNumber	Description	Lead Results (ppb)	
09800-113-S	Sink in Clinic	0.5	
09800-128-S	Sink in Teacher's Lounge	0.6	
09800-214H-DF	Hallway Drinking Fountain	0.1	
09800-2022-214H-WBFS	Hallway water bottle filling station	0.1	
09800-226H-DF	A-Pod Hallway Drinking Fountain	0.2	
09800-225H-DF	A-Pod Hallway Drinking Fountain	0.6	
09800-163H-DF	B-Pod Hallway Drinking Fountain	0.4	
09800-141H-DF	C-Pod Hallway Drinking Fountain	0.2	
09800-139H-DF	C-Pod Hallway Drinking Fountain	0.2	
09800-129H-DF	Hallway Drinking Fountain	0.3	
09800-2022-129H-WBFS	Hallway water bottle filling station	0.2	
09800-102-SWB	Sink with Bubbler in Kindergarten Classroom 102	not in use	
09800-104-SWB	Sink with Bubbler in Kindergarten Classroom 104	not in use	
09800-R1-185-DF	Drinking Fountain in Temp R1-185	0.5	
09800-REC-085-DF	Drinking Fountain in Temp REC-085	0.3	
09800-R1-184-DF	Drinking Fountain in Temp R1-184	2	
09800-162H-DF	B-Pod Hallway Drinking Fountain	0.2	
09800-R1-135-DF	Drinking Fountain in Temp R1-135	5.9	Repairs Pending

* This results is less than 0.1ppb, which is the lowest level that can be reported by the lab.