

Deer Creek Middle School		Sampled 4/6/2022	Status
CustomerSampleNumber	Description	Lead Results (ppb)	
64400-118X-S	Sink in Clinic	0.3	
64400-119XX-S1	Sink in Classroom Kitchen 119XX	0.2	
64400-119XX-S2	Sink in Classroom Kitchen 119XX	0.2	
64400-119XX-S3	Sink in Classroom Kitchen 119XX	0.2	
64400-119XX-S4	Sink in Classroom Kitchen 119XX	0.3	
64400-119XX-S5	Sink in Classroom Kitchen 119XX	0.2	
64400-119XX-S6	Sink in Classroom Kitchen 119XX	0.2	
64400-119XX-S7	Sink in Classroom Kitchen 119XX	0.2	
64400-121-SWB	Sink with Bubbler in Consumer Science Classroom 121	0.8	
64400-143X-S2	Food Service Sink-Food Prep	9.1	Repairs Pending
64400-191X-S	Sink in Lounge 191X by Gym	3.1	
64400-177H-DF	Hallway Drinking Fountain by Gym Lockers	0.2	
64400-2022-177H-WBFS	Water Bottle Filling Station by Gym Lockers	0.2	
64400-125-SWB	Sink with Bubbler in Technology Lab 125	not in use	
64400-181-DF	Drinking Fountain in Boy's Locker Room	0.9	
64400-126-DF	Drinking Fountain in Girl's Locker Room	0.8	
64400-110XH-DF	Hallway Drinking Fountain across from Planning Room 119	<0.1*	
64400-131H-DF	Hallway Drinking Fountain across from Planning Room 108	<0.1*	
64400-102H-DF	Hallway Drinking Fountain across from Main Office	0.3	
64400-202XXH-DF	Hallway Drinking Fountain across from Reception Office	0.2	
64400-203XXH-DF	Hallway Drinking Fountain across from Planning Room 210	<0.1*	
64400-203XH-DF	Hallway Drinking Fountain across from Planning Room 218X	<0.1*	
64400-252XH-DF	Hallway Drinking Fountain near Elevator on 2nd Floor	<0.1*	
64400-2022-252XH-WBFS	Water Bottle Filling Station near Elevator on 2nd Floor	0.1	
* This results is less than 0.1ppb, which is the lowest level that can be reported by the lab.			