

Doral Academy - Sampled 5/16/17				Resampled* 6/15/17	
SampleNumber	Description	Lead Result	Unit	Lead Result	Unit
49500-194-S	Sink in Clinic	6.0	ppb		
49500-204H-DF	Hallway Drinking Fountain by Cafeteria	0.3	ppb		
49500-600-S1	Food Service Sink-Sprayer	7.2	ppb		
49500-600-S2	Food Service Sink- Rinse/Sanitize	12.3	ppb		
49500-600-S3	Food Service Sink-Hand Sink	1.5	ppb		
49500-530H-DF	Hallway Drinking Fountain by Teacher's Lounge	0.8	ppb		
49500-530-S	Sink in Teacher's Lounge	6.6	ppb		
49500-153-S	Sink in Library Work Room	70.2	ppb	Fixture Signed ***	
49500-404-S1	Sink in Classroom 404	37.3	ppb	Fixture Signed ***	
49500-404-S2	Sink in Classroom 404	162.7	ppb	4.2	ppb
49500-116H-DF	Hallway Drinking Fountain across from Classroom 405	15.5	ppb	0.9	ppb
49500-304-S1	Sink in Classroom 304	32.6	ppb	2.5	ppb
49500-304-S2	Sink in Classroom 304	53.7	ppb	4.7	ppb
49500-145H-DF	Hallway Drinking Fountain across from Library	1.6	ppb		
49500-220-S1	Sink in Art Room	1.3	ppb		
49500-220-S2	Sink in Art Room	53.7	ppb	3.0	ppb
49500-142H-DF	Hallway Drinking Fountain across from Planning Room 201	2.2	ppb		
49500-202-S1	Sink in Classroom 202	45.4	ppb	Fixture Signed ***	
49500-202-S2	Sink in Classroom 202	52.5	ppb	Fixture Signed ***	
49500-202-SWB	Sink with Bubbler in Classroom 202	3.2	ppb		
49500-178H-DF	Hallway Drinking Fountain across from Classroom 105	6.9	ppb		
49500-104-S1	Sink in Classroom 104	21.6	ppb	1.9	ppb
49500-104-S2	Sink in Classroom 104	12.9	ppb		
49500-1-SWB	Sink with Bubbler in Kindergarten Room 1	0.6	ppb		
49500-1-S	Sink in Kindergarten Room 1	14.7	ppb		
49500-2-SWB	Sink with Bubbler in Kindergarten Room 2	1.3	ppb		
49500-2-S	Sink in Kindergarten Room 2	25.7	ppb	0.6	ppb
49500-111H-DF	Hallway Drinking Fountain across from Classroom 305	3.3**	ppb		
* Resampling results after elevated fixtures were repaired, or removed and replaced.					
** This fixture was sampled for the first time on 6/15/17.					
*** This fixture is signed "Do Not Drink, No Food Prep, For Hand Washing Only"					