

Deane Elementary - Sampled 6/14/16				Resampled* 11/11/16 or 3/10/17		Resampled*** 4/19/19	
SampleNumber	Description	Lead Result	Unit	Lead Result	Units	Lead Result	Units
42000-056-S1	Food Service Sink	3.3	ppb				
42000-056-S2	Food Service Sink			3.5**	ppb		
42000-014H-DFL	Hallway Drinking Fountain/Left-Outside Gym	15.7	ppb	19.9	ppb		Fixture Removed††
42000-014H-DFR	Hallway Drinking Fountain/Right-Outside Gym	6.6	ppb				Fixture Removed††
42000-014H-WBFS	Hallway Water Bottle Filling Station/Outside of Gym			1.0	ppb	0.7	ppb
42000-059H-DF	Hallway Drinking Fountain Near Room 18	11.0	ppb			8.5	ppb
42000-019-SWB	Sink with Bubblers in Room 19	2.0	ppb			1.8	ppb
42000-021-SWB	Sink with Bubblers in Room 21	0.9	ppb			0.8	ppb
42000-022-SWB	Sink with Bubblers in Room 22	2.3	ppb			1.6	ppb
42000-020-SWB	Sink with Bubblers in Room 20	0.8	ppb			0.6	ppb
42000-018-SWB	Sink with Bubblers in Room 18	2.6	ppb			2.0	ppb
42000-029-SWB	Sink with Bubblers in Room 29	1.9	ppb			1.9	ppb
42000-30H-DF	Hallway Drinking Fountain Near Room 30	0.3	ppb			<0.1†	ppb
42000-030H-WBFS	Hallway Water Bottle Filling Station/Near Room 30			<0.1† **	ppb	<0.1† **	ppb
42000-032-SWB	Sink with Bubblers in Room 32	0.2	ppb			0.1	ppb
42000-028-SWB	Sink with Bubblers in Room 28	2.6	ppb			1.2	ppb
42000-030-SWB	Sink with Bubblers in Room 30	2.1	ppb			1.8	ppb
42000-026-S1	Art Room Sink	0.5	ppb				
42000-026-S2	Art Room Sink	0.6	ppb				
42000-025-SWB	Sink with Bubblers in Room 25	0.5	ppb			0.2	ppb
42000-074-S	Sink in Teacher's Lounge	2.0	ppb			2.2	ppb
42000-004-SWB	Sink with Bubblers in Room 4	3.9	ppb			2.4	ppb
42000-007H-DFR	Hallway Drinking Fountain/Right-Near Room 4	25.2	ppb	39.6			Fixture Removed††
42000-007H-DFL	Hallway Drinking Fountain/Left-Near Room 4	21.8	ppb	15.0	ppb		Fixture Removed††
42000-007H-WBFS	Hallway Water Bottle Filling Station/Near Room 4			2.7	ppb	2.1	ppb
42000-006-SWB	Sink with Bubblers in Room 6	6.1	ppb			4.3	ppb
42000-008-SWB	Sink with Bubblers in Room 8	6.7	ppb			4.2	ppb
42000-010-SWB	Sink with Bubblers in Kindergarten Room 10	10.1	ppb			6.2	ppb
42000-012-SWB	Sink with Bubblers in Kindergarten Room 12	6.2	ppb			3.7	ppb
42000-015-SWB	Sink with Bubblers in Kindergarten Room 15	5.1	ppb			3.3	ppb
42000-011-SWB	Sink with Bubblers in Room 11	7.2	ppb			4.7	ppb
42000-009-SWB	Sink with Bubblers in Room 9	4.6	ppb			1.6	ppb
42000-089-S	Sink in Office Workroom	1.1	ppb				
42000-086-S	Sink in Clinic	0.7	ppb			0.5	ppb
42000-088-S	Sink in Clinic Restroom	8.2	ppb				
42000-R1-179-DF	Drinking Fountain in Temp R1-179	7.8	ppb			6.8	ppb
42000-RE-014-DF	Drinking Fountain in Temp RE-014	1.2	ppb			0.3	ppb
42000-RE-021-DF	Drinking Fountain in Temp RE-021	0.6	ppb			0.2	ppb
42000-016-S	Sink in Classroom 016	6.7**	ppb	7.6**	ppb		
42000-031-S	Sink in Classroom 031	0.7**	ppb	0.4**	ppb		
* Resampling results after elevated fixtures were removed and replaced.							
** This fixture was sampled on 11/11/16 or 3/10/17.							
*** Resampling results were from samples collected on 4/19/19 as part of an ongoing rotation of lead testing.							