

Deviny Elementary School - Sampled 6/21/16				Resampled ** 4/24/19	
SampleNumber	Description	Lead Result	Units	Lead Result	Units
10500-102H-DF	Hallway Drinking Fountain near Cafeteria	0.1	ppb	<0.1 *	ppb
10500-104-SWB	Sink with Bubblers in Classroom 104	<0.1 *	ppb	0.1	ppb
10500-105-SWB	Sink with Bubblers in Classroom 105	<0.1 *	ppb	<0.1 *	ppb
10500-106-SWB	Sink with Bubblers in Classroom 106	<0.1 *	ppb	0.1	ppb
10500-109-SWB	Sink with Bubblers in Classroom 109	<0.1 *	ppb	<0.1 *	ppb
10500-110-SWB	Sink with Bubblers in Classroom 110	<0.1 *	ppb	0.2	ppb
10500-111-SWB	Sink with Bubblers in Classroom 111	0.8	ppb	0.6	ppb
10500-156-S1	Art Room Sink	0.2	ppb		
10500-156-S2	Art Room Sink	0.8	ppb		
10500-156-S3	Art Room Sink	1.0	ppb		
10500-156-S4	Art Room Sink	0.3	ppb		
10500-157-SWB	Sink with Bubblers in Kindergarten Classroom 157	1.8	ppb	0.5	ppb
10500-160-SWB	Sink with Bubblers in Kindergarten Classroom 160	3.7	ppb	2.3	ppb
10500-161-SWB	Sink with Bubblers in Music Room	0.1	ppb	0.2	ppb
10500-121-SWB	Sink with Bubblers in Classroom 121	<0.1 *	ppb	0.2	ppb
10500-122-SWB	Sink with Bubblers in Classroom 122	<0.1 *	ppb	0.2	ppb
10500-123-SWB	Sink with Bubblers in Classroom 123	<0.1 *	ppb	0.2	ppb
10500-124-SWB	Sink with Bubblers in Classroom 124	0.2	ppb	0.2	ppb
10500-125-SWB	Sink with Bubblers in Classroom 125	0.1	ppb	0.2	ppb
10500-126-SWB	Sink with Bubblers in Classroom 126	<0.1 *	ppb	0.2	ppb
10500-127-SWB	Sink with Bubblers in Classroom 127	<0.1 *	ppb	0.2	ppb
10500-128-SWB	Sink with Bubblers in Classroom 128	0.1	ppb	0.2	ppb
10500-130H-DF	Hallway Drinking Fountain near Classroom 128	<0.1 *	ppb	0.1	ppb
10500-130H-WBFS	Hallway Water Bottle Filling Station near Classroom 128			0.1 ***	ppb
10500-132H-DF	Hallway Drinking Fountain near Music Room	0.4	ppb		
10500-135-SWB	Sink with Bubblers in Music Room	<0.1 *	ppb	0.2	ppb
10500-136-SWB	Sink with Bubblers in Classroom 136	<0.1 *	ppb	0.2	ppb
10500-137-SWB	Sink with Bubblers in Classroom 137	<0.1 *	ppb	0.1	ppb
10500-138-SWB	Sink with Bubblers in Classroom 138	<0.1 *	ppb	0.1	ppb
10500-139-SWB	Sink with Bubblers in Classroom 139	<0.1 *	ppb	<0.1 *	ppb
10500-140-SWB	Sink with Bubblers in Classroom 140	<0.1 *	ppb	<0.1 *	ppb
10500-142-S	Sink in Teacher's Lounge	<0.1 *	ppb	0.1	ppb
10500-149-S	Sink in Workroom across from Clinic	0.2	ppb	0.3	ppb
10500-145-S	Sink in Clinic	0.2	ppb	0.2	ppb
10500-115C-S	Sink in Library Workroom	0.2	ppb		
10500-166-S1	Food Service Sink-Sanitize	5.4	ppb	1.7	ppb
10500-166-S2	Food Service Sink-Wash	5.7	ppb	2.9	ppb
10500-166-S3	Food Service Sink-Hand Sink	11.4	ppb		
10500-162H-DF	Hallway Drinking Fountain near Gym	6.2	ppb	0.1	ppb
10500-162H-WBFS	Hallway Water Bottle Filling Station near Gym			0.1 ***	ppb
10500-312H-DF	Hallway Drinking Fountain			<0.1 * ***	ppb
10500-R1-227-S1	Sink in Temp R1-227	0.3	ppb		
10500-R1-227-S2	Sink in Temp R1-227	1.2	ppb		
10500-R1-227-DF	Drinking Fountain in Temp R1-227	0.3	ppb	0.2	ppb
10500-R1-228-DF	Drinking Fountain in Temp R1-228	0.5	ppb	0.3	ppb
10500-R1-228-S1	Sink in Temp R1-228	0.3	ppb		
10500-R1-228-S2	Sink in Temp R1-228	0.6	ppb		
10500-R1-201-S1	Sink in Temp R1-201	1.4	ppb		
10500-R1-201-DF	Drinking Fountain in Temp R1-201	1.7	ppb	1.3	ppb
10500-R1-201-S2	Sink in Temp R1-201	2.5	ppb		
10500-R1-229-S1	Sink in Temp R1-229	0.4	ppb		
10500-R1-229-S2	Sink in Temp R1-229	0.5	ppb		
10500-R1-229-DF	Drinking Fountain in Temp R1-229	0.1	ppb	0.4	ppb
10500-R1-235-DF	Drinking Fountain in Temp R1-235	3.1	ppb		Fixture Shut OFF
10500-R1-235-S	Sink in Temp R1-235	1.3	ppb		
10500-R1-236-DF	Drinking Fountain in Temp R1-236	13.0	ppb		Fixture Shut OFF
10500-R1-241-DF	Drinking Fountain in Temp R1-241	1.7	ppb		

\* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.

\*\* Resampling results were from samples collected on 4/24/19 as part of an ongoing rotation of lead testing.

\*\*\* This fixture was sampled for the first time on 4/24/19.