

<b>Dutch Creek Elementary School</b>		Sampled 4/13/2022
CustomerSampleNumber	Description	Lead Results (ppb)
10900-2022-017DH-DFL	Drinking Fountain across from Main Office/Left	0.4
10900-2022-017DH-DFR	Drinking Fountain across from Main Office/Right	1.5
10900-2022-017DH-WBFS	Water Bottle Filling Station across from Main Office	0.8
10900-2022-009BH-DFL	Drinking Fountain near Classroom 008/Left	1.7
10900-2022-009BH-DFR	Drinking Fountain near Classroom 008/Right	0.4
10900-2022-009BH-WBFS	Water Bottle Filling Station near Classroom 008	0.5
10900-047-S1	Food Service Sink-Prep Sink	2.2
10900-110-DFL	Hallway Drinking Fountain near Music Room/Left	0.2
10900-110-DFR	Hallway Drinking Fountain near Music Room/Right	0.1
10900-031-SWB	Sink with Bubbler in Classroom 031	<0.1*
10900-041-SWB	Sink with Bubbler in Classroom 041	0.2
10900-032-SWB	Sink with Bubbler in Classroom 032	<0.1*
10900-119H-DFL	Hallway Drinking Fountain across from Classroom 033/Left	<0.1*
10900-119H-DFR	Hallway Drinking Fountain across from Classroom 033/Right	<0.1*
10900-2022-119H-WBFS	Water Bottle Filling Station across from Classroom 033	<0.1*
10900-033-SWB	Sink with Bubbler in Classroom 033	<0.1*
10900-034-SWB	Sink with Bubbler in Classroom 034	<0.1*
10900-035-SWB	Sink with Bubbler in Classroom 035	0.1
10900-039-SWB	Sink with Bubbler in Classroom 039	<0.1*
10900-040-SWB	Sink with Bubbler in Classroom 040	0.1
10900-036-SWB	Sink with Bubbler in Classroom 036	<0.1*
10900-037-SWB	Sink with Bubbler in Classroom 037	<0.1*
10900-038-SWB	Sink with Bubbler in Classroom 038	<0.1*
10900-043-SWB2	Sink with Bubbler in Kindergarten Classroom 043	1.3
10900-043-SWB1	Sink with Bubbler in Kindergarten Classroom 043	Not in use
10900-2022-046A-DFL	Hallway Drinking Fountain near Teacher's Lounge/Left	0.4
10900-2022-046A-DFR	Hallway Drinking Fountain near Teacher's Lounge/Right	1.9
10900-2022-046A-WBFS	Water Bottle Filling Station in Hallway near Teacher's Lounge	0.6
10900-548-S	Sink in Teacher's Lounge	1.7
10900-D17H-S	Sink in Clinic	0.4
10900-D17H-SWB	Sink with Bubbler in Clinic	1.5

\* This results is less than 0.1ppb, which is the lowest level that can be reported by the lab.