

Edgewater Elementary School - Sampled 6/3/16				Resampled 4/28/17	
SampleNumber	Description	Lead Result	Units	Lead Result	Unit
11000-203-DFL	C-Wing Drinking Fountain/Left	0.3	ppb	0.2	ppb
11000-203-DFR	C-Wing Drinking Fountain/Right	0.2	ppb	<0.1*	ppb
11000-203-S	C-Wing Sink Near Room C-3	2.7	ppb		
11000-104-DFL	B-Wing Drinking Fountain/Left	0.3	ppb	0.1	ppb
11000-104-DFR	B-Wing Drinking Fountain/Right	0.2	ppb	<0.1*	ppb
11000-104-S	B-Wing Sink Near Room B-2	4.6	ppb		
11000-B-5-S	Art Room Sink	2.4	ppb		
11000-B-1-S	Music Room Sink	2.2	ppb		
11000-105-DF	Drinking Fountain in B-Wing Hall Near Restrooms	5.0	ppb	6.3	ppb
11000-119-DF	Drinking Fountain in Basement Near Elevator	0.5	ppb	0.2	ppb
11000-A-1-SWB	Sink with Bubbler in Room A-1	1.5	ppb	1.6	ppb
11000-A-2-SWB	Sink with Bubbler in Room A-2	2.7	ppb	3.1	ppb
11000-A-3-SWB	Sink with Bubbler in Room A-3	3.2	ppb	2.9	ppb
11000-A-4-SWB	Sink with Bubbler in Room A-4	3.4	ppb	2.9	ppb
11000-A-5-SWB	Sink with Bubbler in Kindergarten Room A-5	1.0	ppb	0.9	ppb
11000-A-6-SWB	Sink with Bubbler in Kindergarten Room A-6	0.7	ppb	1.0	ppb
11000-A-7-SWB	Sink with Bubbler in Kindergarten Room A-7	0.5	ppb	0.4	ppb
11000-A-8-SWB	Sink with Bubbler in Kindergarten Room A-8	2.2	ppb	1.0	ppb
11000-253-S	Sink in Library Workroom	18.0	ppb	†18.4	ppb
11000-220-S	Sink in Office Conference Room	0.5	ppb	0.6	ppb
11000-218-S	Sink in Clinic	0.6	ppb	0.6	ppb
11000-219-S	Sink in Clinic Restroom	0.7	ppb	0.5	ppb
11000-224-S1	Food Service Sink	2.0	ppb	1.8	ppb
11000-224-S2	Food Service Sink	1.8	ppb	1.2	ppb
11000-225-S1	Food Service Sink	1.4	ppb	1.9	ppb
11000-225-S2	Food Service Sink	6.8	ppb	6.8	ppb
11000-225-S3	Food Service Sink	1.3	ppb	1.3	ppb
11000-213A-DF	Drinking Fountain on Main Floor by Elevator	0.2	ppb	0.2	ppb
11000-C-8-H-DFL	C-Wing Drinking Fountain/Left	3.0	ppb	3.9	ppb
11000-208-S	Sink in Teacher's Lounge	0.4	ppb	0.4	ppb
11000-R1-131-DF	Drinking Fountain in TEMP R1-131	2.7	ppb	1.1	ppb
11000-REC-126-DF	Drinking Fountain in TEMP REC-126	1.3	ppb	0.3	ppb
11000-R1-100-DF	Drinking Fountain in TEMP R1-100	4.7	ppb	2.5	ppb
11000-R1-212-DF	Drinking Fountain in TEMP R1-212	0.7	ppb	0.4	ppb
11000-R1-127-DF	Drinking Fountain in TEMP R1-127	9.3	ppb	6.3	ppb
11000-RE-012-DF	Drinking Fountain in TEMP RE-012	1.1	ppb	1.8	ppb
11000-RE-006-DF	Drinking Fountain in TEMP RE-006	2.3	ppb	1.6	ppb
11000-R1-176-DF	Drinking Fountain in TEMP R1-176 ‡	17.8	ppb	‡25.2	ppb
11000-R1-054-DF	Drinking Fountain in TEMP R1-054	4.3	ppb	4.1	ppb
11000-A-4H-DFL	A-Wing Hallway Drinking Fountain/Left	0.2**	ppb	0.2	ppb
11000-A-4H-DFR	A-Wing Hallway Drinking Fountain/Right	0.2**	ppb	0.2	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** This fixture was sampled on 2/24/17.					
† This fixture is for adult use only, and is signed, "For Hand Washing Only."					
‡ This fixture is in a temporary building that is used for storage only, and is signed, "Do not Drink."					