

Falcon Bluffs Middle School		Sampled 4/22/2022
CustomerSampleNumber	Description	Lead Results (ppb)
65600-C101-DF	Drinking Fountain in Gym	<0.1*
65600-C105-DF	Drinking Fountain in Locker Room	0.1
65600-C117-DF	Drinking Fountain in Locker Room	<0.1*
65600-B123H-DF	Hallway Drinking Fountain between Classrooms B112 and B129	<0.1*
65600-B144H-DF	Hallway Drinking Fountain between Classrooms B150 and B133	<0.1*
65600-A120H-DF	Hallway Drinking Fountain between Classrooms A109 and A126	<0.1*
65600-A130H-DF	Hallway Drinking Fountain outside of Cafeteria	<0.1*
65600-2022-A130H-WBFS	Hallway water bottle filling station outside of Cafeteria	<0.1*
65600-A133-S	Sink in Teacher's Lounge A133	0.4
65600-A140-S2	Food Service Sink-Food Prep Sprayer	1.3
65600-A140-S3	Food Service Sink-Food Prep	0.8
65600-A102-S	Sink in Orchestra Room	0.8
65600-A107-S	Sink in Drama Room	2.7
65600-B161-S1	Sink in Kitchen Classroom B161	0.2
65600-B161-S2	Sink in Kitchen Classroom B161	0.4
65600-B161-S3	Sink in Kitchen Classroom B161	0.5
65600-B161-S4	Sink in Kitchen Classroom B161	0.5
65600-B161-S5	Sink in Kitchen Classroom B161	<0.1*
65600-B161-S6	Sink in Kitchen Classroom B161	0.2
65600-B161-S7	Sink in Kitchen Classroom B161	0.5
65600-B176-S	Sink in Teacher's Lounge B176	1.5
65600-B176-SWB	Sink with Bubbler in Teacher's Lounge B176	1.3
65600-2022-B176-WD	water dispenser in Teacher's Lounge B176	<0.1*
65600-B182-S	Sink in Clinic	0.4
65600-A221-DF	Hallway Drinking Fountain between Classrooms A226 and A209	<0.1*
65600-B234-SWB	Sink with Bubbler in Library Work Room	0.6
65600-2022-B234-S	Sink in library work room	2.2
65600-B219H-DF	Hallway Drinking Fountain between Classrooms B208 and B225	0.3
65600-2022-B219H-WBFS	Hallway water bottle filling station between Classrooms B208 and	<0.1*

* This results is less than 0.1ppb, which is the lowest level that can be reported by the lab.