

Fairmount Elementary School - 7/21/16				Resampled ** 11/9/16		Resampled *** 5/22/18	
SampleNumber	Description	Lead Result	Units	Lead Result	Units	Lead Result	Units
14000-102-S	Sink in Music Room	0.7	ppb				
14000-102-SWB	Sink with Bubbler in Music Room	0.2	ppb			0.8	ppb
14000-CR05H-DF	Hallway Drinking Fountain across from Gym	<0.1 *	ppb			<0.1 *	ppb
14000-101A-S	Sink in Main Office Area	0.2	ppb				
14000-101B-S	Sink in Clinic	0.3	ppb			0.6	ppb
14000-101J-S	Sink in Office Work Room	0.9	ppb				
14000-CR20H-DFL	Hallway Drinking Fountain across from Library/Left	11.4	ppb			7.0	ppb
14000-CR20H-DFR	Hallway Drinking Fountain across from Library/Right	9.0	ppb			6.4	ppb
14000-109-S1	Art Room Sink	<0.1 *	ppb				
14000-109-S2	Art Room Sink	0.4	ppb				
14000-110-S	Sink in Classroom 110	0.4	ppb				
14000-110-SWB	Sink with Bubbler in Classroom 110	2.0	ppb			1.0	ppb
14000-111-S	Sink in Classroom 111	0.4	ppb				
14000-111-SWB	Sink with Bubbler in Classroom 111	1.9	ppb			0.9	ppb
14000-114-S1	Sink in Work Room 114	0.2	ppb				
14000-114-S2	Sink in Work Room 114	41.4	ppb	1.0	ppb		
14000-114-SWB	Sink with Bubbler in Work Room 114	59.9	ppb	0.2	ppb	0.5	ppb
14000-CR14H-DF	Hallway Drinking Fountain outside of Work Room 114	0.2	ppb			<0.1 *	ppb
14000-116-S	Sink in Classroom 116	0.2	ppb				
14000-116-SWB	Sink with Bubbler in Classroom 116	2.2	ppb			0.8	ppb
14000-117-SWB	Sink with Bubbler in Classroom 117	1.2	ppb			0.6	ppb
14000-117-S	Sink in Classroom 117	0.3	ppb				
14000-118-S	Sink in Classroom 118	0.2	ppb				
14000-118-SWB	Sink with Bubbler in Classroom 118	1.2	ppb			0.7	ppb
14000-119-S1	Sink in Classroom 119	0.6	ppb				
14000-119-SWB1	Sink with Bubbler in Classroom 119	2.3	ppb			1.8	ppb
14000-119-S2	Sink in Classroom 119	0.4	ppb				
14000-119-SWB2	Sink with Bubbler in Classroom 119	3.1	ppb			0.8	ppb
14000-120-S	Sink in Classroom 120	0.5	ppb				
14000-120-SWB	Sink with Bubbler in Classroom 120	2.2	ppb			1.1	ppb
14000-121-S	Sink in Classroom 121	0.6	ppb				
14000-121-SWB	Sink with Bubbler in Classroom 121	2.0	ppb			0.7	ppb
14000-122-S	Sink in Classroom 122	0.9	ppb				
14000-122-SWB	Sink with Bubbler in Classroom 122	5.2	ppb			5.2	ppb
14000-125-S	Sink in Classroom 125	1.1	ppb				
14000-125-SWB	Sink with Bubbler in Classroom 125	0.3	ppb			0.9	ppb
14000-126-S	Sink in Classroom 126	0.4	ppb				
14000-126-SWB	Sink with Bubbler in Classroom 126	0.2	ppb			0.1	ppb
14000-127-S	Sink in Classroom 127	0.2	ppb				
14000-127-SWB	Sink with Bubbler in Classroom 127	0.1	ppb			<0.1 *	ppb
14000-128-S	Sink in Classroom 128	0.3	ppb				
14000-128-SWB	Sink with Bubbler in Classroom 128	<0.1 *	ppb			<0.1 *	ppb
14000-131-S	Sink in Classroom 131	1.3	ppb				
14000-131-SWB	Sink with Bubbler in Classroom 131	1.8	ppb			1.2	ppb
14000-132-S	Sink in Classroom 132	0.9	ppb				
14000-132-SWB	Sink with Bubbler in Classroom 132	2.3	ppb			0.9	ppb
14000-133-S	Sink in Classroom 133	19.8	ppb	0.8	ppb		
14000-133-SWB	Sink with Bubbler in Classroom 133	0.7	ppb			0.4	ppb
14000-134-S	Sink in Classroom 134	21.8	ppb	8.6	ppb		
14000-134-SWB	Sink with Bubbler in Classroom 134	6.3	ppb			3.9	ppb
14000-139-S	Sink in Teacher's Lounge	0.3	ppb			0.3	ppb
14000-140-S	Sink in Classroom 140	0.2	ppb				
14000-140-SWB	Sink with Bubbler in Classroom 140	0.2	ppb			<0.1 *	ppb
14000-141-S	Sink in Classroom 141	0.6	ppb				
14000-141-SWB	Sink with Bubbler in Classroom 141	0.2	ppb			<0.1 *	ppb
14000-142-S	Sink in Classroom 142	0.5	ppb				
14000-142-SWB	Sink with Bubbler in Classroom 142	0.1	ppb			<0.1 *	ppb
14000-143-S	Sink in Classroom 143	0.4	ppb				
14000-143-SWB	Sink with Bubbler in Classroom 143	<0.1 *	ppb			<0.1 *	ppb
14000-144-S	Sink in Classroom 144	0.6	ppb				
14000-144-SWB	Sink with Bubbler in Classroom 144	0.2	ppb			0.1	ppb
14000-145-S	Sink in Kindergarten Classroom 145	0.3	ppb				
14000-145-SWB	Sink with Bubbler in Kindergarten Classroom 145	0.2	ppb			0.1	ppb

14000-146-S	Sink in Kindergarten Classroom 146	0.3	ppb		
14000-146-SWB	Sink with Bubbler in Kindergarten Classroom 146	0.1	ppb		<0.1 *   ppb
14000-147-S	Sink in Kindergarten Classroom 147	0.3	ppb		
14000-147-SWB	Sink with Bubbler in Kindergarten Classroom 147	<0.1 *	ppb		<0.1 *   ppb
14000-138-S	Sink in Classroom 138	3.2	ppb		
14000-138-SWB	Sink with Bubbler in Classroom 138	3.1	ppb		3.2   ppb
14000-137-S	Sink in Classroom 137	1.5	ppb		
14000-137-SWB	Sink with Bubbler in Classroom 137	2.1	ppb		1.6   ppb
14000-136-S	Sink in Classroom 136	2.0	ppb		
14000-136-SWB	Sink with Bubbler in Classroom 136	1.5	ppb		0.9   ppb
14000-135-S	Sink in Classroom 135	4.9	ppb		
14000-135-SWB	Sink with Bubbler in Classroom 135	4.6	ppb		1.3   ppb
14000-130-S	Sink in Work Room 130	2.0	ppb		
14000-130-SWB	Sink with Bubbler in Work Room 130	0.7	ppb		0.5   ppb
14000-106-S1	Food Service Sink-Hand Sink	4.6	ppb		
14000-106-S2	Food Service Sink-Hand Sink	4.5	ppb		
14000-106-S3	Food Service Sink-Sprayer	2.1	ppb		
14000-106-S4	Food Service Sink-Wash	2.6	ppb		
14000-106-S5	Food Service Sink-Wash	2.5	ppb		
14000-106-S6	Food Service Sink-Hand Sink	0.7	ppb		
14000-106-S7	Food Service Sink-Food Prep	3.5	ppb		2.1   ppb
14000-106-S8	Food Service Sink-Hand Sprayer	6.6	ppb		1.7   ppb
14000-106-S9	Food Service Sink-Hand Sink	2.4	ppb		
14000-129B-S	Sink in Library Work Room	2.5	ppb		
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results after elevated fixtures were removed and replaced.					
*** Resampling results were from samples collected on 5/22/18 as part of an ongoing five-year rotation of lead testing.					