

Elk Creek Elementary School		Sampled 8/20/16	Sampled** 12/7/16	Sampled 7/26/17	Sampled 4/19/19
CustomerSampleNumber	Description	Lead Result (ppb)	Lead Result (ppb)	Lead Result (ppb)	Lead Result (ppb)
13000-100-S	Sink in Kindergarten Classroom 100	49.5	1.0	<1.0	
13000-100-SWB	Sink with Bubbler in Kindergarten Classroom 100	3.9		<1.0	
13000-101-S	Sink in Kindergarten Classroom 101	26.0	0.6	<1.0	
13000-101-SWB	Sink with Bubbler in Kindergarten Classroom 101	7.6		<1.0	0.2
13000-102-S	Sink in Classroom 102	13.7			
13000-102-SWB	Sink with Bubbler in Classroom 102	9.3			1.2
13000-123H-S	Hallway Sink across from Classroom 102	4.2		4.0	
13000-119H-DF	Hallway Drinking Fountain across from Classroom 103	15.4	30.6	8.0	
13000-104-S	Sink in Classroom 104	15.5	1.9	2.0	
13000-104-SWB	Sink with Bubbler in Classroom 104	4.5			0.7
13000-106-S	Sink in Classroom 106	8.0			
13000-106-SWB	Sink with Bubbler in Classroom 106	2.8			0.7
13000-120H-DF	Hallway Drinking Fountain across from Classroom 107	3.5			0.9
13000-108-S	Sink in Classroom 108	27.4	3.8	6.0	
13000-108-SWB	Sink with Bubbler in Classroom 108	21.4	6.4	7.0	
13000-205H-DF	Hallway Drinking Fountain across from Classroom 206	3.5			1.0
13000-156H-S	Hallway Sink across from Classroom 206	11.6		2.0	
13000-206-S	Sink in Classroom 206	21.6	1.8	<1.0	
13000-206-SWB	Sink with Bubbler in Classroom 206	3.4			0.3
13000-202-S	Sink in Classroom 202	4.4			
13000-202-SWB	Sink with Bubbler in Classroom 202	4.7			0.9
13000-201H-DF	Hallway Drinking Fountain across from Classroom 201	3.2			0.7
13000-200-S	Sink in Classroom 200	2.2			
13000-200-SWB	Sink with Bubbler in Classroom 200	2.1			1.0
13000-510-S	Sink in Classroom 510	1.6			
13000-510-SWB	Sink with Bubbler in Classroom 510	3.8			0.4
13000-510H-DF	Hallway Drinking Fountain across from Classroom 510	0.2			0.2
13000-511-S	Sink in Classroom 511	0.8			
13000-511-SWB	Sink with Bubbler in Classroom 511	2.7			
13000-512-S	Sink in Classroom 512	0.9			
13000-512-SWB	Sink with Bubbler in Classroom 512	2.0			2.5
13000-513-S	Sink in Classroom 513	0.4			
13000-513-SWB	Sink with Bubbler in Classroom 513	2.4			77.4
13000-514-S	Sink in Classroom 514	1.3			
13000-514-SWB	Sink with Bubbler in Classroom 514	3.2			
13000-515-S	Sink in Classroom 515	1.3			
13000-515-SWB	Sink with Bubbler in Classroom 515	3.4			3.8
13000-514H-DF	Hallway Drinking Fountain across from Classroom 514	0.2			<0.1
13000-177-S1	Food Service Sink-Hand Sink	7.2		1.0	
13000-177-S2	Food Service Sink-Food Prep	18.6	1.3	2.0	
13000-177-S3	Food Service Sink-Sanitize/Rinse	12.3			
13000-177-S4	Food Service Sink-Rinse/Wash	31.0	2.2	<1.0	
13000-177-S5	Food Service Sink-Sprayer	3.8			
13000-137-S	Sink in Teacher's Lounge	3.6			
13000-306H-DFL	Hallway Drinking Fountain across from Art Room/Left	3.4			0.2
13000-306H-DFR	Hallway Drinking Fountain across from Art Room/Right	2.0			0.3
13000-305-S1	Art Room Sink	1.7			
13000-305-S2	Art Room Sink	2.9			
13000-305-S3	Art Room Sink	2.4			
13000-305-S4	Art Room Sink	2.5			
13000-133-S	Sink in Library Work Room	13.3		7.0	
13000-191-S	Sink in Main Office Work Room	5.8			
13000-195-S	Sink in Clinic	5.1		3.0	
WTP-2017-07	Water Treatment Plant			1.0	
306-RR-2017-07	Restroom 306 Hand Sink			<1.0	
131-S	137 misread as 131; sink in Teacher's Lounge-see 137-S above			<1.0	
N11-H-S3	Hand sink in first floor restroom area			<1.0	

Please note: results in first two columns were from 250 mL samples collected per EPA's 3Ts sampling guidance; results in third column were from 1 liter samples collected per the lead and Copper Rule.