

Fremont Elementary School - Sampled 7/15/16				Resampled* 8/12/16 or 11/30/16		Resampled** 5/17/18	
SampleNumber	Description	Lead Result	Units	Lead Result	Units	Lead Result	Units
16000-041-S	Sink in Library	36.0	ppb	14.5	ppb		
16000-041-SWB	Sink with Bubbler in Library	14.8	ppb			18.6 ‡	ppb
16000-039-S	Sink in Classroom 039	38.9	ppb	127.6	ppb	7.2	ppb
16000-039-SWB	Sink with Bubbler in Classroom 039	24.5	ppb	89.7	ppb	15.5 ‡	ppb
16000-037-S	Sink in Classroom 037	149.7	ppb	15.3	ppb	10.0	ppb
16000-037-SWB	Sink with Bubbler in Classroom 037	10.2	ppb			5.7	ppb
16000-140H-DFL	Hallway Drinking Fountain across from Classroom 034/Left	13.2	ppb			7.6	ppb
16000-140H-DFR	Hallway Drinking Fountain across from Classroom 034/Right	8.1	ppb			4.4	ppb
16000-036-SWB	Sink with Bubbler in Classroom 036	5.9	ppb			3.8	ppb
16000-036-S	Sink in Classroom 036	72.3	ppb	11.7	ppb		
16000-038-S	Sink in Classroom 038	155.3	ppb	13.4	ppb		
16000-038-SWB	Sink with Bubbler in Classroom 038	8.0	ppb			4.4	ppb
16000-030-S1	Food Service Sink-Sprayer	4.1	ppb				
16000-030-S2	Food Service Sink-Wash	12.8	ppb				
16000-030-S3	Food Service Sink-Food Prep	8.0	ppb			6.4	ppb
16000-030-S4	Food Service Sink-Hand Sink	9.5	ppb				
16000-002-S	Sink in Clinic	0.5	ppb			0.3	ppb
16000-006-S	Sink in Classroom 006	6.9	ppb				
16000-006-DF	Drinking Fountain in Classroom 006	9.3	ppb			6.0	ppb
16000-008-S	Sink in Classroom 008	14.9	ppb				
16000-008-DF	Drinking Fountain in Classroom 008	7.8	ppb			6.9	ppb
16000-113H-DFL	Hallway Drinking Fountain across from Classroom 009/Left	3.8	ppb			1.9	ppb
16000-113H-DFR	Hallway Drinking Fountain across from Classroom 009/Right	3.7	ppb			1.0	ppb
16000-010-S1	Sink in Kindergarten Classroom 010	46.7	ppb	7.8	ppb		
16000-010-SWB1	Sink with Bubbler in Kindergarten Classroom 010	10.9	ppb			9.5	ppb
16000-010-S2	Sink in Kindergarten Classroom 010	136.0	ppb	12.0	ppb	68.2 †	ppb
16000-010-SWB2	Sink with Bubbler in Kindergarten Classroom 010	20.8	ppb	75.6	ppb	27.9 ‡	ppb
16000-015-SWB	Sink with Bubbler in Kindergarten Classroom 015	8.3	ppb			7.5	ppb
16000-015-S	Sink in Kindergarten Classroom 015	65.6	ppb	4.5	ppb		
16000-013-S	Sink in Classroom 013	4.9	ppb				
16000-013-SWB	Sink with Bubbler in Classroom 013	6.0	ppb			6.2	ppb
16000-009-DF	Drinking Fountain in Classroom 009	14.8	ppb			2.6	ppb
16000-009-S	Sink in Classroom 009	28.6	ppb	3.1	ppb		
16000-007-DF	Drinking Fountain in Classroom 007	6.6	ppb			4.1	ppb
16000-007-S	Sink in Classroom 007	16.0	ppb	3.8	ppb		
16000-005-DF	Drinking Fountain in Teacher's Lounge	18.4	ppb	12.6	ppb	13.8	ppb
16000-005-S	Sink in Teacher's Lounge	3.2	ppb			1.1	ppb
16000-024-DF	Drinking Fountain in Classroom 024	8.7 ***	ppb				
16000-026-DF	Drinking Fountain in Classroom 026	11.0	ppb			5.8	ppb
16000-042-S1	Sink in Classroom 042	7.4 ***	ppb				
16000-042-S2	Sink in Classroom 042	1.3 ***	ppb				
16000-042-S3	Sink in Classroom 042	0.5 ***	ppb				
16000-042-S4	Sink in Classroom 042	1.0 ***	ppb				
16000-029-DF	Drinking Fountain in Classroom 029	10.0 ***	ppb			6.4	ppb
16000-027-S	Sink in Classroom 027	10.0 ***	ppb				
16000-025-DF	Drinking Fountain in Classroom 025	8.4	ppb			6.7	ppb
16000-023-DF	Drinking Fountain in Classroom 023	8.9	ppb			7.4	ppb
16000-101.2H-DF	Drinking Fountain in Hallway	0.6 ***	ppb				
16000-041.1-S	Sink in Room 041.1	10.6 ***	ppb				
16000-041.1-SWB	Sink with Bubbler in Room 041.1	6.6 ***	ppb				
16000-REC-059-DF	Drinking Fountain in TEMP REC-059	1.3	ppb			1.9	ppb
16000-REC-069-DF	Drinking Fountain in TEMP REC-069	0.7	ppb			0.3	ppb
16000-REC-058-DF	Drinking Fountain in TEMP REC-058	1.2	ppb			0.5	ppb

\* Resampling results after elevated fixtures were repaired, or removed and replaced.

\*\* Resampling results were from samples collected on 5/17/18 as part of an ongoing rotation of lead testing.

\*\*\* This fixture was sampled for the first time on 8/12/16 or 11/30/16.

† This fixture is signed "Do Not Drink, Hand Washing Only"

‡ This fixture is signed "Fountain Out of Service, Do Not Drink"