

Kendrick Lakes Elementary School - Sampled 6/14/16				Resampled* 8/13/16		Resampled** 4/30/19	
SampleNumber	Description	Lead Result	Units	Lead Result	Units	Lead Result	Units
21500-15XH-DF	Hallway Drinking Fountain near Classroom 18	3.8	ppb				
21500-13XH-SWB	Hallway Sink with Bubbler	1.4	ppb			0.6	ppb
21500-23-S	Sink in Planning Room near Office	1.1	ppb				
21500-178-S	Sink in Clinic	3.2	ppb			5.1	ppb
21500-36H-SWB	Hallway Sink with Bubbler	3.8	ppb			1.5	ppb
21500-37H-DF	Hallway Drinking Fountain near Classroom 1	7.5	ppb			7.1	ppb
21500-3-SWB	Sink with Bubbler in Classroom 3	7.1	ppb			4.5	ppb
21500-50-S1	Art Room Sink	1.0	ppb				
21500-50-S2	Art Room Sink	0.9	ppb				
21500-51-SWB1	Sink with Bubbler in Kindergarten Class 51	2.3	ppb			2.0	ppb
21500-51-SWB2	Sink with Bubbler in Kindergarten Class 51	3.4	ppb			2.0	ppb
21500-6-SWB	Sink with Bubbler in Classroom 6	6.9	ppb			5.0	ppb
21500-58H-SWB	Hallway Sink with Bubbler	0.8	ppb			0.5	ppb
21500-23X-S1	Food Service Sink - Wash/Rinse/Sanitize	4.7	ppb			4.1	ppb
21500-23X-S2	Food Service Sink - Hose Connection Spigot	24.5	ppb	Fixture Removed			
21500-23X-S3	Food Service Sink - Hand Sink	1.8	ppb				
21500-23X-S4	Food Service Sink	3.6	ppb			17.0	ppb
21500-23X-S5	Food Service Sink	2.6	ppb			8.7	ppb
21500-21X-S	Sink in Kitchen Restroom	9.7	ppb				
21500-57-S	Sink in Teacher's Lounge	2.7	ppb			2.0	ppb
21500-57H-SWB	Hallway Sink with Bubbler	2.1	ppb			1.9	ppb
21500-29X-S	Sink in Restroom by Cafeteria	0.6	ppb				
21500-11-SWB	Sink with Bubbler in Classroom 11	5.8	ppb			4.7	ppb
21500-12-SWB	Sink with Bubbler in Classroom 12	4.2	ppb			3.9	ppb
21500-15H-SWB	Hallway Sink with Bubbler	0.9	ppb			1.0	ppb
21500-RE-028-S1	Sink in Temp RE-028	3.9	ppb				
21500-RE-028-DF	Drinking Fountain in Temp RE-028	0.6	ppb			0.9	ppb
21500-RE-028-S2	Sink in Temp RE-028	0.8	ppb				
21500-RE-029-S1	Sink in Temp RE-029	0.3	ppb				
21500-RE-029-DF	Drinking Fountain in Temp RE-029	0.2	ppb			0.3	ppb
21500-RE-029-S2	Sink in Temp RE-029	0.4	ppb				
* Resampling results after elevated fixtures were removed and replaced.							
** Resampling results were from samples collected on 4/30/19 as part of an ongoing rotation of lead testing.							