

Long View High School - Sampled 10/21/16				Resampled* 4/25/19	
SampleNumber	Description	Lead Result	Unit	Lead Result	Unit
55010-X004-S	Sink in Student Dining Area	3.9	ppb	0.6	ppb
55010-X004-DF	Drinking Fountain in Student Dining Area	1.0	ppb	1.4	ppb
55010-X004-WBFS	Water Bottle Filling Station in Student Dining Area	2.1 **	ppb		
* Resampling results were from samples collected on 4/25/19 as part of an ongoing rotation of lead testing.					