

Lasley Elementary School - Sampled 7/8/16 or 11/11/16				Resampled** 11/11/16		Resampled† 5/7/19	
SampleNumber	Description	Lead Result	Units	Lead Result	Units	Lead Result	Units
22500-135H-DFL	Hallway Drinking Fountain near Art Room/Left	0.4	ppb			0.3	ppb
22500-135H-DFR	Hallway Drinking Fountain near Art Room/Right	0.5	ppb			0.4	ppb
22500-132-S	Sink in Classroom 132	1.3	ppb				
22500-132-SWB	Sink with Bubbler in Classroom 132	0.6	ppb			0.8	ppb
22500-130-S	Sink in Classroom 130	2.2	ppb				
22500-130-SWB	Sink with Bubbler in Classroom 130	1.0	ppb			2.3	ppb
22500-128-S	Sink in Classroom 128	1.2	ppb				
22500-128-SWB	Sink with Bubbler in Classroom 128	0.2	ppb			0.6	ppb
22500-109-S	Sink in the Work/Prep Room	71.7	ppb	6.2	ppb		
22500-114-S	Sink in Classroom 114	2.2	ppb				
22500-114-SWB	Sink with Bubbler in Classroom 114	1.0	ppb			3.4	ppb
22500-113H-DF	Hallway Drinking Fountain near Classroom 114	2.1	ppb			2.1	ppb
22500-107-S	Sink in Classroom 107	12.2	ppb				
22500-105-S	Sink in Classroom 105	5.3	ppb				
22500-105-SWB	Sink with Bubbler in Classroom 105	1.3	ppb				
22500-103-S	Sink in Classroom 103	4.3	ppb				
22500-103-SWB	Sink with Bubbler in Classroom 103	7.2	ppb			8.6	ppb
22500-101-S	Sink in Classroom 101	21.5	ppb	1.9	ppb		
22500-101-SWB	Sink with Bubbler in Classroom 101	5.6	ppb			2.8	ppb
22500-102-S	Sink in Classroom 102	5.5	ppb				
22500-102-SWB	Sink with Bubbler in Classroom 102	2.0	ppb			2.7	ppb
22500-104-S	Sink in Classroom 104	4.1	ppb				
22500-104-SWB	Sink with Bubbler in Classroom 104	4.7	ppb			5.0	ppb
22500-106-S	Sink in Classroom 106	3.3	ppb				
22500-106-SWB	Sink with Bubbler in Classroom 106	1.0	ppb			2.2	ppb
22500-118-S	Sink in Classroom 118	2.6	ppb				
22500-118-SWB	Sink with Bubbler in Classroom 118	<0.1 *	ppb			0.1	ppb
22500-119-S	Sink in Classroom 119	2.1	ppb				
22500-119-SWB	Sink with Bubbler in Classroom 119	<0.1 *	ppb			<0.1 *	ppb
22500-120H-DF	Hallway Drinking Fountain near Classroom 125	0.3	ppb			0.2	ppb
22500-125-S	Sink in Classroom 125	5.0	ppb				
22500-125-SWB	Sink with Bubbler in Classroom 125	<0.1 *	ppb			0.2	ppb
22500-126-S	Sink in Classroom 126	3.2	ppb				
22500-126-SWB	Sink with Bubbler in Classroom 126	<0.1 *	ppb				
22500-127-S	Sink in Classroom 127	50.3	ppb	2.2	ppb		
22500-127-SWB	Sink with Bubbler in Classroom 127	0.6	ppb			0.1	ppb
22500-129-S	Sink in Classroom 129	1.2	ppb				
22500-129-SWB	Sink with Bubbler in Classroom 129	0.6	ppb			0.1	ppb
22500-131-S	Sink in Classroom 131	2.9	ppb				
22500-131-SWB	Sink with Bubbler in Classroom 131	2.4	ppb			3.5	ppb
22500-133-S	Sink in Classroom 133	1.6	ppb				
22500-133-SWB	Sink with Bubbler in Classroom 133	0.7	ppb			1.2	ppb
22500-161-S	Art Room Sink	1.5	ppb				
22500-166-DF	Drinking Fountain in Cafeteria	11.2	ppb			4.5	ppb
22500-167-S1	Food Service Sink-Hand Sink	8.0	ppb				
22500-167-S2	Food Service Sink-Food Prep	5.8	ppb			1.5	ppb
22500-167-S3	Food Service Sink-Wash/Rinse	4.9	ppb				
22500-167-S4	Food Service Sink-Wash/Rinse	6.9	ppb				
22500-172-S	Sink in Music Room	0.9	ppb				
22500-172-SWB	Sink with Bubbler in Music Room	0.5	ppb			0.6	ppb
22500-100H-DF	Hallway Drinking Fountain near Music Room	1.6	ppb			0.2	ppb
22500-100H-WBFS	Hallway Water Bottle Filling Station near Music Room					0.1	ppb
22500-107-SWB	Sink with Bubbler in Classroom 107	2.1	ppb			2.0	ppb
22500-R1-081-DF	Drinking Fountain in TEMP R1-081	18.2	ppb	17.3	ppb		
22500-R1-200-DF	Drinking Fountain in TEMP R1-200	1.8	ppb			2.6	ppb
22500-167-S5	Food Service Sink-Sprayer	9.4	ppb				
22500-179H-DF	Hallway Drinking Fountain outside of Teacher's Lounge	1.3 ***	ppb			1.5	ppb
22500-186-S	Sink in Clinic	0.8 ***	ppb			1.3	ppb
22500-186-SWB	Sink with Bubbler in Clinic	0.5 ***	ppb			0.7	ppb

22500-184-S	Sink in Workroom near Principal's Office	3.5 ***	ppb	5.9	ppb
22500-196-S	Sink in Classroom 196	4.3 ***	ppb		
22500-196-SWB	Sink with Bubblers in Classroom 196	<0.1 * ***	ppb	0.1	ppb
22500-197-S	Sink in Classroom 197	5.6 ***	ppb		
22500-197-SWB	Sink with Bubblers in Classroom 197	<0.1 * ***	ppb	0.1	ppb
22500-191H-DF	Hallway Drinking Fountain across from Classroom 197	0.2 ***	ppb	0.3	ppb
22500-198-S	Sink in Classroom 198	3.0 ***	ppb		
22500-198-SWB	Sink with Bubblers in Classroom 198	<0.1 * ***	ppb	0.2	ppb
22500-199-S	Sink in Classroom 199	2.0 ***	ppb		
22500-199-SWB	Sink with Bubblers in Classroom 199	<0.1 * ***	ppb	0.2	ppb
22500-208-S	Sink in Classroom 208	10.0 ***	ppb		
22500-208-SWB	Sink with Bubblers in Classroom 208	<0.1 * ***	ppb	0.2	ppb
22500-209-S	Sink in Kindergarten Classroom 209	<0.1 * ***	ppb		
22500-209-SWB	Sink with Bubblers in Kindergarten Classroom 209	0.4 ***	ppb	0.3	ppb
22500-210-S	Sink in Kindergarten Classroom 210	0.7 ***	ppb		
22500-210-SWB	Sink with Bubblers in Kindergarten Classroom 210	<0.1 * ***	ppb	0.3	ppb
22500-211-S	Sink in Kindergarten Classroom 211	0.7 ***	ppb		
22500-211-SWB	Sink with Bubblers in Kindergarten Classroom 211	<0.1 * ***	ppb	0.6	ppb
22500-154-S	Sink in Classroom 154	1.2 ***	ppb		
22500-154-SWB	Sink with Bubblers in Classroom 154	0.3 ***	ppb	0.9	ppb
22500-155-S	Sink in Classroom 155	4.3 ***	ppb		
22500-155-SWB	Sink with Bubblers in Classroom 155	0.4 ***	ppb	1.9	ppb
22500-156-S	Sink in Classroom 155	2.6 ***	ppb		
22500-156-SWB	Sink with Bubblers in Classroom 155	0.5 ***	ppb	1.6	ppb
22500-158-S	Sink in Classroom 158	2.0 ***	ppb		
22500-158-SWB	Sink with Bubblers in Classroom 158	3.1 ***	ppb	3.5	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results after elevated fixtures were removed and replaced.					
*** This fixture was sampled for the first time on 11/11/16.					
† Resampling results were from samples collected on 5/7/19 as part of an ongoing rotation of lead testing.					