

Maple Grove Elementary School - Sampled 7/22/16				Resampled * 8/31/16		Resampled ** 5/2/18 or 5/4/18	
SampleNumber	Description	Lead Result	Units	Lead Result	Units	Lead Result	Units
25100-A55-S	Sink in Clinic	0.3	ppb			0.3	ppb
25100-A61-S	Sink in Teacher's Planning Room	0.3	ppb			0.5	ppb
25100-A65-S	Sink in Teacher's Lounge	0.1	ppb			0.2	ppb
25100-A66H-DF	Hallway Drinking Fountain near Office's	0.7	ppb			0.9	ppb
25100-03-SWB	Sink with Bubblers in Classroom 03	0.7	ppb			1.0	ppb
25100-03-S	Sink in Classroom 03	0.5	ppb				
25100-05-SWB	Sink with Bubblers in Classroom 05	0.5	ppb			0.3	ppb
25100-05-S	Sink in Classroom 05	0.4	ppb				
25100-07-S	Sink in Classroom 07	0.2	ppb				
25100-07-SWB	Sink with Bubblers in Classroom 07	0.2	ppb			0.1	ppb
25100-09-S	Sink in Classroom 09	0.3	ppb				
25100-09-SWB	Sink with Bubblers in Classroom 09	0.2	ppb			0.1	ppb
25100-11-SWB	Sink with Bubblers in Kindergarten Classroom 11	1.1	ppb			0.6	ppb
25100-11-S	Sink in Kindergarten Classroom 11	0.6	ppb				
25100-10-S	Sink in Kindergarten Classroom 10	0.9	ppb				
25100-10-SWB	Sink with Bubblers in Kindergarten Classroom 10	1.9	ppb			1.1	ppb
25100-08-S	Sink in Classroom 08	0.5	ppb				
25100-08-SWB	Sink with Bubblers in Classroom 08	1.1	ppb			0.5	ppb
25100-06-SWB	Sink with Bubblers in Classroom 06	0.5	ppb			0.6	ppb
25100-06-S	Sink in Classroom 06	0.3	ppb				
25100-04-S	Sink in Classroom 04	0.8	ppb				
25100-04-SWB	Sink with Bubblers in Classroom 04	0.3	ppb			0.6	ppb
25100-02-S	Sink in Classroom 02	0.7	ppb				
25100-02-SWB	Sink with Bubblers in Classroom 02	1.0	ppb			1.2	ppb
25100-13-S	Sink in Classroom 13	195.0	ppb	4.3	ppb	0.6	ppb
25100-13-SWB	Sink with Bubblers in Classroom 13	0.4	ppb			1.0	ppb
25100-15-S	Sink in Classroom 15	0.7	ppb				
25100-15-SWB	Sink with Bubblers in Classroom 15	0.5	ppb			0.7	ppb
25100-17-SWB	Sink with Bubblers in Classroom 17	1.3	ppb			1.5	ppb
25100-17-S	Sink in Classroom 17	14.4	ppb				
25100-A02H-DF	Hallway Drinking Fountain across from Classroom 17	2.5	ppb			2.7	ppb
25100-19-S	Sink in Classroom 19	3.2	ppb				
25100-19-SWB	Sink with Bubblers in Classroom 19	1.0	ppb			4.1	ppb
25100-16-S	Sink in Classroom 16	3.2	ppb				
25100-16-SWB	Sink with Bubblers in Classroom 16	0.9	ppb			3.4	ppb
25100-14-S	Sink in Classroom 14	1.0	ppb				
25100-14-SWB	Sink with Bubblers in Classroom 14	2.0	ppb			1.4	ppb
25100-12-S1	Art Room Sink	0.9	ppb				
25100-12-S2	Art Room Sink	0.6	ppb				
25100-A41H-DF	Hallway Drinking Fountain near Kitchen	0.1	ppb			0.2	ppb
25100-A41-S1	Food Service Sink-Hand Sink	3.5	ppb				
25100-A41-S2	Food Service Sink-Sprayer	0.9	ppb				
25100-A41-S3	Food Service Sink-Wash	9.1	ppb				
25100-A41-S4	Food Service Sink-Hand Sink	6.9	ppb				
25100-A41-S5	Food Service Sink-Food Prep	16.7	ppb	14.1	ppb	1.1	ppb
25100-A41-S6	Food Service Sink-Food Prep	2.1	ppb			0.4	ppb
* Resampling results after elevated fixtures were removed and replaced.							
** Resampling results were from samples collected on 5/2/18 or 5/4/18 as part of an ongoing five-year rotation of lead testing.							