

Lukas Elementary School - 6/23/20 [†]			
CustomerSampleNumber	Description	Lead Result	Units
23800-110-S	Sink in Clinic	0.8	ppb
23800-123H-DF	Hallway Drinking Fountain by Music Room	0.8	ppb
23800-122-S1	Food Service Sink-Wash/Rinse	2.9	ppb
23800-122-S2	Food Service Sink-Rinse/Sanitize	8.0	ppb
23800-122-S3	Food Service Sink-Sprayer	3.3	ppb
23800-122-S4	Food Service Sink-Hand Sink	1.2*	ppb
23800-126-S1	Art Room Sink	1.9*	ppb
23800-126-S2	Art Room Sink	1.5*	ppb
23800-126-S3	Art Room Sink	1.0*	ppb
23800-126-S4	Art Room Sink	0.8*	ppb
23800-126-S5	Art Room Sink	1.0*	ppb
23800-126-S6	Art Room Sink	1.2*	ppb
23800-126-S7	Art Room Sink	0.8*	ppb
23800-126-S8	Art Room Sink	0.8*	ppb
23800-21-S	Sink in Classroom 21	1.0	ppb
23800-20-S	Sink in Classroom 20	1.2	ppb
23800-19-S	Sink in Classroom 19	0.9	ppb
23800-141H-DF	Hallway Drinking Fountain near Classroom 18	0.3	ppb
23800-18-S	Sink in Classroom 18	0.7	ppb
23800-16-S	Sink in Classroom 16	0.9	ppb
23800-15-S	Sink in Classroom 15	0.7	ppb
23800-148H-DF	Hallway Drinking Fountain near Classroom 15	0.4	ppb
23800-14-S	Sink in Classroom 14	0.7	ppb
23800-13-S	Sink in Classroom 13	0.7	ppb
23800-158H-DF	Hallway Drinking Fountain near Classroom 12	0.6	ppb
23800-12-S	Sink in Classroom 12	1.0	ppb
23800-10-S	Sink in Classroom 10	0.6	ppb
23800-157H-DF	Hallway Drinking Fountain near Classroom 10	0.2	ppb
23800-009-S	Sink in Classroom 009	0.5	ppb
23800-008-S	Sink in Classroom 008	0.5	ppb
23800-167-S	Sink in Library Work Room	2.2*	ppb
23800-174H-DF	Hallway Drinking Fountain near Classroom 007	0.8	ppb
23800-007-S	Sink in Classroom 007	1.8	ppb
23800-006-S	Sink in Classroom 006	2.1	ppb
23800-004-S	Sink in Classroom 004	1.6	ppb
23800-181H-DF	Hallway Drinking Fountain near Classroom 003	0.5	ppb
23800-003-S	Sink in Classroom 003	1.0	ppb
23800-002-S	Sink in Classroom 002	1.5	ppb
23800-001-S	Sink in Classroom 001	1.0	ppb
23800-191-S	Sink in Teacher's Lounge	0.6	ppb
23800-195H-DFL	Hallway Drinking Fountain near Main Office/Left	1.2	ppb
23800-195H-DFR	Hallway Drinking Fountain near Main Office/Right	1.3	ppb
23800-K2-S	Sink in Kindergarten Classroom K2	1.5	ppb
23800-K1-S	Sink in Kindergarten Classroom K1	1.5	ppb
23800-114-S	Sink in room 114	5.7	ppb
*Sampled on 10/14/16			
† Sampled as part of Jeffco's ongoing 5 year sampling program.			