

McLain Community School - Sampled 7/29/16				Resampled** 4/25/19	
SampleNumber	Description	Lead Result	Units	Lead Result	Units
52700-130-S1	Sink in Child Lab 130	1.8	ppb	0.2	ppb
52700-130-S2	Sink in Child Lab 130	0.9	ppb	0.9	ppb
52700-133-S1	Sink in Child Lab 133	1.3	ppb	1.0	ppb
52700-133-S2	Sink in Child Lab 133	1.9	ppb	1.7	ppb
52700-135-S1	Sink in Child Lab 135	2.0	ppb	1.9	ppb
52700-135-S2	Sink in Child Lab 135	1.7	ppb	1.0	ppb
52700-137-S1	Sink in Computer Room 137	3.8	ppb	3.6	ppb
52700-137-S2	Sink in Computer Room 137	2.1	ppb	2.1	ppb
52700-136-S1	Hand Washing Sink in Child Lab 136	3.2	ppb		
52700-136-S2	Food Prep Sink in Child Lab 136	2.6	ppb	1.3	ppb
52700-134-S1	Hand Washing Sink in Child Lab 134	1.5	ppb		
52700-134-S2	Food Prep Sink in Child Lab 134	0.9	ppb	0.3	ppb
52700-132-S1	Hand Washing Sink in Child Lab 132	6.1	ppb		
52700-132-S2	Food Prep Sink in Child Lab 132	1.7	ppb	0.9	ppb
52700-131-S1	Bottle Prep Sink in Child Lab 131	2.9	ppb	0.7	ppb
52700-131-S2	Hand Washing Sink in Child Lab 131	2.1	ppb		
52700-119-S	Sink in Planning Room 119	0.6	ppb		
52700-119-SA	Sink in Planning Room 119 - Filtered	<0.1* †	ppb		
52700-119-SB	Sink in Planning Room 119 - Not Filtered	0.2*	ppb		
52700-117-S	Sink in Clinic	1.0	ppb	0.7	ppb
52700-1DH-DFL	Hallway Drinking Fountain across from Classroom 110/Left	1.2	ppb	0.2	ppb
52700-1DH-DFR	Hallway Drinking Fountain across from Classroom 110/Right	0.3	ppb	0.4	ppb
52700-104-S1	Sink in FACS Lab	1.9	ppb	0.7	ppb
52700-104-S2	Sink in FACS Lab	1.5	ppb	0.5	ppb
52700-104-S3	Sink in FACS Lab	2.9	ppb	0.7	ppb
52700-104-S4	Sink in FACS Lab	2.5	ppb	0.6	ppb
52700-104-S5	Sink in FACS Lab	1.4	ppb		
52700-104B-S	Sink in Laundry Room	0.8	ppb		
52700-102-S1	Sink in Laboratory Room 102	0.5	ppb		
52700-102-S2	Sink in Laboratory Room 102	0.6	ppb		
52700-102-S3	Sink in Laboratory Room 102	0.8	ppb		
52700-139A-S	Sink in Science Prep Room	0.6	ppb		
52700-1DH-WBFS	Hallway Water Bottle Filling Station across from Classroom 110	0.2*			
52700-217-S1	Sink in Classroom 217	0.7*			
52700-217-S2	Sink in Classroom 217	0.6*			
52700-219-S	Sink in Classroom 219	1.9*			
52700-2EH-DFL	Hallway Drinking Fountain outside of Planning Room 207/Left	0.2*			
52700-2EH-DFR	Hallway Drinking Fountain outside of Planning Room 207/Right	0.9*			
52700-2EH-WBFS	Hallway Water Bottle Filling Station outside of Planning Room 207	0.2*			
52700-307-S	Sink in Planning Room	0.8*			
52700-326-DFL	Drinking Fountain outside of Student Dining/L	0.2*			
52700-326-DFR	Drinking Fountain outside of Student Dining/R	0.2*			
52700-326-WBFS	Water Bottle Filling Station outside of Student Dining	0.2*			
52700-329S-S	Sink in Kitchen	0.8*			
52700-3AXH-DFL	Hallway Drinking Fountain outside of Classroom 302/L	0.6*			
52700-3AXH-DFR	Hallway Drinking Fountain outside of Classroom 302/R	0.4*			
* This fixture was sampled for the first time on 4/25/19.					
** Resampling results were from samples collected on 4/25/19 as part of an ongoing rotation of lead testing.					
† This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					