

Mandalay Middle School - Sampled 6/17/20				Resampled 10/9/20†	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
67400-1050H-DF	Hallway Drinking Fountain near the Main Entrance	2.3	ppb		
67400-101-S	Sink in Instrument/Band Room 101	2.3	ppb		
67400-1044H-DF	Hallway Drinking Fountain near the Cafeteria	0.9	ppb		
67400-1099H-DF	Hallway Drinking Fountain on the First Floor near the Elevator	0.7	ppb		
67400-1091-DF	Drinking Fountain in the Girls Locker Room	5.5	ppb		
67400-1082-DF	Drinking Fountain in the Boys Locker Room	4.0	ppb		
67400-1090-S	Sink in Training Room 1090	10.4	ppb		
67400-112-S1	Sink in Art Room 112/Left	2.9*	ppb		
67400-112-S2	Sink in Art Room 112/Right	4.6*	ppb		
67400-110-S1	Sink in Art Room 110/Left	25.7**	ppb		
67400-110-S2	Sink in Art Room 110/Right	7.7**	ppb		
67400-1059-S	Sink in Custodial Office	2.4	ppb		
67400-106-S	Sink in Teachers' Lounge	33.7	ppb	10.9	ppb
67400-1031-S1	Food Service Sink - Wash/Rinse	7.0*	ppb		
67400-1031-S2	Food Service Sink - Rinse/Sanitize	1.4*	ppb		
67400-1031-S3	Food Service Sink - Food Prep	12.1	ppb		
67400-1032-S	Food Service Sink - Hand Sink	5.3*	ppb		
67400-104-S1	Sink in Consumer Science Classroom 104	6.7	ppb		
67400-104-S2	Sink in Consumer Science Classroom 104	4.6	ppb		
67400-104-S3	Sink in Consumer Science Classroom 104	4.9	ppb		
67400-104-S4	Sink in Consumer Science Classroom 104	4.0	ppb		
67400-104-S5	Sink in Consumer Science Classroom 104	3.6	ppb		
67400-104-S6	Sink in Consumer Science Classroom 104	3.1	ppb		
67400-104-S7	Sink in Consumer Science Classroom 104	5.4	ppb		
67400-102-S	Sink in Consumer Science Classroom 102	9.2	ppb		
67400-102-SWB	Sink with Bubbler in Consumer Science Classroom 102	3.0	ppb		
67400-1017-S	Sink in Clinic	4.2	ppb		
67400-1010-S	Sink in Planning Room 1010 near Principal's Office	5.1	ppb		
67400-249-S	Sink in Planning Room 249 near Library	1.5	ppb		
67400-201-S1	Sink in Science Classroom 201	2.8*	ppb		
67400-201-S2	Sink in Science Classroom 201	10.3*	ppb		
67400-201-S3	Sink in Science Classroom 201	7.3*	ppb		
67400-201-S4	Sink in Science Classroom 201	2.3*	ppb		
67400-207-S1	Sink in Science Classroom 207	11.7*	ppb		
67400-207-S2	Sink in Science Classroom 207	4.2**	ppb		
67400-207-S3	Sink in Science Classroom 207	2.5**	ppb		
67400-207-S4	Sink in Science Classroom 207	13.3*	ppb		
67400-2042-S	Sink in Science Prep Room 2042	10.3*	ppb		
67400-209-S1	Sink in Science Classroom 209	12.8*	ppb		
67400-209-S2	Sink in Science Classroom 209	1.7**	ppb		
67400-209-S3	Sink in Science Classroom 209	13.8*	ppb		
67400-209-S4	Sink in Science Classroom 209	8.1*	ppb		
67400-211-S1	Sink in Science Classroom 211	10.4*	ppb		
67400-211-S2	Sink in Science Classroom 211	11.6*	ppb		
67400-211-S3	Sink in Science Classroom 211	6.8*	ppb		
67400-211-S4	Sink in Science Classroom 211	10.2*	ppb		
67400-213-S1	Sink in Science Classroom 213	5.8*	ppb		
67400-213-S2	Sink in Science Classroom 213	5.6*	ppb		
67400-213-S3	Sink in Science Classroom 213	5.5**	ppb		
67400-213-S4	Sink in Science Classroom 213	12.1*	ppb		
67400-209H-DF	Hallway Drinking Fountain near Science Classroom 209	1.8	ppb		
67400-2035H-DF	Hallway Drinking Fountain near Restrooms across from Library	2.3	ppb		
67400-224H-WBFS	Hallway Water Bottle Filling Station Second Floor near Elevator	0.8***	ppb		
67400-224H-DF	Hallway Drinking Fountain on the Second Floor near the Elevator	0.5	ppb		
67400-104-ICE1	Ice Maker in Consumer Science Room 104	12.0	ppb		
67400-104-ICE2	Ice Maker in Consumer Science Room 104	5.5	ppb		
* This fixture was sampled on 9/2/16.					
** Resampling results from 11/22/16 or 2/15/17 after elevated fixtures were removed and replaced.					
*** New fixture, sampled for first time on 6/17/20.					
† Sample result after fixture was replaced.					
† Sampled as part of Jeffco's ongoing 5 year sampling program.					