

Mt Evans OELS		Sampled 5/27/2022	Status
CustomerSampleNumber	Description	Lead results (ppb)	
59100-Dining Hall-S	Sink in Dining Hall	1	
59100-Dining Hall-Kitchen-S4	Dining Hall Kitchen Sink-Food Prep	0.8	
59100-Conf Center-Spigot	Spigot in front of Conference Center	11.4	Repairs pending
59100-Mt.Epaulet-DF	Drinking Fountain in Mt Epaulet	1.3	
59100-MtWarren-DF	Drinking Fountain in Mt Warren	1.8	
59100-Bear Ham-DF	Drinking Fountain in Bear Ham Rec Center	1.6	
59100-Mt Spalding-DF	Drinking Fountain in Mt Spalding	9.7	Repairs pending
59100-Clinic-S	Sink in Clinic	3.6	
59100-Clinic-Bath-S	Sink in Clinic Restroom	0.4	
59100-Mt Susan-DF	Drinking Fountain in Mt Susan	3.5	
59100-Mt Rosalie-DF	Drinking Fountain in Mt Rosalie	0.8	
59100-Astronomy-DF	Drinking Fountain in Astronomy Building	0.9	