

Moore Middle School - Sampled 6/24/20 [†]			
CustomerSampleNumber	Description	Lead Result	Units
67600-118-S	Sink in Clinic	5.1	ppb
67600-130-S	Sink in Planning Room 130	2.0	ppb
67600-143-S1	Sink in Food Lab 143	3.0	ppb
67600-143-S2	Sink in Food Lab 143	3.8	ppb
67600-143-S3	Sink in Food Lab 143	4.0	ppb
67600-143-S4	Sink in Food Lab 143	4.7	ppb
67600-143-S5	Sink in Food Lab 143	5.7	ppb
67600-143-S6	Sink in Food Lab 143	4.1	ppb
67600-143-S7	Sink in Food Lab 143	4.3	ppb
67600-107-S	Sink in Clothing Lab 107	3.3	ppb
67600-107-SWB	Sink with Bubbler in Clothing Lab 107	8.2	ppb
67600-142-S	Sink in Teacher's Lounge	1.2	ppb
67600-144-S1	Food Service Sink-Hand Sink	3.6*	ppb
67600-144-S2	Food Service Sink-Food Prep	4.3	ppb
67600-144-S3	Food Service Sink-Sprayer	3.3**	ppb
67600-144-S4	Food Service Sink-Wash	5.8*	ppb
67600-144-S5	Food Service Sink	3.6*	ppb
67600-144-S6	Food Service Sink	1.8*	ppb
67600-111-S1	Sink in Drama Room 111	5.7	ppb
67600-111-S2	Sink in Drama Room 111	Fixture Removed	
67600-111-SWB	Sink with Bubbler in Drama Room 111	8.6	ppb
67600-113-S	Sink in Small Shop Room 113	3.4	ppb
67600-117-S1	Sink in Art Room 117	9.9*	ppb
67600-117-S2	Sink in Art Room 117	6.4*	ppb
67600-201X-S	Sink in Technology Lab 201X	5.2	ppb
67600-167-DF	Drinking Fountain in Boy's Locker Room	2.1	ppb
67600-180-S	Sink in PE Storage Room	4.3**	ppb
67600-181-DF	Drinking Fountain in Girl's Locker Room	3.0	ppb
67600-186H-DF	Hallway Drinking Fountain across from Drama Room 111	0.4	ppb
67600-186H-WBFS	Water Bottle Filling Station across from Drama Room 111	0.4	ppb
67600-104-S	Sink in Music Room 104	1.5	ppb
67600-200X-S	Sink in Band Room 200X	5.8	ppb
67600-200X-SWB	Sink with Bubbler in Band Room 200X	4.0	ppb
67600-107XH-DF	Hallway Drinking Fountain across from Attendance Office	0.7	ppb
67600-290H-DF	Hallway Drinking Fountain across from Classroom 217	2.1	ppb
67600-290H-WBFS	Water Bottle Filling Station across from Classroom 217	3.5	ppb
67600-212-S1	Sink in Science Room 212	1.8*	ppb
67600-212-S2	Sink in Science Room 212	7.2*	ppb
67600-212-S3	Sink in Science Room 212	2.2*	ppb
67600-212-S4	Sink in Science Room 212	2.0*	ppb
67600-214-S1	Sink in Science Room 214	3.4*	ppb
67600-214-S2	Sink in Science Room 214	8.3*	ppb
67600-214-S3	Sink in Science Room 214	4.0*	ppb
67600-214-S4	Sink in Science Room 214	7.6*	ppb
67600-210X-S	Sink in Planning Room 210X	4.5	ppb
67600-210H-DF	Hallway Drinking Fountain outside of Science Room210	1.4	ppb

67600-210-S1	Sink in Science Room 210	4.0*	ppb
67600-210-S2	Sink in Science Room 210	2.8*	ppb
67600-210-S3	Sink in Science Room 210	7.4*	ppb
67600-210-S4	Sink in Science Room 210	4.5*	ppb
67600-208-S1	Sink in Science Room 208	4.1*	ppb
67600-208-S2	Sink in Science Room 208	2.1*	ppb
67600-208-S3	Sink in Science Room 208	4.5*	ppb
67600-208-S4	Sink in Science Room 208	3.9*	ppb
67600-206-S	Sink in Classroom 206	2.1	ppb
67600-230-S	Sink in Processing Room 230	2.6	ppb
67600-WC	Water cooler in Planning Room 130	<0.1***	ppb
*Sampled on 8/5/16			
** Resampling results 11/22/16 after elevated fixture was removed and replaced.			
*** This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			
† Sampled as part of Jeffco's ongoing 5 year sampling program.			