

| Meiklejohn Elementary School - Sampled 7/2/20 <sup>†</sup> |   |             |      |
|--|---|-------------|------|
| CustomerSampleNumber                                       | Description   | Lead Result | Unit |
| 26500-1301-S   | Sink in Kindergarten Classroom 1301                                     | 1.4         | ppb  |
| 26500-1301-SWB   | Sink with Bubbler in Kindergarten Classroom 1301                        | 0.5         | ppb  |
| 26500-1305-S   | Sink in Kindergarten Classroom 1305                                     | 1.2         | ppb  |
| 26500-1305-SWB   | Sink with Bubbler in Kindergarten Classroom 1305                        | 0.6         | ppb  |
| 26500-1307-S   | Sink in Kindergarten Classroom 1307                                     | 1.6         | ppb  |
| 26500-1307-SWB   | Sink with Bubbler in Kindergarten Classroom 1307                        | 0.5         | ppb  |
| 26500-1310-S   | Sink in Kindergarten Classroom 1310                                     | 1.0         | ppb  |
| 26500-1310-SWB   | Sink with Bubbler in Kindergarten Classroom 1310                        | 0.7         | ppb  |
| 26500-1401-S   | Sink in Classroom 1401  | 0.4         | ppb  |
| 26500-1401-SWB   | Sink with Bubbler in Classroom 1401                                     | 1.0         | ppb  |
| 26500-1403-S   | Sink in Classroom 1403  | 0.7         | ppb  |
| 26500-1403-SWB   | Sink with Bubbler in Classroom 1403                                     | 0.4         | ppb  |
| 26500-1402-S   | Sink in Classroom 1402  | 1.5         | ppb  |
| 26500-1402-SWB   | Sink with Bubbler in Classroom 1402                                     | 0.5         | ppb  |
| 26500-1501-S   | Sink in Classroom 1501  | 1.3         | ppb  |
| 26500-1502-S   | Sink in Classroom 1502  | 2.3         | ppb  |
| 26500-1503-S   | Sink in Pre-K Classroom 1503  | 1.3         | ppb  |
| 26500-1504-S   | Sink in Pre-K Classroom 1504  | 0.7         | ppb  |
| 26500-1505-S   | Sink in Pre-K Classroom 1505  | 1.7         | ppb  |
| 26500-1506-S   | Sink in Office 1506   | 0.7         | ppb  |
| 26500-499H-DFL   | Hallway Drinking Fountain outside of Classroom 1502/Left                | 0.3         | ppb  |
| 26500-499H-DFR   | Hallway Drinking Fountain outside of Classroom 1502/Right               | 1.3         | ppb  |
| 26500-1513-S   | Sink in Classroom 1513  | 1.0         | ppb  |
| 26500-1513-SWB   | Sink with Bubbler in Classroom 1513                                     | 0.3         | ppb  |
| 26500-1514-S   | Sink in Classroom 1514  | 0.8         | ppb  |
| 26500-1406-S   | Sink in Classroom 1406  | 1.7         | ppb  |
| 26500-1012H-DFL  | Hallway Drinking Fountain outside of Classroom 1401/Left                | 0.7         | ppb  |
| 26500-1012H-DFR  | Hallway Drinking Fountain outside of Classroom 1401/Right               | 0.5         | ppb  |
| 26500-1414-S   | Sink in Classroom 1414  | 1.0         | ppb  |
| 26500-1415-S   | Sink in Classroom 1415  | 3.3         | ppb  |
| 26500-1315-S   | Sink in Library Work Room   | 1.3*        | ppb  |
| 26500-1007H-DFL  | Hallway Drinking Fountain across from Kindergarten Classroom 1301/Left  | 1.1         | ppb  |
| 26500-1007H-DFR  | Hallway Drinking Fountain across from Kindergarten Classroom 1301/Right | 0.8         | ppb  |
| 26500-1201-S1  | Sink in Instrument/Band Room  | 2.7*        | ppb  |
| 26500-1201-S2  | Sink in Instrument/Band Room  | 4.1*        | ppb  |
| 26500-1204-S1  | Sink in Art Room 1204   | 0.2*        | ppb  |
| 26500-1204-S2  | Sink in Art Room 1204   | 0.8*        | ppb  |
| 26500-1204-S3  | Sink in Art Room 1204   | <0.1 * **   | ppb  |
| 26500-1208-S1  | Food Service Sink-Hand Sink   | 1.5         | ppb  |
| 26500-1208-S2  | Food Service Sink-Food Prep   | 1.3         | ppb  |
| 26500-1208-S4  | Food Service Sink-Wash/Rinse  | 0.6*        | ppb  |
| 26500-1208-S5  | Food Service Sink-Rinse/Sanitize  | 0.6*        | ppb  |
| 26500-1208-S6  | Food Service Sink-Sprayer   | 1.8*        | ppb  |
| 26500-1208-S7  | Food Service Sink-Hand Sink   | 1.6*        | ppb  |
| 26500-1207-DFL   | Drinking Fountain in Cafeteria/Left                                     | 1.3         | ppb  |
| 26500-1207-DFR   | Drinking Fountain in Cafeteria/Right                                    | 1.7         | ppb  |
| 26500-1006H-DFL  | Hallway Drinking Fountain between Art Room and Cafeteria/Left           | 0.5         | ppb  |
| 26500-1006H-DFR  | Hallway Drinking Fountain between Art Room and Cafeteria/Right          | 1.2         | ppb  |
| 26500-1214-S   | Sink in Stage Room  | 0.9         | ppb  |
| 26500-1214-SWB   | Sink with Bubbler in Stage Room   | 0.8         | ppb  |
| 26500-1004H-DFL  | Hallway Drinking Fountain outside of Gym/Left                           | 0.3         | ppb  |
| 26500-1004H-DFR  | Hallway Drinking Fountain outside of Gym/Right                          | 0.8         | ppb  |
| 26500-1108-S   | Sink in Teacher's Lounge 1108   | 0.3         | ppb  |

|   |  |      |     |
|---|--|------|-----|
| 26500-1110-S  | Sink in Work Room 1110   | 2.9* | ppb |
| 26500-1104-S  | Sink in Clinic   | 0.7  | ppb |
| 26500-2401-S  | Sink in Classroom 2401   | 1.4  | ppb |
| 26500-2402-S  | Sink in Classroom 2402   | 0.6  | ppb |
| 26500-2403-S  | Sink in Classroom 2403   | 0.8  | ppb |
| 26500-2501-S  | Sink in Classroom 2501   | 1.0  | ppb |
| 26500-2502-S  | Sink in Classroom 2502   | 3.2  | ppb |
| 26500-2503-S  | Sink in Classroom 2503   | 0.5  | ppb |
| 26500-2504-S  | Sink in Classroom 2504   | 2.9  | ppb |
| 26500-2505-S  | Sink in Classroom 2505   | 4.5  | ppb |
| 26500-2506-S  | Sink in Classroom 2506   | 0.8  | ppb |
| 26500-2016H-DFL   | Hallway Drinking Fountain across from Classrooms 2502 and 2503/Left  | 0.4  | ppb |
| 26500-2016H-DFR   | Hallway Drinking Fountain across from Classrooms 2502 and 2503/Right | 1.0  | ppb |
| 26500-2513-S  | Sink in Classroom 2513   | 0.8  | ppb |
| 26500-2514-S  | Sink in Classroom 2514   | 1.4  | ppb |
| 26500-2405-S  | Sink in Classroom 2405   | 1.5  | ppb |
| 26500-2012H-DFL   | Hallway Drinking Fountain across from Classrooms 2403 and 2402/Left  | 0.4  | ppb |
| 26500-2012H-DFR   | Hallway Drinking Fountain across from Classrooms 2403 and 2402/Right | 1.0  | ppb |
| 26500-2412-S  | Sink in Classroom 2412   | 1.0  | ppb |
| 26500-2413-S  | Sink in Classroom 2413   | 0.7  | ppb |
| *Sampled on 11/2/16.  |  |      |     |
| ** This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab. |  |      |     |
| † Sampled as part of Jeffco's ongoing 5 year sampling program.                                  |  |      |     |