

Mount Carbon Elementary School		Sampled 4/19/2022	Status
CustomerSampleNumber	Description	Lead Results (ppb)	
29400-106-S	Sink in Clinic	2.2	
29400-217A-S	Sink in Music Room	11.1	Repairs Pending
29400-217A-SWB	Sink with Bubblers in Music Room	not in use	
29400-202-S8	Food Service Sink-Food Prep	1.3	
29400-202-S9	Food Service Sink-Food Prep Sprayer	2	
29400-200-S	Sink in Teacher's Lounge	<0.1*	
29400-199H-DFL	Hallway Drinking Fountain across from Office 212/Left	not in use	
29400-199H-DFR	Hallway Drinking Fountain across from Office 212/Right	<0.1*	
29400-2022-199H-WBFS	Water Bottle Filling Station across from Office 212	<0.1*	
29400-B-1-SWB	Sink with Bubblers in Classroom B-1	<0.1*	
29400-B-2-SWB	Sink with Bubblers in Classroom B-2	<0.1*	
29400-B-3-SWB	Sink with Bubblers in Classroom B-3	0.2	
29400-B-4-SWB	Sink with Bubblers in Classroom B-4	0.1	
29400-B-5-SWB	Sink with Bubblers in Classroom B-5	<0.1*	
29400-B-6-SWB	Sink with Bubblers in Classroom B-6	not in use	
29400-G-1-SWB	Sink with Bubblers in Classroom G-1	<0.1*	
29400-G-2-SWB	Sink with Bubblers in Classroom G-2	<0.1*	
29400-G-3-SWB	Sink with Bubblers in Classroom G-3	<0.1*	
29400-G-4-SWB	Sink with Bubblers in Classroom G-4	<0.1*	
29400-G-5-SWB	Sink with Bubblers in Classroom G-5	<0.1*	
29400-G-6-SWB	Sink with Bubblers in Classroom G-6	<0.1*	
29400-T-1-SWB	Sink with Bubblers in Classroom T-1	0.1	
29400-T-2-SWB	Sink with Bubblers in Classroom T-2	0.1	
29400-T-3-SWB	Sink with Bubblers in Classroom T-3	0.2	
29400-T-4-SWB	Sink with Bubblers in Classroom T-4	0.2	
29400-T-5-SWB	Sink with Bubblers in Classroom T-5	not in use	
29400-T-6-SWB	Sink with Bubblers in Classroom T-6	not in use	
29400-M-1-SWB	Sink with Bubblers in Classroom M-1	<0.1*	
29400-M-2-SWB	Sink with Bubblers in Classroom M-2	0.1	
29400-M-3-SWB	Sink with Bubblers in Classroom M-3	0.1	
29400-M-4-SWB	Sink with Bubblers in Kindergarten Classroom M-4	<0.1*	
29400-M-5-SWB	Sink with Bubblers in Kindergarten Classroom M-5	<0.1*	

29400-M-6-SWB	Sink with Bubbler in Kindergarten Classroom M-6	<0.1*	
29400-103-S	Sink in Conference Room 103	2.5	
29400-154-SWB	Sink with Bubbler in Library Work Room	0.2	
29400-2022-167H-WBFS	Hallway Water Bottle Filling Station outside restrooms	<0.1*	
29400-2022-167H-DF	Hallway Drinking Fountain outside restrooms	<0.1*	
29400-2022-123H-DF	Hallway Drinking Fountain outside restrooms	<0.1*	
29400-2022-123H-WBFS	Hallway Water Bottle Filling Station outside restrooms	<0.1*	
* This results is less than 0.1ppb, which is the lowest level that can be reported by the lab.			