

Oberon Middle School - Sampled 6/30/20 [†]			
CustomerSampleNumber	Description	Lead Result	Units
67700-207-S	Sink in Library Work Room	12.5*	ppb
67700-S-1H-DFL	Hallway Drinking Fountain across from Laboratory S-1/Left	3.6*	ppb
67700-S-1H-DFR	Hallway Drinking Fountain across from Laboratory S-1/Right	3.4	ppb
67700-S-1-S1	Sink in Laboratory S-1	9.6*	ppb
67700-S-1-S2	Sink in Laboratory S-1	7.3*	ppb
67700-138-S	Sink in Storage Room 138	1.0**	ppb
67700-S-2-S1	Sink in Laboratory S-2	9.9*	ppb
67700-S-2-S2	Sink in Laboratory S-2	6.7*	ppb
67700-S-3-S1	Sink in Laboratory S-3	8.3*	ppb
67700-S-3-S2	Sink in Laboratory S-3	11.6*	ppb
67700-110H-DFL	Hallway Drinking Fountain across from Laboratory S-3/Left	0.6	ppb
67700-110H-DFR	Hallway Drinking Fountain across from Laboratory S-3/Right	1.3	ppb
67700-S-4-S1	Sink in Laboratory S-4	13.4*	ppb
67700-S-4-S2	Sink in Laboratory S-4	8.8*	ppb
67700-A-3-S1	Sink in Art Room A-3	5.0**	ppb
67700-A-3-S2	Sink in Art Room A-3	3.7**	ppb
67700-A-3-S3	Sink in Art Room A-3	4.0**	ppb
67700-A-3-S4	Sink in Art Room A-3	5.0**	ppb
67700-A-3-S5	Sink in Art Room A-3	3.7**	ppb
67700-A-3-S6	Sink in Art Room A-3	3.2**	ppb
67700-A-3-S7	Sink in Art Room A-3	11.5**	ppb
67700-A-3-S8	Sink in Art Room A-3	2.9**	ppb
67700-A-2-S1	Sink in Art Room A-2	5.8**	ppb
67700-A-2-S2	Sink in Art Room A-2	7.4**	ppb
67700-A-2-S3	Sink in Art Room A-2	3.2**	ppb
67700-A-2-S4	Sink in Art Room A-2	14.2*	ppb
67700-A-2-S5	Sink in Art Room A-2	5.3**	ppb
67700-A-2-S6	Sink in Art Room A-2	3.7**	ppb
67700-A-2-S7	Sink in Art Room A-2	6.1**	ppb
67700-A-2-S8	Sink in Art Room A-2	4.8**	ppb
67700-S-5-S1	Sink in Laboratory S-5	0.5**	ppb
67700-S-5-S2	Sink in Laboratory S-5	1.8**	ppb
67700-201H-DFL	Hallway Drinking Fountain across from Laboratory S-6/Left	2.8	ppb
67700-201H-DFR	Hallway Drinking Fountain across from Laboratory S-6/Right	0.9	ppb
67700-S-6-S1	Sink in Laboratory S-6	9.7*	ppb
67700-S-6-S2	Sink in Laboratory S-6	1.4**	ppb
67700-C-4-S	Sink in Consumer Science Classroom C-4	1.8	ppb
67700-C-5-S	Sink in Computer Room C-5	6.6	ppb
67700-C-6-S1	Sink in Classroom C-6	5.4	ppb
67700-C-6-S2	Sink in Classroom C-6	0.7	ppb
67700-301H-DFL	Hallway Drinking Fountain outside of Band Room/Left	4.4	ppb
67700-301H-DFR	Hallway Drinking Fountain outside of Band Room/Right	4.9	ppb
67700-BAND-S	Sink in Band Room	0.6	ppb
67700-BAND-SWB	Sink with Bubbler in Band Room	0.8	ppb
67700-TA1-S1	Sink in Exploration Room TA1	0.8	ppb
67700-TA1-S2	Sink in Exploration Room TA1	1.9	ppb
67700-TA1-SWB	Sink with Bubbler in Exploration Room TA1	0.5	ppb
67700-131-S1	Food Service Sink-Sprayer	6.8*	ppb
67700-131-S2	Food Service Sink-Wash	6.6*	ppb
67700-131-S3	Food Service Sink-Wash	13.5*	ppb
67700-131-S4	Food Service Sink-Hand Sink	5.2*	ppb

67700-131-S5	Food Service Sink-Food Prep	3.2	ppb
67700-107-DFL	Drinking Fountain in Cafeteria/Left	0.5	ppb
67700-107-DFR	Drinking Fountain in Cafeteria/Right	0.7	ppb
67700-115-S	Sink in Teacher's Lounge	0.6	ppb
67700-C-1-S2	Sink in Computer Room C-1	0.7	ppb
67700-105-S	Sink in Clinic	1.3	ppb
67700-106-S	Sink in Principal's Office	0.9	ppb
67700-112-DFL	Drinking Fountain in Cafeteria/Left	1.0	ppb
67700-112-DFR	Drinking Fountain in Cafeteria/Right	1.2	ppb
*Sampled on 8/4/16			
** Results from 12/2/16 after elevated fixture was removed and replaced.			
† Sampled as part of Jeffco's ongoing 5 year sampling program.			