

Patterson Cottages - Sampled 6/21/16				Resampled** 5-9-19	
SampleNumber	Description	Lead Result	Units	Lead Result	Units
32400A-C2A-101X-SWB	Cottage 2A; Sink with Bubbler in Pre-K Classroom 101X	1.4	ppb	1.8	ppb
32400A-C2A-102X-SWB	Cottage 2A; Sink with Bubbler in Pre-K Classroom 102X	1.3	ppb	1.4	ppb
32400A-C4C-102X-SWB	Cottage 4C; Sink with Bubbler in Pre-K Classroom 102X	1.3	ppb	0.5	ppb
32400A-C4C-101X-SWB	Cottage 4C; Sink with Bubbler in Pre-K Classroom 101X	1.1	ppb	0.5	ppb
32400A-C4D-101X-SWB	Cottage 4D; Sink with Bubbler in Pre-K Classroom 101X	1.4	ppb	1.5	ppb
32400A-C4D-102X-SWB	Cottage 4D; Sink with Bubbler in Pre-K Classroom 102X	1.0	ppb	2.3	ppb
32400A-C3B-101X-S	Cottage 3B; Sink in Library	4.5	ppb	3.9	ppb
32400A-C3B-101X-SWB	Cottage 3B; Sink with Bubbler in Library	2.4	ppb	1.5	ppb
32400A-C3B-102X-SWB	Cottage 3B; Sink with Bubbler in Office	3.6	ppb	<0.1 *	ppb
32400A-C2A-BASEMENT-S	Cottage 2A; Sink in Kitchen in Basement	4.5	ppb	2.5	ppb
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** Resampling results were from samples collected on 5/9/19 as part of an ongoing rotation of lead testing.					