

Pomona High School		Sampled 7/14/20 [†]		Resampled 7/31/20, 8/6/20, or 11/6/20 ***	
Sample Number	Description	Lead Result	Units	Lead Result	Units
78000-634-S	Sink in Workroom 634 in Main Office Area	8.6	ppb		
78000-622-S	Sink in Clinic	38.1	ppb	0.2	ppb
78000-550-S	Sink in Planning Room 550 (next to Classroom 547 in the English Area)	12.1	ppb		
78000-525-S	Sink in Library Workroom	1.0	ppb		
78000-603H-DFL	Hallway Drinking Fountain Outside of Small Auditorium/Left	0.6	ppb		
78000-603H-DFR	Hallway Drinking Fountain Outside of Small Auditorium/Right	0.5	ppb		
78000-509-S	Sink in Counseling Room 509	8.3	ppb		
78000-505-S	Sink in Classroom 505	9.6	ppb		
78000-232-S	Sink in Office 232 (across from Classroom 215 in the Math Area)	5.8	ppb		
78000-228-S	Sink in Office 228 (next to Classroom 226 in the Business Ed. Area)	22.5	ppb	0.6	ppb
78000-402-S	Sink in Science Prep Area - Room 402	4.6*	ppb		
78000-403-S1	Sink in Science Lab/Classroom 403	2.0*	ppb		
78000-403-S2	Sink in Science Lab/Classroom 403	2.7*	ppb		
78000-403-S3	Sink in Science Lab/Classroom 403	2.6*	ppb		
78000-403-S4	Sink in Science Lab/Classroom 403	3.1*	ppb		
78000-403-S5	Sink in Science Lab/Classroom 403	4.0*	ppb		
78000-403-S6	Sink in Science Lab/Classroom 403	2.3*	ppb		
78000-425-S1	Sink in Science Lab/Classroom 425	1.4**	ppb		
78000-425-S2	Sink in Science Lab/Classroom 425	2.0**	ppb		
78000-425-S3	Sink in Science Lab/Classroom 425	3.5**	ppb		
78000-425-S4	Sink in Science Lab/Classroom 425	1.2**	ppb		
78000-425-S5	Sink in Science Lab/Classroom 425	0.2**	ppb		
78000-422-S1	Sink in Science Lab/Classroom 422	4.9*	ppb		
78000-422-S2	Sink in Science Lab/Classroom 422	7.4*	ppb		
78000-422-S3	Sink in Science Lab/Classroom 422	9.4*	ppb		
78000-422-S4	Sink in Science Lab/Classroom 422	7.6*	ppb		
78000-422-S5	Sink in Science Lab/Classroom 422	4.4*	ppb		
78000-422-S6	Sink in Science Lab/Classroom 422	5.5*	ppb		
78000-422-S7	Sink in Science Lab/Classroom 422	13.1*	ppb		
78000-421-S1	Sink in Science Lab/Classroom 421	10.1*	ppb		
78000-421-S2	Sink in Science Lab/Classroom 421	2.5*	ppb		
78000-421-S3	Sink in Science Lab/Classroom 421	5.2*	ppb		
78000-421-S4	Sink in Science Lab/Classroom 421	2.8*	ppb		
78000-421-S5	Sink in Science Lab/Classroom 421	2.9*	ppb		
78000-421-S6	Sink in Science Lab/Classroom 421	3.1*	ppb		
78000-421-S7	Sink in Science Lab/Classroom 421	3.1*	ppb		
78000-421-S8	Sink in Science Lab/Classroom 421	10.6*	ppb		
78000-406-S	Sink in Science Prep Area - Room 406	1.6*	ppb		
78000-405-S1	Sink in Science Lab/Classroom 405	2.8*	ppb		
78000-405-S2	Sink in Science Lab/Classroom 405	2.4*	ppb		
78000-405-S3	Sink in Science Lab/Classroom 405	1.9*	ppb		
78000-405-S4	Sink in Science Lab/Classroom 405	1.6*	ppb		
78000-405-S5	Sink in Science Lab/Classroom 405	3.8*	ppb		
78000-405-S6	Sink in Science Lab/Classroom 405	3.7*	ppb		
78000-407-S1	Sink in Science Lab/Classroom 407	3.2*	ppb		
78000-407-S2	Sink in Science Lab/Classroom 407	4.6*	ppb		
78000-407-S3	Sink in Science Lab/Classroom 407	5.4*	ppb		
78000-407-S4	Sink in Science Lab/Classroom 407	6.5*	ppb		
78000-407-S5	Sink in Science Lab/Classroom 407	4.7*	ppb		
78000-407-S6	Sink in Science Lab/Classroom 407	3.1*	ppb		
78000-408-S1	Sink in Science Lab/Classroom 408	5.2*	ppb		
78000-408-S2	Sink in Science Lab/Classroom 408	2.3*	ppb		
78000-408-S3	Sink in Science Lab/Classroom 408	2.5*	ppb		
78000-408-S4	Sink in Science Lab/Classroom 408	5.1*	ppb		
78000-408-S5	Sink in Science Lab/Classroom 408	1.9*	ppb		
78000-408-S6	Sink in Science Lab/Classroom 408	2.4*	ppb		
78000-408-S7	Sink in Science Lab/Classroom 408	2.9*	ppb		
78000-411-S	Sink in Science Prep Area - Room 411	2.6**	ppb		
78000-413-S1	Sink in Science Lab/Classroom 413	4.0*	ppb		
78000-413-S2	Sink in Science Lab/Classroom 413	5.7*	ppb		
78000-413-S3	Sink in Science Lab/Classroom 413	6.6*	ppb		
78000-413-S4	Sink in Science Lab/Classroom 413	13.7*	ppb		
78000-413-S5	Sink in Science Lab/Classroom 413	6.7*	ppb		
78000-413-S6	Sink in Science Lab/Classroom 413	6.2*	ppb		
78000-413-S7	Sink in Science Lab/Classroom 413 (first sink on right from entrance to room)	1.4**	ppb		
78000-414-S1	Sink in Science Lab/Classroom 414	4.2*	ppb		
78000-414-S2	Sink in Science Lab/Classroom 414	2.3*	ppb		
78000-414-S3	Sink in Science Lab/Classroom 414	3.2*	ppb		

78000-414-S4	Sink in Science Lab/Classroom 414	3.8*	ppb	
78000-414-S5	Sink in Science Lab/Classroom 414	5.5*	ppb	
78000-414-S6	Sink in Science Lab/Classroom 414	3.6*	ppb	
78000-414-S7	Sink in Science Lab/Classroom 414	11.1*	ppb	
78000-416-S	Sink in Science Prep Area - Room 416	10.1*	ppb	
78000-417-S1	Sink in Science Lab/Classroom 417	5.2*	ppb	
78000-417-S2	Sink in Science Lab/Classroom 417	4.9*	ppb	
78000-418-S1	Sink in Science Lab/Classroom 418	8.6*	ppb	
78000-418-S2	Sink in Science Lab/Classroom 418	1.6*	ppb	
78000-709-S1	Sink in the Store (Room 709 by Student Dining Area) - Sink on the left of the two on the same wall	1.0	ppb	
78000-709-S2	Sink in the Store (Room 709 by Student Dining Area) - Sink on the right of the two on the same wall	1.0	ppb	
78000-709-S3	Sink in the Store (Room 709 by Student Dining Area) - Sink by itself nearest to the entrance door	54.0	ppb	11.0 ppb
7800-709-IM	Ice Machine in the Store (Room 809 by Student Dining area)	2.0	ppb	
78000-705-DF	Drinking Fountain in Room 705 - Custodial Area	1.1	ppb	
78000-706-S	Sink in Room 706 - Custodial Area	3.2	ppb	
78000-1123-DF	Drinking Fountain in Locker Room 1123 -	1.6	ppb	
78000-1116-S	Sink in Training Room 1116	1.9	ppb	
78000-1116-IM	Ice Machine in Training Room 1116	1.5	ppb	
78000-1115-WBFS	Water Bottle Filling Station in Hallway outside of Gym (across from Training Room)	0.3	ppb	
78000-1115-DF	Drinking Fountain in Hallway outside of Gym (across from Training Room)	0.4	ppb	
78000-1101-DF	Drinking Fountain in Locker Room 1101	15.8	ppb	15.7 † ppb
78000-714-S1	Food Service Sink - Hand Sink	1.1*	ppb	
78000-714-S2	Food Service Sink - Hand Sink	3.6*	ppb	
78000-714-S3	Food Service Sink - Sprayer	3.4	ppb	
78000-714-S4	Food Service Sink - Wash/Sanitize	1.0	ppb	
78000-714-S5	Food Service Sink - Sanitize/Rinse	1.6	ppb	
78000-714-S6	Food Service Sink - Hand Sink	0.6*	ppb	
78000-714-S7	Food Service Sink	0.8	ppb	
78000-714-S8	Food Service Sink - Sprayer	2.7	ppb	
78000-714-S9	Food Service Sink - Hand Sink	1.5*	ppb	
78000-720-DFL	Drinking Fountain near Restrooms in Cafeteria/Left	0.4	ppb	
78000-720-DFR	Drinking Fountain near Restrooms in Cafeteria/Right	0.3	ppb	
78000-1001-S	Sink in Consumer Science Classroom 1001	8.8	ppb	
78000-1011-S1	Sink in Consumer Science Kitchen Classroom 1011	11.7	ppb	
78000-1011-S2	Sink in Consumer Science Kitchen Classroom 1011	5.9	ppb	
78000-1011-S3	Sink in Consumer Science Kitchen Classroom 1011	6.6	ppb	
78000-1011-S4	Sink in Consumer Science Kitchen Classroom 1011	12.0	ppb	
78000-1011-S5	Sink in Consumer Science Kitchen Classroom 1011	12.6	ppb	
78000-1011-S6	Sink in Consumer Science Kitchen Classroom 1011	12.6	ppb	
78000-1011-S7	Sink in Consumer Science Kitchen Classroom 1011	9.5	ppb	
78000-1031H-DF	Drinking Fountain near Cafeteria in Hallway leading to Art Room 1046	0.7	ppb	
78000-1015-S	Sink in CCTV Lab 1015	40.7	ppb	1.1 ppb
78000-1016-S1	Sink in Technology Lab 1016	0.8**	ppb	
78000-1024-DF	Drinking Fountain in Instrument/Band Room 1024	0.4*	ppb	
78000-1037-S	Sink in Technology Lab 1037	14.2	ppb	
78000-1037-SWB	Sink with Bubbler in Technology Lab 1037	3.1	ppb	
78000-1035-DF	Drinking Fountain in Tech Ed Lab 1035	1.1	ppb	
78000-1043-DF	Drinking Fountain in Tech Ed Lab 1043	1.0	ppb	
78000-1046-S1	Sink in Art Room 1046	8.9*	ppb	
78000-1046-S2	Sink in Art Room 1046	2.1*	ppb	
78000-1056-S1	Sink in Art Room 1056	1.1*	ppb	
78000-1056-S2	Sink in Art Room 1056	0.7*	ppb	
78000-1056-S3	Sink in Art Room 1056	9.3*	ppb	
78000-1052-S1	Sink in Art Room 1052	1.8*	ppb	
78000-1052-S2	Sink in Art Room 1052	1.7*	ppb	
78000-807-SWB	Sink with Bubbler just outside practice rooms by Vocal Classroom 807	0.3	ppb	
78000-807-S	Sink just outside practice rooms by Vocal Classroom 807	22.2	ppb	8.9 ppb
78000-815-S	Sink in Drama Storage Area - Room 815	1.0	ppb	
78000-SSWR-S	Sink in Social Studies Workroom - 2nd Floor	7.4	ppb	
78000-FLWR-S	Sink in World Language Workroom - 2nd Floor	11.9	ppb	
78000-310H-DFL	Drinking Fountain near Social Studies/World Language Areas on 2nd Floor/Left	0.1	ppb	
78000-310H-DFR	Drinking Fountain near Social Studies/World Language Areas on 2nd Floor/Right	0.1	ppb	

*Sampled on 9/13/16

** Results from 12/6/16 after elevated fixtures were removed and replaced.

*** Results from 7/31/20 or 11/6/20 after elevated fixtures were repaired or replaced.

‡ Fixture is shut off and has "Do not drink" sign.

† Sampled as part of Jeffco's ongoing 5 year sampling program.