

Red Rocks Elementary School - Sampled 7/19/16				Resampled* 11/15/16		Resampled** 5/15/19	
SampleNumber	Description	Lead Result	Units	Lead Result	Units	Lead Result	Units
36000-132-S	Sink in Cafeteria	0.7	ppb				
36000-132-SWB	Sink with Bubblers in Cafeteria	0.3	ppb			0.7	ppb
36000-125-S1	Food Service Sink-Hand Sink	47.6	ppb	27.6	ppb		
36000-125-S2	Food Service Sink-Rinse/Wash	3.7	ppb			4.7	ppb
36000-125-S3	Food Service Sink-Sprayer	0.9	ppb				
36000-118-S	Sink in Gym Office	4.9	ppb				
36000-139-S	Sink in Library Workroom	1.7	ppb				
36000-101-S	Sink in Classroom 101	1.8	ppb				
36000-101-SWB	Sink with Bubblers in Classroom 101	0.3	ppb			0.6	ppb
36000-104-S	Sink in Teacher's Lounge	0.5	ppb			0.3	ppb
36000-107-S	Sink in Main Office Area	19.7	ppb	15.0	ppb		
36000-140H-DF	Hallway Drinking Fountain near Art Room	0.2	ppb			0.4	ppb
36000-144-S	Sink in Classroom 144	4.2	ppb				
36000-144-SWB	Sink with Bubblers in Classroom 144	1.0	ppb			0.1	ppb
36000-146-S	Sink in Classroom 146	1.5	ppb				
36000-146-SWB	Sink with Bubblers in Classroom 146	0.4	ppb			0.2	ppb
36000-147-S	Sink in Classroom 147	3.0	ppb				
36000-147-SWB	Sink with Bubblers in Classroom 147	1.4	ppb			0.3	ppb
36000-004H-DF	Hallway Drinking Fountain near Classroom 007	0.3	ppb			0.4	ppb
36000-007-S	Sink in Classroom 007	3704.8	ppb	0.6	ppb		
36000-007-SWB	Sink with Bubblers in Classroom 007	185.3	ppb	1.1	ppb	0.2	ppb
36000-008-S	Sink in Classroom 008	8.4	ppb				
36000-008-SWB	Sink with Bubblers in Classroom 008	1.8	ppb			0.2	ppb
36000-010-S	Sink in Classroom 010	4.6	ppb				
36000-010-SWB	Sink with Bubblers in Classroom 010	0.1	ppb			0.1	ppb
36000-011-S	Sink in Classroom 011	2.6	ppb				
36000-011-SWB	Sink with Bubblers in Classroom 011	0.1	ppb			0.2	ppb
36000-REC-078-DF	Drinking Fountain in TEMP REC-078	10.4	ppb			0.4	ppb
36000-R1-089-DF	Drinking Fountain in TEMP R1-089	4.2	ppb			0.4	ppb
36000-R1-034-DF	Drinking Fountain in TEMP R1-034	3.2	ppb			0.5	ppb
36000-R1-024-DF	Drinking Fountain in TEMP R1-024	12.6	ppb			13.9	ppb
* Resampling results after elevated fixtures were removed and replaced.							
** Resampling results were from samples collected on 5/15/19 as part of an ongoing rotation of lead testing.							