

Ryan Elementary School - Sampled 6/16/20 <sup>†</sup>				Resampled 7/7/20	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
38500-107-S	Sink in Planning Room near Principal's Office	2.4	ppb		
38500-114-S	Sink in Library Workroom - Room 114	1.2	ppb		
38500-129H-DFL	Drinking Fountain in Hallway near Computer Lab/Left	0.3*	ppb		
38500-129H-DFR	Drinking Fountain in Hallway near Computer Lab/Right	0.3*	ppb		
38500-2020-129H-DF	Hallway Drinking Fountain outside Cafeteria	0.3	ppb		
38500-2020-129H-WBFS	Hallway Water Bottle Filling Station Outside Cafeteria	0.3	ppb		
38500-124-S1	Food Service Sink-Hand Sink	0.8*	ppb		
38500-124-S2	Food Service Sink-Food Prep	22.9	ppb	1.5**	ppb
38500-124-S3	Food Service Sink-Wash/Rinse/Sanitize	0.9*	ppb		
38500-124-S4	Food Service Sink-Wash/Rinse/Sanitize	1.2*	ppb		
38500-124-S5	Food Service Sink-Serving Line	5.9*	ppb		
38500-124-S6	Food Service Sink-Serving Line	1.3*	ppb		
38500-MUSIC-S	Sink in Music Room	1.0*	ppb		
38500-ART-S1	Art Room Sink	3.2*	ppb		
38500-ART-S2	Art Room Sink	4.6*	ppb		
38500-D19-S	Sink in Kindergarten Classroom D-19	2.4	ppb		
38500-196H-DF	Hallway Drinking Fountain across from Classroom D-21	0.3	ppb		
38500-D22-S	Sink in Kindergarten Classroom D-22	3.3	ppb		
38500-195H-DF	Hallway Drinking Fountain across from Classroom D-23	0.4	ppb		
38500-D24-S	Sink in Resource Room D-24	2.1*	ppb		
38500-C18-S	Sink in Classroom C-18	0.6	ppb		
38500-207H-DF	Hallway Drinking Fountain across from Classroom C-18	0.2	ppb		
38500-C16-S	Sink in Classroom C-16	2.8	ppb		
38500-206H-DF	Hallway Drinking Fountain across from Classroom C-15	0.3	ppb		
38500-C13-S	Sink in Classroom C-13	4.1	ppb		
38500-182-S	Sink in Teacher's Lounge	0.5	ppb		
38500-B12-S	Sink in Classroom B-12	3.7	ppb		
38500-170H-DFL	Hallway Drinking Fountain across from Classroom B-10/Left	0.3	ppb		
38500-170H-DFR	Hallway Drinking Fountain across from Classroom B-10/Right	0.2	ppb		
38500-B10-S	Sink in Classroom B-10	3.2	ppb		
38500-B7-S	Sink in Classroom B-7	10.9	ppb		
38500-A6-S	Sink in Classroom A-6	6.3	ppb		
38500-139H-DFL	Hallway Drinking Fountain across from Classroom A-4/Left	0.3	ppb		
38500-139H-DFR	Hallway Drinking Fountain across from Classroom A-4/Right	0.3	ppb		
38500-A4-S	Sink in Classroom A-4	0.9	ppb		
38500-A1-S	Sink in Classroom A-1	1.0	ppb		
38500-109-S	Sink in Clinic	1.8	ppb		
38500-REC-076-DF	Drinking Fountain in Temporary Classroom REC-076	4.4	ppb		
38500-RE-035-DF	Drinking Fountain in Temporary Classroom RE-035	0.9	ppb		
38500-RE-023-DF	Drinking Fountain in Temporary Classroom RE-023	6.1	ppb		
*Sampled on 7/7/16					
** Results from 7/7/20 after elevated fixture was removed and replaced.					
† Sampled as part of Jeffco's ongoing 5 year sampling program.					