

Rose Stein International - Sampled 11/4/16				Resampled*** 4/19/19	
SampleNumber	Description	Lead Result	Unit	Lead Result	Unit
43100-147-S	Sink in Clinic	3.3	ppb	2.5	ppb
43100-100.4H-DF	Hallway Drinking Fountain outside of Classroom 106	1.4	ppb	0.3	ppb
43100-102-S	Sink in Classroom 102	1.3	ppb		
43100-100.1H-WBFS	Hallway Water Bottle Filling Station across from Gym	1.0	ppb	0.3	ppb
43100-100.1H-DF	Hallway Drinking Fountain across from Gym	1.7	ppb	0.4	ppb
43100-113-WBFS	Water Bottle Filling Station in the Gym	1.5	ppb	0.3	ppb
43100-113-DF	Drinking Fountain in Gym	2.1	ppb	0.4	ppb
43100-115-S	Sink in Stage Area	1.0	ppb		
43100-116-S	Sink in Library Work Room	2.4	ppb		
43100-120-S	Sink in Classroom 120	0.7	ppb		
43100-122-S	Sink in Classroom 122	2.3	ppb		
43100-124-S	Sink in Classroom 124	3.6	ppb		
43100-126-S	Sink in Classroom 126	1.3	ppb		
43100-125-S	Sink in Classroom 125	1.8	ppb		
43100-123-S	Sink in Classroom 123	1.6	ppb		
43100-100.5H-WBFS	Hallway Water Bottle Filling Station across from Classroom 130	2.3	ppb	0.2	ppb
43100-100.5H-DF	Hallway Drinking Fountain across from Classroom 130	2.0	ppb	0.2	ppb
43100-128-S	Sink in Art Room	9.3	ppb		
43100-134H-DF	Hallway Drinking Fountain across from Classroom 135	1.4	ppb	1.0	ppb
43100-012-S1	Food Service Sink-Soup Sink	2.9	ppb	0.4	ppb
43100-012-S2	Food Service Sink-Hand Sink	2.1	ppb		
43100-012-S3	Food Service Sink-Sanitize/Rinse	9.9	ppb		
43100-012-S4	Food Service Sink-Rinse/Wash	10.6	ppb		
43100-012-S5	Food Service Sink-Food Prep	4.3	ppb	1.3	ppb
43100-012-S6	Food Service Sink-Hand Sink	0.7	ppb		
43100-014-S1	Food Service Sink-Sprayer	2.5	ppb		
43100-014-S2	Food Service Sink-Hand Sink	9.2	ppb		
43100-R1-114-DF	Drinking Fountain in TEMP R1-114	4.0	ppb		
43100-R1-191-DF	Drinking Fountain in TEMP R1-191	14.3	ppb		
43100-REC-091-EXAM-S	Sink in TEMP REC-091	0.2 **	ppb		
43100-REC-091-WC	Water Cooler in TEMP REC-091	<0.1 * **	ppb		
43100-REC-091-Kitchen-S	Sink in Kitchen in TEMP REC-091	0.1 **	ppb		
* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.					
** This fixture was sampled on 11/18/16.					
*** Resampling results were from samples collected on 4/19/19 as part of an ongoing rotation of lead testing.					