

Shaffer Elementary School		Sampled 4/27/2022	Status
CustomerSampleNumber	Description	Lead Results (ppb)	
40300-B20-S	Sink in Clinic	0.3	
40300-D20-SWB	Sink with Bubblers in Kindergarten Classroom D20	0.1	
40300-D19-SWB	Sink with Bubblers in Classroom D19	0.2	
40300-D18-SWB	Sink with Bubblers in Classroom D18	0.2	
40300-D17-SWB	Sink with Bubblers in Classroom D17	0.1	
40300-D01-SWB	Sink with Bubblers in Classroom D01	0.2	
40300-D02-SWB	Sink with Bubblers in Classroom D02	not in use	
40300-D03-SWB	Sink with Bubblers in Classroom D03	0.4	
40300-D04-SWB	Sink with Bubblers in Classroom D04	0.2	
40300-D09H-DF	Hallway Drinking Fountain outside of Planning Room D21	0.2	
40300-A20-SWB	Sink with Bubblers in Kindergarten Classroom A20	0.1	
40300-A19-SWB	Sink with Bubblers in Classroom A19	0.5	
40300-A18-SWB	Sink with Bubblers in Classroom A18	0.2	
40300-A17-SWB	Sink with Bubblers in Classroom A17	<0.1*	
40300-A01-SWB	Sink with Bubblers in Classroom A01	0.8	
40300-A02-SWB	Sink with Bubblers in Classroom A02	0.2	
40300-A03-SWB	Sink with Bubblers in Classroom A03	0.2	
40300-A04-SWB	Sink with Bubblers in Classroom A04	0.2	
40300-A09H-DF	Hallway Drinking Fountain outside of Planning Room A21	0.3	
40300-E20-SWB	Sink with Bubblers in Classroom E20	0.2	
40300-E19-SWB	Sink with Bubblers in Classroom E19	0.2	
40300-E18-SWB	Sink with Bubblers in Classroom E18	0.2	
40300-E17-SWB	Sink with Bubblers in Classroom E17	0.1	
40300-E01-SWB	Sink with Bubblers in Classroom E01	0.2	
40300-E02-SWB	Sink with Bubblers in Classroom E02	0.2	
40300-E03-SWB	Sink with Bubblers in Classroom E03	0.2	
40300-E04-SWB	Sink with Bubblers in Classroom E04	0.2	
40300-E09H-DF	Hallway Drinking Fountain outside of Planning Room E21	0.3	
40300-C03-S	Sink in Music Room C03	0.5	
40300-C03-SWB	Sink with Bubblers in Music Room C03	not in use	
40300-C26-S4	Food Service Sink-Food Prep	1.1	
40300-C14-DFL	Drinking Fountain across from Gym/Left	0.2	

40300-C14-DFR	Drinking Fountain across from Gym/Right	0.3	
40300-C13-S	Sink in Teacher's Lounge	0.7	
40300-C13-WC	Water Cooler in Teacher's Lounge	<0.1*	
40300-R1-132-DF	Drinking Fountain in TEMP R1-132	16.6	Repairs pending
40300-REC-062-DF	Drinking Fountain in TEMP REC-062	0.7	
40300-RE-034-DF	Drinking Fountain in TEMP RE-034	2.9	
40300-R1-164-DF	Drinking Fountain in TEMP R1-164	9.9	Repairs pending
40300-R1-103-DF	Drinking Fountain in TEMP R1-130	12.7	Repairs pending
40300-REC-072-DF	Drinking Fountain in TEMP REC-072	1.1	
* This results is less than 0.1ppb, which is the lowest level that can be reported by the lab.			