

| Standley Lake High School - Sampled 6/19/20 |   | †Resampled 6/19/20 |       |
|---|---|--------------------|-------|
| CustomerSampleNumber                        | Description   | Lead Result        | Units |
| 78500-D236H-DF                              | Hallway Drinking Fountain across from Classroom D236            | 1.4                | ppb   |
| 78500-D235-S1                               | Sink in Kitchen Classroom D235                                  | 0.7                | ppb   |
| 78500-D235-S2                               | Sink in Kitchen Classroom D235                                  | 0.7                | ppb   |
| 78500-D235-S3                               | Sink in Kitchen Classroom D235                                  | 0.7                | ppb   |
| 78500-D235-S4                               | Sink in Kitchen Classroom D235                                  | 0.7                | ppb   |
| 78500-D235-S5                               | Sink in Kitchen Classroom D235                                  | 0.6                | ppb   |
| 78500-D235-S6                               | Sink in Kitchen Classroom D235                                  | 0.8                | ppb   |
| 78500-235-S7                                | Sink in Kitchen Classroom D235                                  | 0.9                | ppb   |
| 78500-D222-S                                | Sink in Planning Room D222                                      | 0.4*               | ppb   |
| 78500-D234-S                                | Sink in Consumer Science Room D234                              | 0.6                | ppb   |
| 78500-D232H-DF                              | Hallway Drinking Fountain across from Classroom D232            | 0.5                | ppb   |
| 78500-D232H-WBFS                            | Hallway Water Bottle Filling Station across from Classroom D232 | 0.6                | ppb   |
| 78500-B231H-DFL                             | Hallway Drinking Fountain outside of Classroom B2321/Left       | 1.3                | ppb   |
| 78500-B231H-DFR                             | Hallway Drinking Fountain outside of Classroom B2321/Right      | 0.3                | ppb   |
| 78500-B223-S                                | Sink in Classroom B223  | 2.9                | ppb   |
| 78500-B202H-DF                              | Hallway Drinking Fountain outside of Storage Room B202          | 0.2                | ppb   |
| 78500-B202H-WBFS                            | Hallway Water Bottle Filling Station outside Storage Room B202  | 0.2                | ppb   |
| 78500-B203-S                                | Sink in Library Work Room                                       | 0.3*               | ppb   |
| 78500-A225-S                                | Sink in Clinic  | 2.7                | ppb   |
| 78500-A226-S                                | Sink in Planning Room A226                                      | 0.5                | ppb   |
| 78500-A228H-DF                              | Hallway Drinking Fountain across from Asst Principal Office     | 2.2                | ppb   |
| 78500-A218H-DFR                             | Hallway Drinking Fountain outside of Auditorium/Right           | 0.4                | ppb   |
| 78500-A218H-DFL                             | Hallway Drinking Fountain outside of Auditorium/Left            | 0.2                | ppb   |
| 78500-A218H-WBFS                            | Hallway Drinking Fountain outside Auditorium                    | 0.4                | ppb   |
| 78500-C203-DF                               | Drinking Fountain in Vocal Room C203                            | 1.1                | ppb   |
| 78500-C208-S                                | Sink in Instrument/Band Room C208                               | 0.8                | ppb   |
| 78500-A130-S1                               | Sink in Laboratory A130   | 3.4*               | ppb   |
| 78500-A130-S2                               | Sink in Laboratory A130   | 1.0*               | ppb   |
| 78500-A130-S3                               | Sink in Laboratory A130   | 2.2*               | ppb   |
| 78500-A130-S4                               | Sink in Laboratory A130   | 2.3*               | ppb   |
| 78500-131-S1                                | Sink in Laboratory A131   | 0.4*               | ppb   |
| 78500-A131-S2                               | Sink in Laboratory A131   | 1.1*               | ppb   |
| 78500-A131-S3                               | Sink in Laboratory A131   | 1.4*               | ppb   |
| 78500-A131-S4                               | Sink in Laboratory A131   | 2.7*               | ppb   |
| 78500-A139H-DF                              | Hallway Drinking Fountain across from Classroom A137/138        | 6.2                | ppb   |
| 78500-D131-DF                               | Drinking Fountain in Weight Room D131                           | 0.6                | ppb   |
| 78500-D118-IM                               | Ice Machine in Training Room D118                               | 0.1                | ppb   |
| 78500-D118-S                                | Sink in Training Room D118                                      | 2.4                | ppb   |
| 78500-D119-DF                               | Drinking Fountain in Women's Locker Room                        | 0.5                | ppb   |
| 78500-D122-DF                               | Drinking Fountain in Women's PE Locker Room                     | 0.4                | ppb   |
| 78500-D107-DF                               | Drinking Fountain in Men's Locker Room                          | 0.6                | ppb   |
| 78500-D116-S                                | Sink in Training Room D116                                      | 1.8                | ppb   |
| 78500-112-DF                                | Drinking Fountain Men's Athletic Locker Room                    | 0.5                | ppb   |
| 78500-D134-DF                               | Drinking Fountain in Small Gym                                  | 1.4                | ppb   |
| 78500-B139-S                                | Sink in STEM Lab B139   | 1.0                | ppb   |
| 78500-B132H-DF                              | Hallway Drinking Fountain outside of Art Room B138              | 0.3                | ppb   |
| 78500-B132-S1                               | Sink in Art Room B132   | 0.6*               | ppb   |
| 78500-B132-S2                               | Sink in Art Room B132   | 0.6*               | ppb   |
| 78500-B132-S3                               | Sink in Art Room B132   | 0.7*               | ppb   |
| 78500-B132-S4                               | Sink in Art Room B132   | 1.0*               | ppb   |
| 78500-B134-S1                               | Sink in Art Room B134   | 0.1*               | ppb   |
| 78500-B134-S2                               | Sink in Art Room B134   | 0.2*               | ppb   |
| 78500-B134-S3                               | Sink in Art Room B134   | 0.5*               | ppb   |
| 78500-B134-S4                               | Sink in Art Room B134   | 1.2*               | ppb   |
| 78500-B134-S5                               | Sink in Art Room B134   | 0.2*               | ppb   |
| 78500-B134-S6                               | Sink in Art Room B134   | 0.1*               | ppb   |

|                |  |         |     |
|----------------|--|---------|-----|
| 78500-B134-S7  | Sink in Art Room B134  | <0.1 *  | ppb |
| 78500-B134-S8  | Sink in Art Room B134  | <0.1 *  | ppb |
| 78500-B135-S   | Sink in Technology Lab B135                                  | 2.4     | ppb |
| 78500-B136-S1  | Sink in Auto Shop B136                                       | 2.2*    | ppb |
| 78500-B136-S2  | Sink in Auto Shop B136                                       | 2.6*    | ppb |
| 78500-B136-S3  | Sink in Auto Shop B136                                       | 2.7*    | ppb |
| 78500-B137-S1  | Sink in Tech Ed B137   | 5.6     | ppb |
| 78500-B137-S2  | Sink in Tech Ed B137   | 10.6    | ppb |
| 78500-B109-S1  | Sink in Laboratory B109                                      | 0.7*    | ppb |
| 78500-B109-S2  | Sink in Laboratory B109                                      | 0.5*    | ppb |
| 78500-B109-S3  | Sink in Laboratory B109                                      | 1.0*    | ppb |
| 78500-B109-S4  | Sink in Laboratory B109                                      | 0.9*    | ppb |
| 78500-B109-S5  | Sink in Laboratory B109                                      | 2.4*    | ppb |
| 78500-B108H-DF | Hallway Drinking Fountain across from Science Prep Room B111 | 0.4*    | ppb |
| 78500-B108-S1  | Sink in Laboratory B108                                      | 0.7*    | ppb |
| 78500-B108-S2  | Sink in Laboratory B108                                      | 1.1*    | ppb |
| 78500-B108-S3  | Sink in Laboratory B108                                      | 0.7*    | ppb |
| 78500-B108-S4  | Sink in Laboratory B108                                      | 0.8*    | ppb |
| 78500-B108-S5  | Sink in Laboratory B108                                      | 8.7*    | ppb |
| 78500-B107-S1  | Sink in Laboratory B107                                      | 0.8*    | ppb |
| 78500-B107-S2  | Sink in Laboratory B107                                      | 0.9*    | ppb |
| 78500-B107-S3  | Sink in Laboratory B107                                      | 0.8*    | ppb |
| 78500-B107-S4  | Sink in Laboratory B107                                      | 0.9*    | ppb |
| 78500-B107-S5  | Sink in Laboratory B107                                      | 5.1*    | ppb |
| 78500-B106-S1  | Sink in Ceramics Room B106                                   | 1.0*    | ppb |
| 78500-B106-S2  | Sink in Ceramics Room B106                                   | 0.3*    | ppb |
| 78500-B106-S3  | Sink in Ceramics Room B106                                   | 0.3*    | ppb |
| 78500-B106-S4  | Sink in Ceramics Room B106                                   | 0.3*    | ppb |
| 78500-B106-S5  | Sink in Ceramics Room B106                                   | 0.5*    | ppb |
| 78500-B106-S6  | Sink in Ceramics Room B106                                   | 0.2*    | ppb |
| 78500-B106-S7  | Sink in Ceramics Room B106                                   | 0.3*    | ppb |
| 78500-B106-S8  | Sink in Ceramics Room B106                                   | 0.1*    | ppb |
| 78500-B110-S1  | Sink in Science Prep Room B110                               | 1.1*    | ppb |
| 78500-B110-S2  | Sink in Science Prep Room B110                               | 0.6*    | ppb |
| 78500-B105-S1  | Sink in Laboratory B105                                      | 1.8*    | ppb |
| 78500-B105-S2  | Sink in Laboratory B105                                      | 2.3*    | ppb |
| 78500-B105-S3  | Sink in Laboratory B105                                      | 0.7*    | ppb |
| 78500-B105-S4  | Sink in Laboratory B105                                      | 0.6*    | ppb |
| 78500-B104-S1  | Sink in Laboratory B104                                      | 2.1*    | ppb |
| 78500-B104-S2  | Sink in Laboratory B104                                      | 0.7*    | ppb |
| 78500-B104-S3  | Sink in Laboratory B104                                      | 1.7*    | ppb |
| 78500-B104-S4  | Sink in Laboratory B104                                      | 2.1*    | ppb |
| 78500-B111-S1  | Sink in Science Prep Room B111                               | 1.3*    | ppb |
| 78500-B111-S2  | Sink in Science Prep Room B111                               | 0.7*    | ppb |
| 78500-B111-S3  | Sink in Science Prep Room B111                               | 0.4*    | ppb |
| 78500-B111-S4  | Sink in Science Prep Room B111                               | 2.4* ** | ppb |
| 78500-B112-S   | Sink in Flammable Storage B112                               | 6.7*    | ppb |
| 78500-B103-S1  | Sink in Laboratory B103                                      | 0.4*    | ppb |
| 78500-B103-S2  | Sink in Laboratory B103                                      | 1.2*    | ppb |
| 78500-B103-S3  | Sink in Laboratory B103                                      | 0.8*    | ppb |
| 78500-B103-S4  | Sink in Laboratory B103                                      | 0.7*    | ppb |
| 78500-B103-S5  | Sink in Laboratory B103                                      | 1.1*    | ppb |
| 78500-B103-S6  | Sink in Laboratory B103                                      | 0.9*    | ppb |
| 78500-B103-S7  | Sink in Laboratory B103                                      | 1.1*    | ppb |
| 78500-B103-S8  | Sink in Laboratory B103                                      | 0.7*    | ppb |
| 78500-B102-S1  | Sink in Laboratory B102                                      | 4.8*    | ppb |
| 78500-B102-S2  | Sink in Laboratory B102                                      | 1.8*    | ppb |
| 78500-B102-S3  | Sink in Laboratory B102                                      | 2.0*    | ppb |

|   |  |      |     |
|---|--|------|-----|
| 78500-B102-S4   | Sink in Laboratory B102                                    | 1.2* | ppb |
| 78500-B102-S5   | Sink in Laboratory B102                                    | 0.6* | ppb |
| 78500-B102-S6   | Sink in Laboratory B102                                    | 4.4* | ppb |
| 78500-B102-S7   | Sink in Laboratory B102                                    | 0.8* | ppb |
| 78500-B102-S8   | Sink in Laboratory B102                                    | 8.7* | ppb |
| 78500-B102H-DF  | Hallway Drinking Fountain outside of Laboratory B102       | 0.7  | ppb |
| 78500-A140-S1   | Sink in Laboratory A140                                    | 1.9* | ppb |
| 78500-A140-S2   | Sink in Laboratory A140                                    | 1.5* | ppb |
| 78500-A140-S3   | Sink in Laboratory A140                                    | 2.8* | ppb |
| 78500-A140-S4   | Sink in Laboratory A140                                    | 0.7* | ppb |
| 78500-C103-S1   | Sink in Store C103   | 0.7* | ppb |
| 78500-C103-S2   | Sink in Store C103   | 1.9* | ppb |
| 78500-A121-S1   | Food Service Sink-Hand Sink                                | 1.7* | ppb |
| 78500-A121-S2   | Food Service Sink-Food Prep                                | 9.8  | ppb |
| 78500-A121-S3   | Food Service Sink-Sprayer                                  | 0.8* | ppb |
| 78500-A121-S4   | Food Service Sink-Wash/Rinse                               | 1.0* | ppb |
| 78500-A121-S5   | Food Service Sink-Rinse/Sanitize                           | 1.5* | ppb |
| 78500-A121-S6   | Food Service Sink-Sprayer                                  | 2.6* | ppb |
| 78500-A121-S7   | Food Service Sink-Hand Sink                                | 1.1* | ppb |
| 78500-A124-S  | Sink in Kitchen Prep Area                                  | 7.4  | ppb |
| 78500-A126-DF   | Drinking Fountain in Cafeteria                             | 1.5  | ppb |
| 78500-A116-S  | Sink in Teacher's Lounge                                   | 0.5  | ppb |
| 78500-A101H-DF  | Hallway Drinking Fountain across from Drama Classroom A101 | 1.2  | ppb |
| 78500-A100-S  | Sink in Drama Classroom A100                               | 0.2* | ppb |
| 78500-A117H-DF  | Hallway Drinking Fountain outside of Food Service          | 0.4* | ppb |
| 78500-A102-S  | Sink in Computer Room A102                                 | 4.9  | ppb |
| 78500-A103-S  | Sink in Classroom A103                                     | 0.3  | ppb |
| 78500-A104-S  | Sink in Classroom A104                                     | 0.4  | ppb |
| 78500-C106H-DFL   | Hallway Drinking Fountain outside of Large Gym/Left        | 0.1  | ppb |
| 78500-C106H-WBFS  | Hallway Bottle Filling Station outside Large Gym           | 0.1  | ppb |
| 78500-C106H-DFR   | Hallway Drinking Fountain outside of Large Gym/Right       | 0.1  | ppb |
| *Sampled on 10/14/16  |  |      |     |
| ** Results from 11/30/16 after elevated fixture was removed and replaced. |  |      |     |
| † Sampled as part of Jeffco's ongoing 5 year sampling program.            |  |      |     |