

Sierra Elementary School		Sampled 7/7/20 [†]	
CustomerSampleNumber	Description	Lead Result	Units
40500-101L-S	Sink in Clinic	0.7	ppb
40500-101L-HS	Hand Sprayer in Clinic	1.7	ppb
40500-101C-S	Sink in Conference room	0.9	ppb
40500-101C-HS	Hand Sprayer in Conference Room	2.0	ppb
40500-101D-WD	Water Dispenser in refrigerator in resource room	<0.1*	ppb
40500-101D-IM	Ice Machine in refrigerator n resource room	0.3	ppb
40500-105A-S	Sink in music room	1.1	ppb
40500-106-DFL	Gym Drinking Fountain/Left	2.6	ppb
40500-106-DFR	Gym Drinking Fountain/Right	2.3	ppb
40500-108-S3	Sink in Art Room	0.2	ppb
40500-108-S4	Sink in Art Room	0.4	ppb
40500-108-S5	Sink in Art Room	0.6	ppb
40500-109B-S	Sink in Office	0.6	ppb
40500-113-S	Sink in Classroom 113	0.3	ppb
40500-115-S	Sink in Classroom 115	0.3	ppb
40500-116-S	Sink in Classroom 116	0.5	ppb
40500-117-S	Sink in Classroom 117	0.5	ppb
40500-118-S	Sink in Classroom 118	0.4	ppb
40500-119-S	Sink in Classroom 119	1.4	ppb
40500-120-S	Sink in Classroom 120	0.3	ppb
40500-122-S	Sink in Classroom 122	0.3	ppb
40500-123-S	Sink in Classroom 123	0.3	ppb
40500-125-S	Sink in Resource Rm 125	0.4	ppb
40500-125-WD	Water dispenser in refridgerator in resource rm 125	<0.1*	ppb
40500-125-IM	Ice Machine in refridgerator resource rm 125	2.1	ppb
40500-103E-DFL	Hallway Drinking Fountain near resource rm 125/Left	0.3	ppb
40500-103E-DFR	Hallway Drinking Fountain near resource rm 125/Right	0.3	ppb
40500-126-S	Sink in Classroom 126	0.5	ppb
40500-127-S	Sink in Classroom 127	0.5	ppb
40500-128-S	Sink in Classroom 128	0.6	ppb
40500-129-S	Sink in Classroom 129	0.6	ppb
40500-130-S1	Sink in Classroom 130	0.3	ppb
40500-130-S2	Sink in Classroom 130	0.3	ppb
40500-131-S1	Sink in Classroom 131	0.3	ppb
40500-131-S2	Sink in Classroom 131	0.3	ppb
40500-132-S1	Sink in Classroom 132	0.3	ppb
40500-132-S2	Sink in Classroom 132	0.5	ppb
40500-133-S1	Sink in Classroom 133	0.4	ppb
40500-135-S2	Food Service Sink - Wash Sprayer	0.5	ppb
40500-134-DFL	Cafeteria Drinking Fountain/Left	0.4	ppb
40500-134-DFR	Cafeteria Drinking Fountain/Right	0.8	ppb
40500-135-S7	Food Service Sink - Food Prep	5.5	ppb
40500-135-S8	Food Service Sink - Food Prep Sprayer	2.6	ppb
40500-103B-DFL	Hallway Drinking Fountain Near Gym/Left	0.3	ppb
40500-103B-WBFS	Hallway Water Bottle Fill Station Near Gym	0.9	ppb
40500-103B-DFR	Hallway Drinking Fountain Near Gym/Right	0.3	ppb
40500-102E-S	Sink in Workroom	0.5	ppb
40500-102-S	Sink in Classroom 102	0.3	ppb
40500-102-HS	Hand Sprayer in Classroom 102	0.8	ppb
40500-204-S	Sink in Classroom 204	0.3	ppb
40500-205-S	Sink in Classroom 205	0.4	ppb
40500-206-S	Sink in Classroom 206	0.2	ppb
40500-207-S	Sink in Classroom 207	0.5	ppb
40500-208-S	Sink in Classroom 208	0.5	ppb
40500-209-S	Sink in Classroom 209	0.4	ppb
40500-210-S	Sink in Classroom 210	0.2	ppb
40500-212-S	Sink in Classroom 212	0.2	ppb
40500-213-S	Sink in Classroom 213	0.4	ppb
40500-215-S	Sink in Resource Rm 215	0.3	ppb
40500-215-WD	Water dispenser in refridgerator in resource rm 215	<0.1*	ppb
40500-200-DFL	Hallway Drinking Fountain Near Resource Room 215/Left	0.1	ppb
40500-200-WBFS	Water Bottle Fill Station Near Resource Room 215	0.2	ppb
40500-200-DFR	Hallway Drinking Fountain Near Resource Room 215/Right	0.1	ppb
40500-216-S	Sink in Classroom 216	0.5	ppb
40500-217-S	Sink in Classroom 217	0.2	ppb
40500-218-S	Sink in Classroom 218	0.4	ppb
40500-219-S	Sink in Classroom 219	0.4	ppb

* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.

[†] Sampled as part of Jeffco's ongoing 5 year sampling program.