

Shelton Elementary School - Sampled 10/7/16				Resampled** 12/6/16		Resampled 5/12/17	
SampleNumber	Description	Lead Results	Unit	Lead Result	Units	Lead Result	Unit
40400-106-S	Sink in Classroom 106	13.8	ppb				
40400-108H-DF	Hallway Drinking Fountain across from Classroom 104	<0.1 *	ppb			<0.1 *	ppb
40400-104-SWB	Sink with Bubblers in Classroom 104	1.6	ppb			0.4	ppb
40400-104-S	Sink in Classroom 104	9.4	ppb				
40400-103-S	Sink in Classroom 103	12.4	ppb				
40400-103-SWB	Sink with Bubblers in Classroom 103	0.5	ppb			0.2	ppb
40400-101-S	Sink in Classroom 101	14.1	ppb				
40400-101-SWB	Sink with Bubblers in Classroom 101	1.7	ppb			0.3	ppb
40400-010-S1	Sink in Art Room 010	12.2	ppb				
40400-010-S2	Sink in Art Room 010	7.8	ppb				
40400-010-S3	Sink in Art Room 010	8.1	ppb				
40400-010-S4	Sink in Art Room 010	4.2	ppb				
40400-010-S5	Sink in Art Room 010	2.6	ppb				
40400-015-S	Sink in Library Work Room	20.3	ppb	0.6	ppb		
40400-206-S	Sink in Classroom 206	3.7	ppb				
40400-206-SWB	Sink with Bubblers in Classroom 206	1.3	ppb			0.5	ppb
40400-208H-DF	Hallway Drinking Fountain across from Classroom 204	<0.1 *	ppb			<0.1 *	ppb
40400-204-S	Sink in Classroom 204	10.4	ppb				
40400-204-SWB	Sink with Bubblers in Classroom 204	2.1	ppb			1.2	ppb
40400-203-S	Sink in Classroom 203	11.7	ppb				
40400-203-SWB	Sink with Bubblers in Classroom 203	3.6	ppb			0.8	ppb
40400-201-S	Sink in Classroom 201	15.7	ppb	0.7	ppb		
40400-201-SWB	Sink with Bubblers in Classroom 201	1.1	ppb			0.9	ppb
40400-406-S	Sink in Classroom 406	15.5	ppb	0.7	ppb		
40400-406-SWB	Sink with Bubblers in Classroom 406	3.9	ppb			1.7	ppb
40400-408H-DF	Hallway Drinking Fountain across from Kindergarten Classroom 404	<0.1 *	ppb			<0.1 *	ppb
40400-404-S	Sink in Kindergarten Classroom 404	9.6	ppb				
40400-404-SWB	Sink with Bubblers in Kindergarten Classroom 404	2.1	ppb			0.7	ppb
40400-403-S	Sink in Kindergarten Classroom 403	11.8	ppb				
40400-403-SWB	Sink with Bubblers in Kindergarten Classroom 403	0.9	ppb			0.3	ppb
40400-401-S	Sink in Classroom 401	6.8	ppb				
40400-401-SWB	Sink with Bubblers in Classroom 401	1.3	ppb			0.8	ppb
40400-048-S2	Food Service Sink-Hand Sink	14.6	ppb				
40400-049-S2	Food Service Sink-Wash/Rinse	2.5	ppb			2.9	ppb
40400-049-S3	Food Service Sink-Rinse/Sanitize	3.0	ppb			6.0	ppb
40400-049-S4	Food Service Sink-Hand Sink	7.6	ppb				
40400-049-S5	Food Service Sink-Food Prep	0.7	ppb			0.8	ppb
40400-045-DF	Drinking Fountain in Cafeteria	<0.1 *	ppb			<0.1 *	ppb
40400-034-S	Sink in Clinic	1.1	ppb			1.3	ppb
40400-037-S	Sink in Teacher's Lounge	0.4	ppb			0.4	ppb
40400-040-DF	Drinking Fountain in Gym	<0.1 *	ppb			<0.1 *	ppb
40400-044H-DF	Hallway Drinking Fountain outside of Cafeteria	<0.1 *	ppb			<0.1 *	ppb
40400-306-S	Sink in Classroom 306	11.4	ppb				
40400-306-SWB	Sink with Bubblers in Classroom 306	0.3	ppb			<0.1 *	ppb
40400-308H-DF	Hallway Drinking Fountain across from Classroom 304	<0.1 *	ppb			<0.1 *	ppb
40400-304-S	Sink in Classroom 304	11.2	ppb				
40400-304-SWB	Sink with Bubblers in Classroom 304	1.5	ppb			0.2	ppb
40400-303-S	Sink in Classroom 303	11.8	ppb				
40400-303-SWB	Sink with Bubblers in Classroom 303	0.5	ppb			0.3	ppb
40400-301-S	Sink in Classroom 301	15.9	ppb	1.1	ppb		
40400-301-SWB	Sink with Bubblers in Classroom 301	0.9	ppb			0.6	ppb

\* This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.

\*\* Resampling results after elevated fixtures were removed and replaced.