

| Welchester Elementary School - Sampled 6/23/16 | | | | Resampled ** 8/19/16 | | Resampled † 5/18/17 | |
|---|---|-------------|-------|----------------------|------|---------------------|------|
| SampleNumber | Description | Lead Result | Units | Lead Result | Unit | Lead Result | Unit |
| 45500-103-S1 | Food Service Sink-Food Prep | 8.4 | ppb | | | 7.6 | ppb |
| 45500-103-S2 | Food Service Sink-Hand Sink | 5.4 | ppb | | | | |
| 45500-103-S3 | Food Service Sink-Wash/Rinse | 12.8 | ppb | | | | |
| 45500-103-S4 | Food Service Sink-Rinse/Sanitize | 10.3 | ppb | | | | |
| 45500-200-DF | Drinking Fountain in Cafeteria | 4.4 | ppb | | | 3.1 | ppb |
| 45500-107X-S | Sink in Teacher's Lounge | 0.7 | ppb | | | <0.1 * | ppb |
| 45500-117-S | Sink in Classroom 117 | 75.4 | ppb | 2.7 | ppb | | |
| 45500-117-SWB | Sink with Bubbler in Classroom 117 | 3.9 | ppb | | | 5.8 | ppb |
| 45500-119-S | Sink in Classroom 119 | 197.8 | ppb | 82.3 *** | ppb | 3.5 | ppb |
| 45500-119-SWB | Sink with Bubbler in Classroom 119 | 19.5 | ppb | 5.3 | ppb | 61.4 ‡ | ppb |
| 45500-120-S | Sink in Classroom 120 | 5.3 | ppb | | | | |
| 45500-120-SWB | Sink with Bubbler in Classroom 120 | 2.4 | ppb | | | 1.3 | ppb |
| 45500-121-S | Sink in Classroom 121 | 12.5 | ppb | | | | |
| 45500-121-SWB | Sink with Bubbler in Classroom 121 | 4.9 | ppb | | | 2.7 | ppb |
| 45500-122-S | Sink in Classroom 122 | 14.0 | ppb | | | | |
| 45500-122-SWB | Sink with Bubbler in Classroom 122 | 5.7 | ppb | | | 2.3 | ppb |
| 45500-123-S | Sink in Classroom 123 | 10.1 | ppb | | | | |
| 45500-123-SWB | Sink with Bubbler in Classroom 123 | 0.6 | ppb | | | 1.4 | ppb |
| 45500-603H-DF | Hallway Drinking Fountain near Classroom 123 | 0.6 | ppb | | | 0.2 | ppb |
| 45500-127-S | Sink in Classroom 127 | 14.6 | ppb | | | | |
| 45500-127-SWB | Sink with Bubbler in Classroom 127 | 0.5 | ppb | | | 0.3 | ppb |
| 45500-128-S | Sink in Classroom 128 | 8.0 | ppb | | | | |
| 45500-128-SWB | Sink with Bubbler in Classroom 128 | 0.3 | ppb | | | 0.2 | ppb |
| 45500-129-S | Sink in Classroom 129 | 8.2 | ppb | | | | |
| 45500-129-SWB | Sink with Bubbler in Classroom 129 | 3.3 | ppb | | | 2.8 | ppb |
| 45500-131-S | Sink in Classroom 131 | 4.2 | ppb | | | | |
| 45500-131-SWB | Sink with Bubbler in Classroom 131 | 3.7 | ppb | | | 3.0 | ppb |
| 45500-133-S | Sink in Classroom 133 | 3.4 | ppb | | | | |
| 45500-133-SWB | Sink with Bubbler in Classroom 133 | 2.4 | ppb | | | 1.7 | ppb |
| 45500-130-S | Sink in Classroom 130 | 13.8 | ppb | | | | |
| 45500-130-SWB | Sink with Bubbler in Classroom 130 | 3.0 | ppb | | | 7.2 | ppb |
| 45500-132-S | Sink in Classroom 132 | 103.2 | ppb | 5.8 | ppb | | |
| 45500-132-SWB | Sink with Bubbler in Classroom 132 | 3.6 | ppb | | | 2.5 | ppb |
| 45500-140-S | Sink in Library Workroom | 30.6 | ppb | 14.9 | ppb | | |
| 45500-125-S1 | Art Room Sink | 4.3 | ppb | | | | |
| 45500-125-S2 | Art Room Sink | 4.6 | ppb | | | | |
| 45500-135-S | Sink in Classroom 135 | 13.7 | ppb | | | | |
| 45500-135-SWB | Sink with Bubbler in Classroom 135 | 1.2 | ppb | | | 1.1 | ppb |
| 45500-137-S | Sink in Music Room | 8.6 | ppb | | | | |
| 45500-137-SWB | Sink with Bubbler in Music Room | 9.0 | ppb | | | 10.4 | ppb |
| 45500-112-S | Sink in Classroom 112 | 32.2 | ppb | 23.9 *** | ppb | 28.5 ‡ | ppb |
| 45500-112-SWB | Sink with Bubbler in Classroom 112 | 52.0 | ppb | 13.3 *** | ppb | 34.7 ‡ | ppb |
| 45500-114-S | Sink in Kindergarten Classroom 114 | 20.6 | ppb | 3.4 *** | ppb | 6.1 | ppb |
| 45500-114-SWB | Sink with Bubbler in Kindergarten Classroom 114 | 3.8 | ppb | | | 7.1 | ppb |
| 45500-116-S | Sink in Classroom 116 | 34.3 | ppb | 3.6 *** | ppb | 3.7 | ppb |
| 45500-116-SWB | Sink with Bubbler in Classroom 116 | 1.4 | ppb | | | 2.4 | ppb |
| 45500-118-S | Sink in Classroom 118 | 4.9 | ppb | | | | |
| 45500-118-SWB | Sink with Bubbler in Classroom 118 | 7.1 | ppb | | | 5.1 | ppb |
| 45500-109-S | Sink in Kindergarten Classroom 109 | 1.9 | ppb | | | | |
| 45500-109-SWB | Sink with Bubbler in Kindergarten Classroom 109 | 0.5 | ppb | | | 0.6 | ppb |
| 45500-104-S | Sink in Clinic | 0.6 | ppb | | | 0.5 | ppb |
| * This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab. | | | | | | | |
| ** Resampling results after elevated fixtures were repaired, or removed and replaced. | | | | | | | |
| *** This result was measured after running water for a short time. | | | | | | | |
| † Resampling results were from samples collected on 5/18/17 as part of an ongoing rotation of lead testing. | | | | | | | |
| ‡ This fixture is signed Do Not Drink, Fountain out of Service. | | | | | | | |
| ‡ ‡ This fixture is signed Do Not Drink, No Food Prep, For Handwashing Only. | | | | | | | |