

| Warren Tech North Campus - Sampled 10/25/16 | | | | Resampled* 1/20/17 | | Resampled** 5/17/18 | |
|--|--|-------------|------|--------------------|------|---------------------|------|
| SampleNumber | Description | Lead Result | Unit | Lead Result | Unit | Lead Result | Unit |
| 55020-A110-S | Sink in Clinic | 2.5 | ppb | | | 2.0 | ppb |
| 55020-A109-S | Sink in Planning Room A109 | 0.9 | ppb | | | 0.6 | ppb |
| 55020-A135H-DFL | Hallway Drinking Fountain outside of Library/Left | 0.4 | ppb | | | 0.1 | ppb |
| 55020-A135H-DFR | Hallway Drinking Fountain outside of Library/Right | 2.1 | ppb | | | 1.0 | ppb |
| 55020-A135H-WBFS | Water Bottle Filling Station outside of Library | 0.7 | ppb | | | 0.2 | ppb |
| 55020-A146-S | Sink in Technology Lab A146 | 1.7 | ppb | | | 1.9 | ppb |
| 55020-A142-S | Sink in Lab Classroom A142 | 1.6 | ppb | | | 1.0 | ppb |
| 55020-A210-S | Sink in Nursing Lab A210 | 15.8 | ppb | 2.3 | ppb | 0.7 | ppb |
| 55020-A219-S | Sink in Sports Medicine Classroom A219 | 28.3 | ppb | 0.7 | ppb | 0.7 | ppb |
| 55020-A215H-DFL | Main Hallway Drinking Fountain on 2nd Floor/Left | 1.3 | ppb | | | 0.8 | ppb |
| 55020-A215H-DFR | Main Hallway Drinking Fountain on 2nd Floor/Right | 1.9 | ppb | | | 0.9 | ppb |
| * Resampling results after elevated fixtures were repaired, or removed and replaced. | | | | | | | |
| ** Resampling results were from samples collected on 5/17/18 as part of an ongoing five-year rotation of lead testing. | | | | | | | |