

Warren Tech South		Sampled 5/4/2022	Status
CustomerSampleNumber	Description	Lead Results (ppb)	
55040-104-S	Sink in room 104	0.2	
55040-120H-WBFS	Water Bottle filling station in hallway 120	<0.1*	
55040-120H-DFL	Drinking fountain in hallway 120-Left	<0.1*	
55040-120H-DFR	Drinking fountain in hallway 120-Right	<0.1*	
55040-111-S	Sink in Room 111	<0.1*	
55040-111-WD	Water Dispenser in room 111	<0.1*	
55040-111-IM	Ice machine in room 111	0.1	
55040-126-S1	Sink in room 126	0.3	
55040-126-S2	Sink in room 126	0.4	
55040-126-WBFS	Water Bottle filling station in room 126	0.1	
55040-126-DFL	Drinking fountain in room 126-Left	0.1	
55040-126-DFR	Drinking fountain in room 126-Right	0.1	
55040-151-S	Sink in room 151	0.5	
55040-152-S	Sink in room 151	0.4	
55040-140H-WBFS	Water Bottle filling station in hallway 140	missed 1st draw	Sampling pending
55040-140H-DFL	Drinking fountain in hallway 140-Left	<0.1*	
55040-140H-DFR	Drinking fountain in hallway 140-Right	<0.1*	
* This results is less than 0.1ppb, which is the lowest level that can be reported by the lab.			