

Weber Elementary - Sampled 6/26/20 <sup>†</sup>			
CustomerSampleNumber	Description	Lead Result	Units
45200-10-S	Sink in Teacher's Lounge	0.8	ppb
45200-61XH-DF	Drinking Fountain in Hallway across from Book Room (Room 30)	0.8	ppb
45200-61XH-WBFS	Water Bottle Filling Station in Hallway across from Book Room (Rm 30)	1.0	ppb
45200-60XH-DFL	Drinking Fountain in Hallway across from Classroom 19/Left	0.7	ppb
45200-60XH-DFR	Drinking Fountain in Hallway across from Classroom 19/Right	0.8	ppb
45200-B4H-DFL	Drinking Fountain in Hallway across from Classroom 15/Left	0.5	ppb
45200-B4H-DFR	Drinking Fountain in Hallway across from Classroom 15/Right	1.0	ppb
45200-37H-S	Sink in Hallway between Classrooms 21 and 25	0.6	ppb
45200-64XH-DFL	Drinking Fountain in Hallway just outside Classroom 24/Left	0.1	ppb
45200-64XH-DFR	Drinking Fountain in Hallway just outside Classroom 24/Right	0.1	ppb
45200-44-S1	Food Service - Hand Sink	3.0*	ppb
45200-44-S2	Food Service - Hose Sprayer	8.3*	ppb
45200-44-S3	Food Service - Sanitize/Rinse Sink	8.7*	ppb
45200-44-S4	Food Service - Rinse/Wash Sink	8.1*	ppb
45200-44-S5	Food Service - Food Prep Sink (on left)	11.5*	ppb
45200-44-S6	Food Service - Food Prep Sink (on right)	Fixture Removed	
45200-45-DF	Drinking Fountain in Cafeteria	0.2	ppb
45200-45-S	Sink in Cafeteria	7.3	ppb
45200-66H-DF	Drinking Fountain in Hallway near Room 23	0.2	ppb
45200-65H-DF	Drinking Fountain in Hallway near Art Room	0.4	ppb
45200-28-S1	Sink in Art Room	3.2*	ppb
45200-28-S2	Sink in Art Room	1.8*	ppb
45200-76X-S	Sink in Office (Room 76X) near Music Room	6.3	ppb
45200-51H-DF	Drinking Fountain in Hallway near Gym	0.7	ppb
45200-52X-S	Sink in Clinic	1.7	ppb
45200-63XH-S1	Sink in Hallway near Principal's Office	3.1	ppb
45200-63XH-DFL	Drinking Fountain in Hallway across from Classroom 5/Left	0.4	ppb
45200-63XH-DFR	Drinking Fountain in Hallway across from Classroom 5/Right	0.6	ppb
45200-63XH-S2	Sink in Hallway across from Classroom 5	0.5	ppb
45200-63XH-S3	Sink in Hallway across from Classroom 2	5.9	ppb
45200-170H-DFL	Drinking Fountain in Hallway across from Classroom 1/Left	1.0	ppb
45200-170H-DFR	Drinking Fountain in Hallway across from Classroom 1/Right	0.5	ppb
45200-R1-154-DF	Drinking Fountain in Temporary Classroom R1-154	7.8	ppb
45200-R1-153-DF	Drinking Fountain in Temporary Classroom R1-153	14.7*	ppb
45200-62XH-DFL	Drinking Fountain in Hallway across from Classroom 8/Left	0.4	ppb
45200-62XH-DFR	Drinking Fountain in Hallway across from Classroom 8/Right	0.4	ppb
*Sampled on 7/13/16			
† Sampled as part of Jeffco's ongoing 5 year sampling program.			