

Warder Elementary School		Sampled 6/26/20†		Resampled 7/10/20***	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
44800-131-S	Sink in Classroom 131	0.9	ppb		
44800-131-SWB	Sink with Bubblers in Classroom 131	0.2	ppb		
44800-133-S	Sink in Classroom 133	0.3	ppb		
44800-133-SWB	Sink with Bubblers in Classroom 133	0.3	ppb		
44800-135-S	Sink in Classroom 135	0.8	ppb		
44800-135-SWB	Sink with Bubblers in Classroom 135	0.2	ppb		
44800-137-S	Sink in Classroom 137	0.3	ppb		
44800-137-SWB	Sink with Bubblers in Classroom 137	0.3	ppb		
44800-134-S	Sink in Classroom 134	2.9	ppb		
44800-134-SWB	Sink with Bubblers in Classroom 134	0.2	ppb		
44800-132-S	Sink in Classroom 132	1.5	ppb		
44800-132-SWB	Sink with Bubblers in Classroom 132	0.2	ppb		
44800-111H-S	Sink in Hallway across from Classroom 133	0.3	ppb		
44800-111H-SWB	Sink with Bubblers in Hallway across from Classroom 133	0.2	ppb		
44800-130-S	Sink in Classroom 130	0.2	ppb		
44800-130-SWB	Sink with Bubblers in Classroom 130	0.2	ppb		
44800-128-S	Sink in Kindergarten Classroom 128	28.1	ppb	2.3	ppb
44800-128-SWB	Sink with Bubblers in Kindergarten Classroom 128	1.3	ppb		
44800-127-S	Sink in Kindergarten Classroom 127	4.6	ppb		
44800-127-SWB	Sink with Bubblers in Kindergarten Classroom 127	1.2	ppb		
44800-139H-S	Sink in Hallway outside of Library	2.2	ppb		
44800-139H-SWB	Sink with Bubblers in Hallway outside of Library	2.8	ppb		
44800-104-S	Sink in Clinic	2.1	ppb		
44800-104-SWB	Sink with Bubblers in Clinic	6.0	ppb		
44800-141-S	Sink in Library Workroom	4.1**	ppb		
44800-122-S	Sink in Teacher's Lounge	0.4	ppb		
44800-47H-S1	Sink in Hallway outside of Kitchen	2.1	ppb		
44800-47H-SWB1	Sink with Bubblers in Hallway outside of Kitchen	3.3	ppb		
44800-47H-S2	Sink in Hallway outside of Kitchen	2.2	ppb		
44800-47H-SWB2	Sink with Bubblers in Hallway outside of Kitchen	1.8	ppb		
44800-117-S1	Food Service Sink-Food Prep	3.4	ppb		
44800-117-S2	Food Service Sink-Food Prep	Fixture Removed			
44800-117-S3	Food Service Sink-Rinse	9.4*	ppb		
44800-117-S4	Food Service Sink-Wash	12.1*	ppb		
44800-117-S5	Food Service Sink-Hand Wash	2.0*	ppb		
44800-118-S	Sink in Classroom 118	0.3	ppb		
44800-118-SWB	Sink with Bubblers in Classroom 118	0.4	ppb		
44800-112-S	Sink in Classroom 112	7.1	ppb		
44800-112-SWB	Sink with Bubblers in Classroom 112	0.4	ppb		
44800-114-S	Sink in Classroom 114	0.7	ppb		
44800-126H-S	Sink in Hallway across from Classroom 112	1.8	ppb		
44800-126H-SWB	Sink with Bubblers in Hallway across from Classroom 112	1.4	ppb		
44800-113-S	Sink in Classroom 113	0.8	ppb		
44800-129H-S	Sink in Hallway across from Classroom 106	2.6	ppb		
44800-129H-SWB	Sink with Bubblers in Hallway across from Classroom 106	3.1	ppb		
44800-103-S1	Art Room Sink	13.4*	ppb		
44800-103-S2	Art Room Sink	6.3*	ppb		
44800-101H-DF	Hallway Drinking Fountain across from Counselor Office	2.1	ppb		
44800-101-H-WBFS	Water Bottle Filling Station across from Counselor Office	2.1	ppb		
*Sampled on 7/6/16					
** Results from 8/9/16 after elevated fixture was repaired or removed and replaced.					
*** Results from 7/10/20 after elevated fixture was repaired or removed and replaced.					
† Sampled as part of Jeffco's ongoing 5 year sampling program.					