

West Woods Elementary School		Sampled 7/1/20 [†]		Resampled 78/7/20 ^{***}	
CustomerSampleNumber	Description	Lead Result	Units	Lead Result	Units
47700-160-S	Sink in Clinic	1.4	ppb		
47700-163-S	Sink in Teachers' Lounge	0.8	ppb		
47700-214-S	Sink in Classroom 214	1.5	ppb		
47700-214-SWB	Sink with Bubblers in Classroom 214	0.3	ppb		
47700-207H-DF	Hallway Drinking Fountain across from Classroom 214	<0.1**	ppb		
47700-213-S	Sink in Classroom 213	18.7	ppb	1.5	ppb
47700-213-SWB	Sink with Bubblers in Classroom 213	0.2	ppb		
47700-212-S	Sink in Classroom 212	15.7	ppb	1.1	ppb
47700-212-SWB	Sink with Bubblers in Classroom 212	0.3	ppb		
47700-201-S	Sink in Classroom 201	15.6	ppb	0.8	ppb
47700-201-SWB	Sink with Bubblers in Classroom 201	0.1	ppb		
47700-200-S	Sink in Classroom 200	11.6	ppb		
47700-200-SWB	Sink with Bubblers in Classroom 200	0.1	ppb		
47700-199-S	Sink in Classroom 199	9.3	ppb		
47700-199-SWB	Sink with Bubblers in Classroom 199	<0.1**	ppb		
47700-197-S	Sink in Classroom 197	0.5	ppb		
47700-197-SWB	Sink with Bubblers in Classroom 197	<0.1**	ppb		
47700-196-S	Sink in Classroom 196	10.5	ppb		
47700-196-SWB	Sink with Bubblers in Classroom 196	0.4	ppb		
47700-190H-DF	Hallway Drinking Fountain across from Classroom 196	<0.1**	ppb		
47700-195-S	Sink in Classroom 195	10.3	ppb		
47700-195-SWB	Sink with Bubblers in Classroom 195	0.1	ppb		
47700-185-S	Sink in Classroom 185	12.1	ppb		
47700-185-SWB	Sink with Bubblers in Classroom 185	0.1	ppb		
47700-184-S	Sink in Classroom 184	6.5	ppb		
47700-184-SWB	Sink with Bubblers in Classroom 184	0.2	ppb		
47700-183-S	Sink in Classroom 183	11.8	ppb		
47700-183-SWB	Sink with Bubblers in Classroom 183	<0.1**	ppb		
47700-178-S1	Food Service Sink - Hand Sink	1.4*	ppb		
47700-178-S2	Food Service Sink - Rinse/Sanitize	1.6*	ppb		
47700-178-S3	Food Service Sink - Wash/Rinse	1.0*	ppb		
47700-178-S4	Food Service Sink - Sprayer	3.3*	ppb		
47700-178-S5	Food Service Sink - Food Prep Sink	6.0	ppb		
47700-178-S6	Food Service Sink - Food Prep Sink	2.0	ppb		
47700-174-S1	Food Service Sink - Hand Sink	5.8	ppb		
47700-174-S2	Food Service Sink - Spayer	0.3	ppb		
47700-146-S	Sink in Library Workroom	2.6	ppb		
47700-157H-DF	Hallway Drinking Fountain near Music Room	0.1	ppb		
47700-157H-WBFS	Hallway Water Bottle Filling Station near Music Room	0.1	ppb		
47700-135-S	Sink in Music Room	0.4	ppb		
47700-135-SWB	Sink With Bubblers in Music Room	1.7	ppb		
47700-151-S1	Sink in Art Room 151	1.3*	ppb		
47700-151-S2	Sink in Art Room 151	1.2*	ppb		
47700-101-S	Sink in Classroom 101	12.1	ppb		
47700-101-SWB	Sink with Bubblers in Classroom 101	0.1	ppb		
47700-102-S	Sink in Classroom 102	6.3	ppb		
47700-102-SWB	Sink with Bubblers in Classroom 102	1.1	ppb		
47700-107H-DF	Hallway Drinking Fountain Across from Classroom 103	0.5	ppb		
47700-103-S	Sink in Classroom 103	760.0	ppb	3.6	ppb
47700-103-SWB	Sink with Bubblers in Classroom 103	0.6	ppb		
47700-104-S	Sink in Classroom 104	10.1	ppb		
47700-104-SWB	Sink with Bubblers in Classroom 104	0.1	ppb		
47700-113-S	Sink in Classroom 113	14.1	ppb		
47700-113-SWB	Sink with Bubblers in Classroom 113	0.2	ppb		
47700-114-S	Sink in Classroom 114	0.8	ppb		
47700-114-SWB	Sink with Bubblers in Classroom 114	0.2	ppb		
47700-116-S	Sink in Classroom 116	17.0	ppb	1.0	ppb
47700-116-SWB	Sink with Bubblers in Classroom 116	0.4	ppb		
47700-117-S	Sink in Classroom 117	8.9	ppb		

47700-117-SWB	Sink with Bubbler in Classroom 117	0.3	ppb
47700-122H-DF	Hallway Drinking Fountain across from Clsroom 117	0.2	ppb
47700-118-S	Sink in Classroom 118	10.5	ppb
47700-118-SWB	Sink with Bubbler in Classroom 118	0.1	ppb
47700-128-S	Sink in Classroom 128	9.8	ppb
47700-128-SWB	Sink with Bubbler in Classroom 128	0.2	ppb
47700-129-S	Sink in Classroom 129	0.5	ppb
47700-129-SWB	Sink with Bubbler in Classroom 129	0.2	ppb
47700-130-S	Sink in Classroom 130	0.7	ppb
47700-130-SWB	Sink with Bubbler in Classroom 130	0.3	ppb
47700-R1-104-DF	Drinking Fountain in TEMP R1-104	7.2	ppb
47700-R1-105-DF	Drinking Fountain in TEMP R1-105	11.4	ppb
47700-R1-109-DF	Drinking Fountain in TEMP R1-109	9.6	ppb
47700-R1-103-DF	Drinking Fountain in TEMP R1-103	6.7	ppb
47700-R1-143-DF	Drinking Fountain in TEMP R1-143	9.4	ppb
* Fixture sampled on 9/1/16.			
** This result is less than 0.1 ppb, which is the lowest level that can be reported by the lab.			
*** Resampling results after elevated fixture was removed and replaced.			
† Sampled as part of Jeffco's ongoing 5 year sampling program.			