

Facility Name:		Richmond Middle School							
Station ID Number:		SCH-20825							
		Testing Lead in Drinking Water							
Outlet Type:		BF: Bathroom Faucet	CF: Classroom Faucet	DF: Drinking Fountain	IM: Ice Machine	KF: Kitchen Faucet	NS: Nurse's Sink	O: Other	R: Refrigerator
Station ID	Outlet	Outlet	Floor	Location / Room Number	Sample Date	Sample Time	Sample Result	Notes	
20825	1	DF	G	Gym Hall Corridor 149 Bubbler	12/4/23	6:00	0.0012		
20825	2	CF	G	Rm 806 (011) Classroom Sink #2	12/4/23	6:01	0.001		
20825	3	CF	G	Rm 804 (017) Classroom Sink #1	12/4/23	6:02	0.001		
20825	4	CF	G	Rm 804 (017) Classroom Sink #2	12/4/23	6:03	0.001		
20825	5	O	G	Rm 804/806 (013) Prep Room Sin	12/4/23	6:04	0.001		
20825	6	DF	G	8th Gr Hall Corridor 007 Bubbler	12/4/23	6:05	0.001		
20825	7	CF	G	Rm 800 (031) Classroom Sink	12/4/23	6:06	0.001		
20825	8	CF	G	Rm 800 (028) Classroom Sink	12/4/23	6:07	0.001		
20825	9	DF	1	Music Hall Corridor 117 Bubbler	12/4/23	6:08	0.001		
20825	10	CF	1	Rm 715 (172) Classroom Sink #1	12/4/23	6:09	0.001	Living Arts	
20825	11	CF	1	Rm 715 (172) Classroom Sink #2	12/4/23	6:10	0.001	Living Arts	
20825	12	CF	1	Rm 715 (172) Classroom Sink #3	12/4/23	6:11	0.001	Living Arts	
20825	13	CF	1	Rm 715 (172) Classroom Sink #4	12/4/23	6:12	0.001	Living Arts	
20825	14	CF	1	Rm 715 (172) Classroom Sink #5	12/4/23	6:13	0.001	Living Arts	
20825	15	CF	1	Rm 715 (172) Classroom Sink #6	12/4/23	6:14	0.001	Living Arts	
20825	16	CF	1	Rm 713 (169) Classroom Sink #1	12/4/23	6:15	0.001	Art Room	
20825	17	CF	1	Rm 713 (169) Classroom Sink #2	12/4/23	6:16	0.001	Art Room	
20825	18	CF	1	Rm 713 (169) Classroom Sink #3	12/4/23	6:17	0.001	Art Room	
20825	19	CF	1	Rm 713 (169) Classroom Sink #4	12/4/23	6:18	0.001	Art Room	
20825	20	CF	1	Rm 713 (169) Classroom Sink #5	12/4/23	6:19	0.001	Art Room	
20825	21	CF	1	Rm 713 (169) Classroom Sink #6	12/4/23	6:20	0.001	Art Room	
20825	22	NS	1	Rm 71 (162) Nurse Sink #1	12/4/23	6:21	0.0102	Counter Sink	
20825	23	NS	1	Rm 71 (162) Nurse Sink #2	12/4/23	6:22	0.001	Hand Sink	
20825	24	NS	1	Rm 71 (162b) Nurse Sink #3	12/4/23	6:23	0.001	Hand Sink	
20825	25	O	1	Rm 73 (142) Staff Room Sink	12/4/23	6:24	0.001		
20825	26	CF	1	Rm 702 (135) Classroom Sink #1	12/4/23	6:25	0.001		
20825	27	CF	1	Rm 702 (135) Classroom Sink #2	12/4/23	6:26	0.001		
20825	28	O	1	Rm 702A (131) Prep Room Sink	12/4/23	6:27	0.001		
20825	29	CF	1	Rm 704 (129) Classroom Sink #1	12/4/23	6:28	0.001		
20825	30	CF	1	Rm 704 (129) Classroom Sink #2	12/4/23	6:29	0.001		
20825	31	DF	1	7th Gr Hall Corridor 125 Bubbler	12/4/23	6:30	0.001		
20825	32	O	1	Rm 729 (141A) Workroom Sink	12/4/23	6:31	0.001		
20825	33	DF	1	Hall Corridor 180 Bubbler	12/4/23	6:32	0.001		
20825	34	KF	1	Room 728a(145) Kitchen Sink #1	12/4/23	6:33	0.0012		
20825	35	KF	1	Room 728a(145) Kitchen Sink #2	12/4/23	6:34	0.001		
20825	36	KF	1	Room 728a(145) Kitchen Sink #3	12/4/23	6:35	0.001		
20825	37	O	2	Rm 604 (209) Staff Room Sink	12/4/23	6:36	0.001		
20825	38	CF	2	Rm 602 (219) Classroom Sink #1	12/4/23	6:37	0.001		
20825	39	CF	2	Rm 602 (219) Classroom Sink #2	12/4/23	6:38	0.001		