



**MILLER PACIFIC
ENGINEERING GROUP**

August 4, 2017
File: 1911.034altr.doc

Alameda Unified School District
2060 Challenger Drive
Alameda, California 94501

Attention: Chad Pimentel, Legal Counsel for AUSD

Re: Geotechnical Engineering Investigation
Evaluation of Liquefaction Risk and Liquefaction Induced Settlement Potential
Paden Elementary School Campus
444 Central Avenue
Alameda, California

Introduction

This letter summarizes our geotechnical investigation of the Paden Elementary School campus located at 444 Central Avenue in Alameda, California. The approximate site location is presented on Figure 1, Site Location Map. The purpose of our geotechnical investigation is to evaluate the site soil and groundwater conditions and to assess the liquefaction risk and liquefaction induced settlement potential across the school campus. Our scope includes exploring the subsurface conditions with four Cone Penetration Tests (CPTs), conducting engineering analyses to evaluate the liquefaction risk and liquefaction induced settlement potential, and presentation of our geotechnical conclusions in this letter report.

Site Description

The Paden Elementary School campus is located on the southerly side of Central Avenue, east of Ballena Boulevard, as shown on the Site Location Map, Figure 1. The existing campus consists of numerous permanent and portable buildings, paved driveways, parking areas, and play areas, and landscaping improvements, as shown on the Site Plan, Figure 2. The ground surface at the project site and the surrounding area is characterized by nearly level to slightly sloping terrain.

Regional Geology

The site is located within the Coast Range Geomorphic Province of California. The regional bedrock geology consists of complexly folded, faulted, sheared, and altered sedimentary, igneous, and metamorphic rock of the Franciscan Complex. Bedrock is characterized by a diverse assemblage of greenstone, sandstone, shale, chert, and melange, with lesser amounts of conglomerate, calc-silicate rock, schist and other metamorphic rocks.

The regional topography is characterized by northwest-southeast trending mountain ridges and intervening valleys that were formed by movement between the North American and the Pacific Plates. Continued deformation and erosion during the late Tertiary and Quaternary Age (the last several million years) formed the prominent coastal ridges and the inland depression that is now the San Francisco Bay. The more recent seismic activity within the Coast Range

Geomorphic Province is concentrated along the San Andreas Fault zone, a complex group of generally north to northwest trending faults.

Geologic mapping¹ indicates the site is located in an area underlain by artificial fill sands, as shown on Figure 3. These artificial (manmade) fills were placed over older dune sands and soft clay (Bay Mud).

Surface Conditions

The site is currently developed as an elementary school campus. The attached Site Plan, Figure 2, shows the locations of existing buildings, driveways, and play areas. Most of the ground surface immediately around the existing buildings consists of asphalt paved surfaces.

Seismicity

The San Francisco Bay Region is located in a seismically active area and the proposed improvements will therefore experience the effects of future earthquakes. Such earthquakes could occur on any of several active faults within the region. These faults are shown on the Active Fault Map, Figure 4.

Subsurface Exploration and Laboratory Testing

Miller Pacific Engineering Group explored the subsurface soil and groundwater conditions with four Cone Penetration Tests (CPTs) at the approximate locations shown on the Site Plan, Figure 2. The CPTs were conducted with truck-mounted equipment on April 12, 2017. The CPTs were extended to depths of about 32 feet to 60 feet below the ground surface. A schematic of the CPT apparatus is provided on Figure A-1 and a CPT Soil Interpretation Chart is provided on Figure A-2. CPT logs are shown on Figures A-3 through A-6.

Subsurface Conditions

The subsurface conditions are consistent with the mapped geology. Review of subsurface data collected from the CPTs conducted at the site indicate that the campus is generally underlain by approximately seven to ten feet of loose to medium-dense sandy fill. Beneath the fill, each CPT encountered predominantly medium-dense to dense silty sand and sandy silt extending to a depth of 50 feet or more.

Groundwater was measured at approximately eleven to twelve feet below the ground surface during our CPT investigations. It is anticipated that the groundwater level beneath the site is influenced by tidal activity in the nearby San Francisco Bay.

¹ Graymer, R. W., "Geologic Map and Map Database of the Oakland Metropolitan Area, Alameda, Contra Costa, and San Francisco Counties, California", 2000, USGS, MF-2342 Version 1.0., Scale 1:50,000.

Given the low site elevations and proximity to San Francisco Bay, the highest historic groundwater elevation is assumed to coincide with the ground surface.

Liquefaction Risk and Liquefaction Induced Settlement Potential

The project site lies within a California Seismic Hazard Zone of Required Investigation for Liquefaction, as mapped by CGS (2003).

Liquefaction refers to the sudden, temporary loss of soil shear strength during strong ground shaking. Liquefaction-related phenomena include liquefaction-induced settlement, flow failure, and lateral spreading. These phenomena can occur where there are saturated, loose, granular deposits. Recent advances in liquefaction studies indicate that liquefaction can occur in granular materials with a high fines content (35 to 50% clayey and silty materials that pass the #200 sieve) provided the fines exhibit a plasticity less than 7. Granular layers with a potential for liquefaction were observed during our subsurface exploration.

To evaluate soil liquefaction, the seismic energy from an earthquake is compared with the ability of the soil to resist pore pressure generation. The earthquake energy is termed the cyclic stress ratio (CSR) and is a function of the maximum credible earthquake peak ground acceleration (PGA) and depth. The soil resistance to liquefaction is based on the relative density, and the amount and plasticity of the fines (silts and clays). The relative density of cohesionless soil is correlated with Cone Penetration Test data measured in the field.

We analyzed the potential for liquefaction utilizing the CPT Liquefaction Assessment software program CLiq (2007, ver. 2.1.6.9), and the procedures outlined by Idriss and Boulanger (2014). The design seismic conditions consisted of a magnitude 7.3 earthquake producing a PGA of 0.54g, which corresponds to the PGA_M per ASCE 7-10 Section 11.8.3, and assuming groundwater at the ground surface. The results of our liquefaction analyses are presented on Figures 5 through 8, and indicate granular soil layers observed between roughly one and nine feet, and discontinuous lenses between roughly 28 and 52 feet below the ground surface classify as liquefiable during the design seismic event. Therefore, we judge the risk of liquefaction at the site is high.

Potential liquefaction of sandy layers between one and nine feet below the ground surface may result in ground surface settlement of between roughly 0.5-inch to 1.5-inches, based on the liquefaction analyses discussed above, and as shown on Figures 5 through 8. Potential liquefaction induced differential ground surface settlement within a given building footprint area is estimated to be approximately one half of the total settlement (approximately 0.5 to 1.0-inches).


Alameda Unified School District
Page 4 of 4

August 4, 2017

Based on procedures outlined by Idriss and Boulanger, 2014, the discontinuous and relatively thin layers of potentially liquefiable soil observed 28-feet to 52-feet below the ground surface in the CPT's may experience 0.5-inch to 1.0-inch of post-liquefaction settlement. However, because there is a significant non-liquefiable soil "cap" overlying these deeper potentially liquefiable soil layers, we utilized the procedures outlined by Youd and Garris (1995) to determine if post-liquefaction settlement will be manifested in the form of ground surface settlement. As shown on Figure 9, based on the relative thicknesses of the non-liquefiable "cap" and the liquefiable layers, post-liquefaction settlements are not expected to result in ground surface settlement from the potentially liquefiable layers located below a depth of 28-feet.


If you have any questions, or if we can be of further assistance, please call us at your convenience.

Yours very truly,
MILLER PACIFIC ENGINEERING GROUP



Daniel S. Caldwell
Geotechnical Engineer #2006
(Expires 9/30/17)

Attachments: Figures 1 through 9, A-1 through A-6



SITE: LATITUDE, 37.7710°
LONGITUDE, -122.2836°

SITE LOCATION
N.T.S.



REFERENCE: Google Earth, 2017



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

SITE LOCATION MAP


Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034

Date: 4/3/2017

Drawn
MMT
Checked

1
FIGURE



SITE PLAN

SCALE

0 25 50 100 FEET



 Approximate CPT location completed by MPEG, 2017.

REFERENCE: Site Plan Provided by QKA



MILLER PACIFIC **ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

SITE PLAN

Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034

Date: 4/3/2017

Drawn **MMT**
Checked

2
FIGURE



REGIONAL GEOLOGIC MAP
(NOT TO SCALE)



LEGEND

af

ARTIFICIAL FILL (HOLOCENE)

Man made deposit of various materials and ages. Some are compacted and quite firm, but fills made before 1865 are nearly everywhere not compacted and consist simply of dumped materials.

Qds

DUNE SAND (HOLOCENE AND PLEISTOCENE)

Fine-grained, very well sorted, well-drained, eolian deposits. They occur mainly in large sheets, as well as many small hills, most displaying Barchan morphology. Dunes display as much as 30 m of erosional relief and are presently being buried by basin deposits (Qhb) and bay mud (Qhbm). They probably began accumulating after the last interglacial high stand of sea level began to recede about 71 ka, continued to form when sea level dropped to its Wisconsin minimum about 18 ka, and probably ceased to accumulate after sea level reached its present elevation (about 6 ka). Atwater (1982) recognized buried paleosols in the dunes, indicating periods of nondeposition

REFERENCE: Graymer, R.W. (2000), "Geologic Map of the Oakland Metropolitan Area, Alameda, Contra Costa, and San Francisco Counties, California", United States Geological Survey Miscellaneous Field Studies Map MF-2342, Version 1.0, Map Scale 1:50,000.



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

REGIONAL GEOLOGIC MAP

Paden Elementary School
444 Central Avenue
Alameda, California


Project No. 1911.034

Date: 4/25/2017

Drawn
MMT
Checked

3

FIGURE



DATA SOURCE:

1) U.S. Geological Survey, U.S. Department of the Interior, "Earthquake Outlook for the San Francisco Bay Region 2014-2043", Map of Known Active Faults in the San Francisco Bay Region, Fact Sheet 2016-3020, Revised August 2016 (ver. 1.1).



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

ACTIVE FAULT MAP
Paden Elementary School
444 Central Avenue
Alameda, California
Project No. 1911.034 Date: 4/25/2017

Drawn
MMT
Checked

4
FIGURE



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT-1 LIQUEFACTION ANALYSIS

Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034

Date: 4/25/2017


Drawn
MMT
Checked

5
FIGURE

This software is licensed to: Miller Pacific Engineering Group

CPT name: CPT-01

Liquefaction analysis overall plot




Input parameters and analysis data

Analysis method: BS1 (2014)
Fines correction method:
Points to test:
Earthquake magnitude M_w : 7.30
Peak ground acceleration: 0.54
Depth to water table (in situ): 0.00 ft

Depth to GWT (erthq.): 0.00 ft
Average results interval: 3 ft
Ic cutoff value: 2.60
Unit weight calculation: Based on SBT
Use fill: No
Fill height: N/A

Fill weight: N/A
Transition detect. applied: Yes
 K_0 applied: Yes
Clay like behavior applied: Sands only
Limit depth applied: No
Limit depth: N/A

CLiq v.2.1.6.9 - CPT Liquefaction Assessment Software - Report created on: 4/19/2017, 11:26:58 AM
Project file: H:\Jobs\1906-1999\1911.034 Paden ES Classrooms\Analyses\1911.034 CPT\lqclq.clq



Input parameters and analysis data		Output parameters	
Analysis method:	B81 (2014)	Depth to GWT (erthq.):	0.00 ft
Fines correction method:	B81 (2014)	Average results interval:	3
Points to test:	Based on Ic value	Ic cut-off value:	2.60
Earthquake magnitude M_w :	7.30	Unit weight calculation:	Based on SBT
Peak ground acceleration:	0.55 g	Use fill:	No
Depth to water table (in situ):	0.00 ft	Fill height:	N/A

CLiq v.2.1.6.9 - CPT Liquefaction Assessment Software - Report created on: 4/19/2017, 11:26:59 AM
Project file: H:\Jobs\1900-1999\1911.034 Paden ES Classrooms\Analyses\1911.034-CPTLiq.clq



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg


504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT-2 LIQUEFACTION ANALYSIS

Paden Elementary School
444 Central Avenue
Alameda, California
Project No. 1911.034 Date: 4/25/2017

Drawn
MMT
Checked

6
FIGURE



Input parameters and analysis data

LPI color scheme

- Very high risk (Red)
- High risk (Orange)
- Low risk (Yellow/Green)
- Unlike to liquefy (Light Green)
- Almost certain it will not liquefy (Dark Green)

FS - color scheme

- Almost certain it will liquefy (Red)
- Very likely to liquefy (Orange)
- Liquefaction and no liqu. are equally likely (Yellow)
- Unlike to liquefy (Light Green)
- Almost certain it will not liquefy (Dark Green)



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com


CPT-3 LIQUEFACTION ANALYSIS

Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034 Date: 4/25/2017

Drawn
MMT
Checked

7
FIGURE

Liquefaction analysis overall plot**Input parameters and analysis data**

Analysis method:	B8I (2014)	Depth to GWT (erthiq):	0.00 ft	Fill weight:	N/A
Fines correction method:	B8I (2014)	Average results interval:	3	Transition detect. applied:	Yes
Points to test:	Based on Ic value	Ic cut-off value:	2.60	K _c applied:	Yes
Earthquake magnitude M _w :	7.30	Unit weight calculation:	Based on SBT	Clay like behavior applied:	Sands only
Peak ground acceleration:	0.54	No	No	Limit depth applied:	No
Depth to water table (insteq):	0.00 ft	Use fill:	N/A	Limit depth:	N/A

CLiq v.2.1.6.9 - CPT Liquefaction Assessment Software - Report created on: 4/19/2017, 11:27:00 AM
Project file: H:\Jobs\1900-1999\1911.034 Paden ES Classrooms\Analyses\1911.034-CPTLiq.clq



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT-4 LIQUEFACTION ANALYSIS


Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034 Date: 4/25/2017

Drawn
MMT
Checked

8
FIGURE

Liquefaction-Induced Ground-Surface Distribution
(Youd and Garris, 1995)



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 Figures.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

LIQUEFACTION ANALYSIS - SURFACE EFFECTS

Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034


Drawn
MMT
Checked

Date: 4/25/2017

9

FIGURE

APPENDIX A



CONE PENETROMETER

(NO SCALE)



**MILLER PACIFIC
ENGINEERING GROUP**


A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 CPT.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CONE PENETROMETER
Paden Elementary School
444 Central Avenue
Alameda, California
Project No. 1911.034 Date: 4/7/17

Drawn
MMT
Checked

A-1
FIGURE



Zone: Q_c/N Soil Behavior Type:

1)	2	Sensitive Fine Grained
2)	1	Organic Material
3)	1	Clay
4)	1.5	Silty Clay to Clay
5)	2	Clayey Silt to Silty Clay
6)	2.5	Sandy Silt to Clayey Silt
7)	3	Silty Sand to Sandy Silt
8)	4	Sand to Silty Sand
9)	5	Sand
10)	6	Gravelly Sand to Sand
11)	1	Very Stiff Fine Grained (*)
12)	2	Sand to Clayey Sand (*)

(*) Overconsolidated or Cemented

Reference: Robertson, P.K. (1986), "In-Situ Testing and Its Application to Geotechnical Engineering," Canadian Geotechnical Journal, Vol. 23; No. 23; No. 4, pp. 573-594



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 CPT.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT SOIL INTERPRETATION CHART

Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034

Drawn
MMT
Checked

Date: 4/7/17

A-2
FIGURE

Miller Pacific Engineering



Project
Job Number
Hole Number
EST GW Depth During Test


Paden Elementary School
1911.034
CPT-01
10.70 ft

File Name
GPS
Maximum Depth

SDF037.cpt
RB KK
DDG1379
4/12/2017 2:48:11 PM
56.92 ft

Net Area Ratio .8

CPT DATA



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 CPT.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT-1 PLOT
Paden Elementary School
444 Central Avenue
Alameda, California
Project No. 1911.034 Date: 4/7/17

Drawn
MMT
Checked

A-3
FIGURE

Miller Pacific Engineering



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 CPT.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT-2 PLOT

Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034

Date: 4/7/17


Drawn
MMT
Checked

A-4
FIGURE

Project Job Number	Paden Elementary School	Operator Cone Number	RB KK
Hole Number	1911.034	Date and Time	DDG1379
EST GW Depth During Test	CPT-02	4/12/2017 12:58:34 PM	
11.00 ft		Maximum Depth	31.82 ft

Net Area Ratio .8

CPT DATA



S*Soil behavior type and SPT based on data from UBC-1983

Miller Pacific Engineering




Project Number: Paden Elementary School
Job Number: 1911.034
Hole Number: CPT-03
EST GW Depth During Test: 11.90 ft

File Name: SDF(034).cpt
GPS: RB KK
Maximum Depth: DDG/379
Date and Time: 4/12/2017 11:32:24 AM
Depth: 60.69 ft

Net Area Ratio .8

CPT DATA



MILLER PACIFIC
ENGINEERING GROUP

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 CPT.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT-3 PLOT
Paden Elementary School
444 Central Avenue
Alameda, California
Project No. 1911.034 Date: 4/7/17

Drawn _____
MMT _____
Checked _____

A-5
FIGURE

Miller Pacific Engineering



**MILLER PACIFIC
ENGINEERING GROUP**

A CALIFORNIA CORPORATION, © 2017, ALL RIGHTS RESERVED
FILENAME: 1911.034 CPT.dwg

504 Redwood Blvd.
Suite 220
Novato, CA 94947
T 415 / 382-3444
F 415 / 382-3450
www.millerpac.com

CPT-4 PLOT

Paden Elementary School
444 Central Avenue
Alameda, California

Project No. 1911.034

Date: 4/7/17


Drawn
MMT
Checked

A-6
FIGURE

Project Job Number	Paden Elementary School	Operator Cone Number	RB KK
Hole Number	1911.034	Date and Time	DDG1379
EST GW Depth During Test	CPT-04		4/12/2017 1:36:02 PM
	11.00 ft		

Net Area Ratio .8

CPT DATA



- 7 - silty sand to sandy silt
- 10 - gravelly sand to sand
- 8 - sand to silty sand
- 11 - very stiff fine grained (*)
- 9 - sand
- 4 - silty clay to clay
- 5 - clayey silt to silty clay
- 6 - sandy silt to clayey silt
- 2 - organic material
- 3 - clay

*Soil behavior type and SPT based on data from UBC-1983