Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6321040

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321040-01	**Sample Name:** Dishwasher sink **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	01/19/17 16:38
6321040-02	**Sample Name:** Prep sink 1 **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	01/19/17 16:38
6321040-03	**Sample Name:** Prep sink 2 **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	9.9	ppb	2.0	20 ppb	01/19/17 16:38
6321040-04	**Sample Name:** Staff RR f **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-05	**Sample Name:** Gym RR boy 1 **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-06	**Sample Name:** Gym RR boy 2 **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-07	**Sample Name:** PE off **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-08	**Sample Name:** Gym RR girl 1 **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-09	**Sample Name:** Gym RR girl 2 **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-10	**Sample Name:** Staff Kit **Sampled:** 11/16/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6321040

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321040-11	**Sample Name:** Gym Fountain 1 **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-12	**Sample Name:** Gym Fountain 2 **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-13	**Sample Name:** Staff RR girl F **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-14	**Sample Name:** Staff RR boy F **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-15	**Sample Name:** Learning ctr boy RR 1 **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-16	**Sample Name:** Learning ctr boy RR 2 **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-17	**Sample Name:** Learning ctr F **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	01/19/17 16:38
6321040-18	**Sample Name:** Learning ctr B **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/19/17 16:38
6321040-19	**Sample Name:** Room 101 F **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	01/19/17 16:38
6321040-20	**Sample Name:** Room 101 B **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	01/19/17 16:38

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6321040

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321040-21	**Sample Name:** Rm 102 F **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-22	**Sample Name:** Rm 102 B **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	01/19/17 16:38
6321040-23	**Sample Name:** Rm 103 F **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	01/19/17 16:38
6321040-24	**Sample Name:** Rm 103 B **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	01/19/17 16:38
6321040-25	**Sample Name:** Rm 104 F **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.7	ppb	2.0	20 ppb	01/19/17 16:38
6321040-26	**Sample Name:** Rm 104 B **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/19/17 16:38
6321040-27	**Sample Name:** Learning ctr girls RR 1 **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-28	**Sample Name:** Learning ctr girls RR 2 **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-29	**Sample Name:** Learning ctr Staff F **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-30	**Sample Name:** Rm 113 Boys RR 1 **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6321040

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321040-31	**Sample Name:** Rm 113 Boys RR 2 **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/19/17 16:38
6321040-32	**Sample Name:** Room 113 F **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	01/19/17 16:38
6321040-33	**Sample Name:** Room 113 B **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/19/17 16:38
6321040-34	**Sample Name:** Room 112 F **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	01/19/17 16:38
6321040-35	**Sample Name:** Room 112 B **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/19/17 16:38
6321040-36	**Sample Name:** Room 111 F **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	01/20/17 16:36
6321040-37	**Sample Name:** Room 111 B **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	01/20/17 16:36
6321040-38	**Sample Name:** Room 110 F **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.8	ppb	2.0	20 ppb	01/20/17 16:36
6321040-39	**Sample Name:** Room 110 B **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	01/20/17 16:36
6321040-40	**Sample Name:** Room 109 F **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.4	ppb	2.0	20 ppb	01/20/17 16:36

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6321040

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321040-41	**Sample Name:** Room 109 B **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	01/20/17 16:36
6321040-42	**Sample Name:** RR 109 girls 1 **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6321040-43	**Sample Name:** RR 109 girls 2 **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	01/20/17 16:36
6321040-44	**Sample Name:** Room 108 F **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/20/17 16:36
6321040-45	**Sample Name:** Room 108 B **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/20/17 16:36
6321040-46	**Sample Name:** Room 107 F **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	01/20/17 16:36
6321040-47	**Sample Name:** Room 107 B **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/20/17 16:36
6321040-48	**Sample Name:** RR 108 Boys 1 **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6321040-49	**Sample Name:** RR 108 Boys 2 **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6321040-50	**Sample Name:** Room 106 F **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.4	ppb	2.0	20 ppb	01/20/17 16:36

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/23/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6321040

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321040-51	**Sample Name:** Room 106 B **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	01/20/17 16:36
6321040-52	**Sample Name:** Room 105 F **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	01/20/17 16:36
6321040-53	**Sample Name:** Room 105 B **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	01/20/17 16:36
6321040-54	**Sample Name:** RR 105 girls 1 **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	01/20/17 16:36
6321040-55	**Sample Name:** RR 105 girls 2 **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6321040-56	**Sample Name:** RR 105 Staff **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	01/20/17 16:36

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: Carrie Seidl for AGG
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/24/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6321052

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321052-01	**Sample Name:** Room 200 sink **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	01/23/17 16:46
6321052-02	**Sample Name:** Room 200 Bubbler **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/23/17 16:46
6321052-03	**Sample Name:** 201 sink **Sampled:** 11/16/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	01/23/17 16:46
6321052-04	**Sample Name:** 201 BB **Sampled:** 11/16/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/23/17 16:46
6321052-05	**Sample Name:** 203 sink **Sampled:** 11/16/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/23/17 16:46
6321052-06	**Sample Name:** 203 BB **Sampled:** 11/16/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	01/23/17 16:46
6321052-07	**Sample Name:** 204 sink **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/23/17 16:46
6321052-08	**Sample Name:** 204 BB **Sampled:** 11/16/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	01/23/17 16:46
6321052-09	**Sample Name:** 200 pod GRR 1 **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-10	**Sample Name:** 200 pod GRR 2 **Sampled:** 11/16/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/24/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6321052

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321052-11	**Sample Name:** Mtz MR BB **Sampled:** 11/16/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	01/23/17 16:46
6321052-12	**Sample Name:** Mtz MR sink **Sampled:** 11/16/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-13	**Sample Name:** Mtz WR sink **Sampled:** 11/16/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.0	ppb	2.0	20 ppb	01/23/17 16:46
6321052-14	**Sample Name:** Mtz HR sink **Sampled:** 11/16/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-15	**Sample Name:** Mtz HR RR sink **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-16	**Sample Name:** Mtz Lib **Sampled:** 11/16/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	01/23/17 16:46
6321052-17	**Sample Name:** Mtz 200 pod boys RR 1 **Sampled:** 11/16/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-18	**Sample Name:** Mtz 200 pod boys RR 2 **Sampled:** 11/16/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-19	**Sample Name:** 200 WF 1 **Sampled:** 11/16/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-20	**Sample Name:** 200 WF 2 **Sampled:** 11/16/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/24/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6321052

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321052-21	**Sample Name:** Upper staff RR **Sampled:** 11/16/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-22	**Sample Name:** 210 pod BRR 1 **Sampled:** 11/16/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-23	**Sample Name:** 210 pod BRR 2 **Sampled:** 11/16/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-24	**Sample Name:** 213 sink **Sampled:** 11/16/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	01/23/17 16:46
6321052-25	**Sample Name:** 213 BB **Sampled:** 11/16/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	01/23/17 16:46
6321052-26	**Sample Name:** 212 sink **Sampled:** 11/16/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	01/23/17 16:46
6321052-27	**Sample Name:** 212 BB **Sampled:** 11/16/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	01/23/17 16:46
6321052-28	**Sample Name:** 211 sink **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.2	ppb	2.0	20 ppb	01/23/17 16:46
6321052-29	**Sample Name:** 211 BB **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/23/17 16:46
6321052-30	**Sample Name:** 210 sink **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/24/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6321052

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321052-31	**Sample Name:** 210 BB **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-32	**Sample Name:** 209 sink **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	01/23/17 16:46
6321052-33	**Sample Name:** 209 BB **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-34	**Sample Name:** 210 pod WF1 **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-35	**Sample Name:** 210 pod WF2 **Sampled:** 11/16/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-36	**Sample Name:** 210 pod GRR1 **Sampled:** 11/16/16 5:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-37	**Sample Name:** 210 pod GRR2 **Sampled:** 11/16/16 5:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-38	**Sample Name:** 205 pod GRR1 **Sampled:** 11/16/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-39	**Sample Name:** 205 pod GRR2 **Sampled:** 11/16/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-40	**Sample Name:** 205 pod BRR1 **Sampled:** 11/16/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/24/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6321052

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6321052-41	**Sample Name:** 205 pod BRR2 **Sampled:** 11/16/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/23/17 16:46
6321052-42	**Sample Name:** 205 sink **Sampled:** 11/16/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	01/23/17 16:46
6321052-43	**Sample Name:** 205 BB **Sampled:** 11/16/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	01/23/17 16:46
6321052-44	**Sample Name:** 206 sink **Sampled:** 11/16/16 6:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	01/23/17 16:46
6321052-45	**Sample Name:** 206 BB **Sampled:** 11/16/16 6:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/23/17 16:46
6321052-46	**Sample Name:** 207 sink **Sampled:** 11/16/16 6:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	01/23/17 16:46
6321052-47	**Sample Name:** 207 BB **Sampled:** 11/16/16 6:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	01/23/17 16:46
6321052-48	**Sample Name:** 208 sink **Sampled:** 11/16/16 6:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	01/23/17 16:46
6321052-49	**Sample Name:** 208 BB **Sampled:** 11/16/16 6:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	01/23/17 16:46

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/24/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6321052

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Metzger

Lab Number

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: Carrie Seidl for AGG
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.