Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-01	**Sample Name:** Staff lav - workroom **Sampled:** 10/26/16 4:49						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-02	**Sample Name:** Staff lav - lounge **Sampled:** 10/26/16 4:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-03	**Sample Name:** Health Rm **Sampled:** 10/26/16 4:52						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-04	**Sample Name:** Health Rm Bathroom **Sampled:** 10/26/16 4:52						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-05	**Sample Name:** Library Office **Sampled:** 10/26/16 4:53						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	12/05/16 17:23
6301016-06	**Sample Name:** Boys Left by Gym **Sampled:** 10/26/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-07	**Sample Name:** Boys Right by Gym **Sampled:** 10/26/16 5:01						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-08	**Sample Name:** Girls Left by Gym **Sampled:** 10/26/16 5:01						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-09	**Sample Name:** Girls Right by Gym **Sampled:** 10/26/16 5:01						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-10	**Sample Name:** Gym Hall fountain high **Sampled:** 10/26/16 5:02						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-11	**Sample Name:** Gym Hall fountain low **Sampled:** 10/26/16 5:03						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-12	**Sample Name:** Gym Restroom **Sampled:** 10/26/16 5:03						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-13	**Sample Name:** Kitchen handsink west **Sampled:** 10/26/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-14	**Sample Name:** Kitchen rinse sink left **Sampled:** 10/26/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/02/16 15:50
6301016-15	**Sample Name:** Kitchen rinse sink right **Sampled:** 10/26/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	12/02/16 15:50
6301016-16	**Sample Name:** Kitchen Prerinse dishwasher **Sampled:** 10/26/16 5:18						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-17	**Sample Name:** rm 114 restroom **Sampled:** 10/26/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-18	**Sample Name:** rm 114 sink **Sampled:** 10/26/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-19	**Sample Name:** rm 114 bubbler **Sampled:** 10/26/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/02/16 15:50
6301016-20	**Sample Name:** Pod 1 boys right **Sampled:** 10/26/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-21	**Sample Name:** Pod 1 boys left **Sampled:** 10/26/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/02/16 15:50
6301016-22	**Sample Name:** Room 113 sink **Sampled:** 10/26/16 5:21						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-23	**Sample Name:** Room 113 bubbler **Sampled:** 10/26/16 5:21						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-24	**Sample Name:** Pod 1 common sink left **Sampled:** 10/26/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**40.2**	ppb	4.0	20 ppb	12/05/16 17:23 **MCLE**
6301016-25	**Sample Name:** Pod 1 common bubbler **Sampled:** 10/26/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.5	ppb	2.0	20 ppb	12/05/16 17:23
6301016-26	**Sample Name:** Pod 1 common sink right **Sampled:** 10/26/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	16.0	ppb	2.0	20 ppb	12/05/16 17:23
6301016-27	**Sample Name:** Pod 1 Rm 112 sink **Sampled:** 10/26/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-28	**Sample Name:** Pod 1 Rm 112 bubbler **Sampled:** 10/26/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-29	**Sample Name:** Pod 1 Rm 111 sink **Sampled:** 10/26/16 5:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-30	**Sample Name:** Pod 1 Rm 111 bubbler **Sampled:** 10/26/16 5:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-31	**Sample Name:** Room 110 sink **Sampled:** 10/26/16 5:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-32	**Sample Name:** Room 110 bubbler **Sampled:** 10/26/16 5:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.1	ppb	2.0	20 ppb	12/05/16 17:23
6301016-33	**Sample Name:** Pod 1 girls left **Sampled:** 10/26/16 5:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-34	**Sample Name:** Pod 1 girls right **Sampled:** 10/26/16 5:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-35	**Sample Name:** Pod 2 girls left **Sampled:** 10/26/16 5:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-36	**Sample Name:** Pod 2 girls right **Sampled:** 10/26/16 5:33						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-37	**Sample Name:** 1st floor staff Pod 2 **Sampled:** 10/26/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-38	**Sample Name:** Rm 105 sink **Sampled:** 10/26/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/05/16 17:23
6301016-39	**Sample Name:** Rm 105 Bubbler **Sampled:** 10/26/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-40	**Sample Name:** Pod 2 common sink left **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	15.8	ppb	2.0	20 ppb	12/05/16 17:23

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-41	**Sample Name:** rm 103 sink **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	12/05/16 17:23
6301016-42	**Sample Name:** rm 103 bubbler **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	12/05/16 17:23
6301016-43	**Sample Name:** rm 102 sink **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/05/16 17:23
6301016-44	**Sample Name:** rm 102 bubbler **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-45	**Sample Name:** rm 101 sink **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8.8	ppb	2.0	20 ppb	12/05/16 17:23
6301016-47	**Sample Name:** Pod 2 common sink right **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.0	ppb	2.0	20 ppb	12/05/16 17:23
6301016-48	**Sample Name:** Pod 2 common sink bubbler **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-49	**Sample Name:** Pod 2 Boys left **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-50	**Sample Name:** Pod 2 Boys right **Sampled:** 10/26/16 5:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-51	**Sample Name:** Pod 3 - common sink left **Sampled:** 10/26/16 6:02						**Matrix:** Water
†*Lead*	1030	EPA 200.9	9.5	ppb	2.0	20 ppb	12/05/16 17:23

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-52	**Sample Name:** Pod 3 girls **Sampled:** 10/26/16 6:04						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-53	**Sample Name:** Pod 3 boys **Sampled:** 10/26/16 6:04						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-54	**Sample Name:** Pod 3 common sink right **Sampled:** 10/26/16 6:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.4	ppb	2.0	20 ppb	12/05/16 17:23
6301016-55	**Sample Name:** Pod 3 bubbler **Sampled:** 10/26/16 6:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-56	**Sample Name:** rm 109 sink **Sampled:** 10/26/16 6:08						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-57	**Sample Name:** rm 109 bubbler **Sampled:** 10/26/16 6:08						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-58	**Sample Name:** rm 108 sink **Sampled:** 10/26/16 6:09						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-59	**Sample Name:** rm 108 bubbler **Sampled:** 10/26/16 6:09						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	12/05/16 17:23
6301016-60	**Sample Name:** room 107 sink **Sampled:** 10/26/16 6:13						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	12/05/16 17:23
6301016-61	**Sample Name:** room 107 bubbler **Sampled:** 10/26/16 6:13						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-62	**Sample Name:** room 106 sink **Sampled:** 10/26/16 6:14						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-63	**Sample Name:** room 106 bubbler **Sampled:** 10/26/16 6:14						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-64	**Sample Name:** Pod 3 staff **Sampled:** 10/26/16 6:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-65	**Sample Name:** room 204 sink **Sampled:** 10/26/16 6:23						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-66	**Sample Name:** room 204 bubbler **Sampled:** 10/26/16 6:23						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-67	**Sample Name:** Pod 4 boys left **Sampled:** 10/26/16 6:24						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-68	**Sample Name:** Pod 4 boys right **Sampled:** 10/26/16 6:24						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	12/05/16 17:23
6301016-69	**Sample Name:** Pod 4 sink right **Sampled:** 10/26/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	13.0	ppb	2.0	20 ppb	12/05/16 17:23
6301016-70	**Sample Name:** Pod 4 room 213 bubbler **Sampled:** 10/26/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	11/22/16 16:54
6301016-71	**Sample Name:** Pod 4 room 213 sink **Sampled:** 10/26/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	11/22/16 16:54

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-72	**Sample Name:** rm 212 sink **Sampled:** 10/26/16 6:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	11/22/16 16:54
6301016-73	**Sample Name:** rm 212 bubbler **Sampled:** 10/26/16 6:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-74	**Sample Name:** rm 211 sink **Sampled:** 10/26/16 6:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-75	**Sample Name:** rm 211 bubbler **Sampled:** 10/26/16 6:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-76	**Sample Name:** rm 210 sink **Sampled:** 10/26/16 6:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-77	**Sample Name:** rm 210 bubbler **Sampled:** 10/26/16 6:32						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	11/22/16 16:54
6301016-78	**Sample Name:** Pod 4 fountain lower **Sampled:** 10/26/16 6:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-79	**Sample Name:** Pod 4 fountain upper **Sampled:** 10/26/16 6:41						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-80	**Sample Name:** Pod 5 staff **Sampled:** 10/26/16 6:42						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-81	**Sample Name:** Pod 6 209 bubbler **Sampled:** 10/26/16 6:44						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-82	**Sample Name:** Pod 6 209 sink **Sampled:** 10/26/16 6:44						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-83	**Sample Name:** Pod 6 208 bubbler **Sampled:** 10/26/16 6:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-84	**Sample Name:** Pod 6 208 sink **Sampled:** 10/26/16 6:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-85	**Sample Name:** Pod 6 girls left **Sampled:** 10/26/16 6:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-86	**Sample Name:** Pod 6 sink right **Sampled:** 10/26/16 6:46						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	11/22/16 16:54
6301016-87	**Sample Name:** Pod 6 sink left **Sampled:** 10/26/16 6:47						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	11/22/16 16:54
6301016-88	**Sample Name:** Pod 6 boys **Sampled:** 10/26/16 6:48						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-89	**Sample Name:** Pod 6 sink right bubbler **Sampled:** 10/26/16 6:48						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-90	**Sample Name:** Pod 6 rm 205 sink **Sampled:** 10/26/16 6:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-91	**Sample Name:** Pod 6 rm 205 bubbler **Sampled:** 10/26/16 6:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301016-92	**Sample Name:** Pod 6 rm 206 sink **Sampled:** 10/26/16 6:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-93	**Sample Name:** Pod 6 rm 206 bubbler **Sampled:** 10/26/16 6:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-94	**Sample Name:** Pod 5 girls left **Sampled:** 10/26/16 6:52						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-95	**Sample Name:** Pod 5 girls right **Sampled:** 10/26/16 6:52						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-96	**Sample Name:** Pod 5 room 205 bubbler **Sampled:** 10/26/16 6:54						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-97	**Sample Name:** Pod 5 room 205 sink **Sampled:** 10/26/16 6:54						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301016-98	**Sample Name:** Pod 5 room 204 sink **Sampled:** 10/26/16 6:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301017-01	**Sample Name:** room 204 Pod 5 bubbler **Sampled:** 10/26/16 6:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301017-02	**Sample Name:** room 203 Pod 5 bubbler **Sampled:** 10/26/16 6:56						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301017-03	**Sample Name:** room 203 Pod 5 sink **Sampled:** 10/26/16 6:56						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301017-04	**Sample Name:** room 202 Pod 5 sink **Sampled:** 10/26/16 6:58						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.2	ppb	2.0	20 ppb	11/22/16 16:54
6301017-05	**Sample Name:** room 202 Pod 5 bubbler **Sampled:** 10/26/16 6:58						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301017-06	**Sample Name:** room 201 Pod 5 sink **Sampled:** 10/26/16 6:59						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301017-07	**Sample Name:** room 201 Pod 5 bubbler **Sampled:** 10/26/16 6:59						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/22/16 16:54
6301017-08	**Sample Name:** room 5 sink right **Sampled:** 10/26/16 7:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.9	ppb	2.0	20 ppb	11/22/16 16:54
6301017-09	**Sample Name:** room 5 low fountain **Sampled:** 10/26/16 7:01						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301017-10	**Sample Name:** room 5 high fountain **Sampled:** 10/26/16 7:01						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301017-11	**Sample Name:** Pod 5 boys right **Sampled:** 10/26/16 7:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301017-12	**Sample Name:** Pod 5 boys left **Sampled:** 10/26/16 7:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301017-13	**Sample Name:** Pod 4 Common sink left **Sampled:** 10/26/16 6:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.2	ppb	2.0	20 ppb	11/23/16 15:41

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/06/2016
Received: 10/26/2016
Sampled By: P. Wentz
Work Order: Multiple Work Orders

CLIENT

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: CFT

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6301017-14	**Sample Name:** Music **Sampled:** 10/26/16 4:59						**Matrix:** Water
†*Lead*	1030	EPA 200.9	15.1	ppb	2.0	20 ppb	11/23/16 15:41
6301017-15	**Sample Name:** Room 104 sink **Sampled:** 10/26/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41
6301017-16	**Sample Name:** Room 104 bubbler **Sampled:** 10/26/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/23/16 15:41

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.