Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/07/2017
Received: 11/16/2016
Sampled By: P Wentz
Work Order: 6323022

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: TUEL

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323022-01	**Sample Name:** health room faucet **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.4	ppb	2.0	20 ppb	02/06/17 16:11
6323022-02	**Sample Name:** health room bubbler **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	02/06/17 16:11
6323022-03	**Sample Name:** Jamie's office sink **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.0	ppb	2.0	20 ppb	02/06/17 16:11
6323022-04	**Sample Name:** office bathroom **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	02/06/17 16:11
6323022-05	**Sample Name:** cafeteria low fountain **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-06	**Sample Name:** cafeteria high fountain **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-07	**Sample Name:** kitchen hand wash west **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	02/06/17 16:11
6323022-08	**Sample Name:** kitchen food prep **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-09	**Sample Name:** kitchen dish sink **Sampled:** 11/15/16 4:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-10	**Sample Name:** kitchen bathroom **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.2	ppb	2.0	20 ppb	02/06/17 16:11

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/07/2017
Received: 11/16/2016
Sampled By: P Wentz
Work Order: 6323022

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: TUEL

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323022-11	**Sample Name:** rm 208 sink **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.8	ppb	2.0	20 ppb	02/06/17 16:11
6323022-12	**Sample Name:** rm 208 bubbler **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	02/06/17 16:11
6323022-13	**Sample Name:** rm 204 sink **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.8	ppb	2.0	20 ppb	02/06/17 16:11
6323022-14	**Sample Name:** rm 204 bubbler **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/06/17 16:11
6323022-15	**Sample Name:** rm 206 sink **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	02/06/17 16:11
6323022-16	**Sample Name:** rm 206 bubbler **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-17	**Sample Name:** rm 205 sink **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8.5	ppb	2.0	20 ppb	02/06/17 16:11
6323022-18	**Sample Name:** rm 205 bubbler **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	02/06/17 16:11
6323022-19	**Sample Name:** rm 202 sink **Sampled:** 11/15/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	02/06/17 16:11
6323022-20	**Sample Name:** rm 202 bubbler **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/07/2017
Received: 11/16/2016
Sampled By: P Wentz
Work Order: 6323022

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: TUEL

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323022-21	**Sample Name:** rm 203 sink **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	02/06/17 16:11
6323022-22	**Sample Name:** rm 203 bubbler **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-23	**Sample Name:** rm 200 sink **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	02/06/17 16:11
6323022-24	**Sample Name:** rm 200 bubbler **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-25	**Sample Name:** rm 201 sink **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	02/06/17 16:11
6323022-26	**Sample Name:** rm 201 bubbler **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-27	**Sample Name:** music sink **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	9.4	ppb	2.0	20 ppb	02/06/17 16:11
6323022-28	**Sample Name:** music bubbler **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323022-29	**Sample Name:** upper staff break **Sampled:** 11/15/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	02/06/17 16:11

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/07/2017
Received: 11/16/2016
Sampled By: P Wentz
Work Order: 6323022

CLIENT

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: TUEL

Lab Number

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/07/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6323021

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tualatin Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323021-01	**Sample Name:** Tuel 105 RR **Sampled:** 11/15/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	02/04/17 13:11
6323021-02	**Sample Name:** Tuel 105 **Sampled:** 11/15/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.9	ppb	2.0	20 ppb	02/06/17 16:11
6323021-03	**Sample Name:** Tuel 103 **Sampled:** 11/15/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323021-04	**Sample Name:** Tuel 103 BB **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323021-05	**Sample Name:** Tuel 101 **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	02/06/17 16:11
6323021-06	**Sample Name:** Tuel 101 BB **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323021-07	**Sample Name:** Tuel Salon 1 BB **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323021-08	**Sample Name:** Tuel Salon 1 **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.8	ppb	2.0	20 ppb	02/06/17 16:11
6323021-09	**Sample Name:** Tuel 100 BB **Sampled:** 11/15/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323021-10	**Sample Name:** Tuel 100 **Sampled:** 11/15/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	02/06/17 16:11

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/07/2017
Received: 11/16/2016
Sampled By: Dani Gavaza
Work Order: 6323021

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tualatin Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323021-11	**Sample Name:** Tuel 102 RR **Sampled:** 11/15/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/06/17 16:11
6323021-12	**Sample Name:** Tuel Stage **Sampled:** 11/15/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	02/06/17 16:11
6323021-13	**Sample Name:** Tuel Library **Sampled:** 11/15/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	10.3	ppb	2.0	20 ppb	02/06/17 16:11

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6323020

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tualatin Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323020-01	**Sample Name:** Rm 106 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	02/03/17 15:33
6323020-02	**Sample Name:** Rm 106 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6323020-03	**Sample Name:** Rm 107 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	02/03/17 15:33
6323020-04	**Sample Name:** Rm 107 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6323020-05	**Sample Name:** Rm 108 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	02/04/17 13:11
6323020-06	**Sample Name:** Rm 108 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11
6323020-07	**Sample Name:** Rm 109 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.4	ppb	2.0	20 ppb	02/04/17 13:11
6323020-08	**Sample Name:** Rm 109 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11
6323020-09	**Sample Name:** Rm 110 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	02/04/17 13:11
6323020-10	**Sample Name:** Rm 110 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6323020

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tualatin Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323020-11	**Sample Name:** Rm 111 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.7	ppb	2.0	20 ppb	02/04/17 13:11
6323020-12	**Sample Name:** Rm 111 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	02/04/17 13:11
6323020-13	**Sample Name:** Rm 210 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.1	ppb	2.0	20 ppb	02/04/17 13:11
6323020-14	**Sample Name:** Rm 210 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11
6323020-15	**Sample Name:** Rm 212 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8.1	ppb	2.0	20 ppb	02/04/17 13:11
6323020-16	**Sample Name:** Rm 212 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/04/17 13:11
6323020-17	**Sample Name:** Rm 209 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.6	ppb	2.0	20 ppb	02/04/17 13:11
6323020-18	**Sample Name:** Rm 209 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11
6323020-19	**Sample Name:** Rm 207 F **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	02/04/17 13:11
6323020-20	**Sample Name:** Rm 207 B **Sampled:** 11/15/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6323020

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tualatin Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323020-21	**Sample Name:** Rm 211 F **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.0	ppb	2.0	20 ppb	02/04/17 13:11
6323020-22	**Sample Name:** Rm 211 B **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11
6323020-23	**Sample Name:** Rm 214 F **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	02/04/17 13:11
6323020-24	**Sample Name:** Rm 214 B **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11
6323020-25	**Sample Name:** Rm 213 F **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.6	ppb	2.0	20 ppb	02/04/17 13:11
6323020-26	**Sample Name:** Rm 213 B **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	02/04/17 13:11
6323020-27	**Sample Name:** Rm 216 F **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.5	ppb	2.0	20 ppb	02/04/17 13:11
6323020-28	**Sample Name:** Rm 216 B **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/04/17 13:11
6323020-29	**Sample Name:** Rm 218 F **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.6	ppb	2.0	20 ppb	02/04/17 13:11
6323020-30	**Sample Name:** Rm 218 B **Sampled:** 11/15/16 5:25						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	02/04/17 13:11

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/16/2016
Sampled By: Lisa Cresap
Work Order: 6323020

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tualatin Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6323020-31	**Sample Name:** Art Rm F-1 **Sampled:** 11/15/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	02/04/17 13:11
6323020-32	**Sample Name:** Art Rm B **Sampled:** 11/15/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	02/04/17 13:11
6323020-33	**Sample Name:** Art Rm F-2 **Sampled:** 11/15/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.9	ppb	2.0	20 ppb	02/04/17 13:11

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.