

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 04/23/2015
Received: 04/16/2015
Sampled By: P. Wentz
Work Order: 5106022

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project: -
Project # : N/A
PWSID # : -

Sampling Location: TTSD
Sample Matrix: Water

Lab Number **Sample Name** **Sampled:** 4/16/15 16:15 **Sample Composition:**
5106022-01 **Fowler Rm 24**


Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
+Lead	1030	EPA 200.9	mg/L	0.009	0.002	0.015	-	04/22/15 17:10

ND = None detected MRL = Minimum Reporting Limit MCL = Maximum Contamination Limit
†All procedures for this analysis conform to NELAC standards.

Approved by: _____

Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/04/2015
Received: 02/25/2015
Sampled By: Phil Wentz
Work Order: 5056004

Project:

Project # : N/A
PWSID # : -
PO # : -

Sampling Location: Various
Sample Matrix: Water

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T


Lab Number	Sample Name	Sampled: 2/19/15 10:10		Sample Composition:					
5056004-01	Bridgeport Gym								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26	

Lab Number	Sample Name	Sampled: 2/19/15 10:15		Sample Composition:					
5056004-02	Bridgeport Room 20								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26	

Lab Number	Sample Name	Sampled: 2/19/15 10:40		Sample Composition:					
5056004-03	Bryom Gym								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26	

Lab Number	Sample Name	Sampled: 2/19/15 10:30		Sample Composition:					
5056004-04	Bryom Computer Lab #18								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	0.005	0.002	0.015	-	03/03/15 17:26	

Lab Number	Sample Name	Sampled: 2/19/15 11:45		Sample Composition:					
5056004-05	Fowler Gym								
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time	
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26	



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/04/2015
Received: 02/25/2015
Sampled By: Phil Wentz
Work Order: 5056004

Project:

Project # : N/A
PWSID # : -
PO # : -

Sampling Location: Various
Sample Matrix: Water

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T


Lab Number	Sample Name	Sampled: 2/19/15 11:55 Sample Composition:						
5056004-06	Fowler Rm 24							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.040	0.002	0.015	-	03/03/15 17:26 MCLE

Lab Number	Sample Name	Sampled: 2/19/15 12:05 Sample Composition:						
5056004-07	Woodward Gym							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26

Lab Number	Sample Name	Sampled: 2/19/15 12:15 Sample Composition:						
5056004-08	Woodward Rm 25							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	03/03/15 17:26

Lab Number	Sample Name	Sampled: 2/19/15 12:35 Sample Composition:						
5056004-09	Templeton D19							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	0.002	0.002	0.015	-	03/03/15 17:26

Lab Number	Sample Name	Sampled: 2/19/15 12:45 Sample Composition:						
5056004-10	Templeton E17							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26



13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

**Professional
Laboratory
Services**

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/04/2015
Received: 02/25/2015
Sampled By: Phil Wentz
Work Order: 5056004

Project:

Project # : N/A
PWSID # : -
PO # : -

Sampling Location: Various
Sample Matrix: Water

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T


Lab Number	Sample Name	Sampled: 2/19/15 13:00 Sample Composition:						
5056004-11	Twality #3							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26

Lab Number	Sample Name	Sampled: 2/19/15 13:15 Sample Composition:						
5056004-12	Twality #38							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26

Lab Number	Sample Name	Sampled: 2/24/15 15:30 Sample Composition:						
5056004-13	THS Hall by Bookkeeper							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26

Lab Number	Sample Name	Sampled: 2/24/15 15:40 Sample Composition:						
5056004-14	THS Lower Rotunda							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26

Lab Number	Sample Name	Sampled: 2/24/15 15:50 Sample Composition:						
5056004-15	DEC Upper Sink							
Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/04/2015
Received: 02/25/2015
Sampled By: Phil Wentz
Work Order: 5056004

Project:

Project # : N/A
PWSID # : -
PO # : -

Sampling Location: Various
Sample Matrix: Water

C Tigard-Tualatin SD
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Lab Number **Sample Name** **Sampled: 2/24/15 15:59** **Sample Composition:**
5056004-16 **DEC Kitchen**

Metals (Total)	Code	Method	Units	Result	MRL	EPA MCL	Secondary Standard*	Analysis Date/ Time
†Lead	1030	EPA 200.9	mg/L	ND	0.002	0.015	-	03/03/15 17:26

MCL This analyte exceeds the MCL limit.

† All procedures for this analysis conform to NELAC standards.

ND = None detected **MRL** = Minimum Reporting Limit **MCL** = Maximum Contaminant Limit

Approved by:

Scott Dickman
Lab Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.