Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

This report shows the results from the water retesting that occurred during the week of Jan. 2. These results reflect sampling efforts that are consistent with the EPA's testing procedure guidelines and include both a first draw sample and a "flushed" sample. Based on those sampling efforts, none of the follow-up "flushed" test results exceeded the EPA's actionable level of 20 ppb (parts per billion).

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 01/12/2017
Received: 01/04/2017
Sampled By: Dani Gavaza
Work Order: 7004007

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
7004007-01	**Sample Name:** Rm 21 faucet **Sampled:** 1/4/17 7:00						**Matrix:** Water	
†*Lead*	1030	EPA 200.9	16.6	ppb	4.0	20 ppb	01/10/17 16:19	
7004007-02	**Sample Name:** Rm 21 faucet flush **Sampled:** 1/4/17 7:00						**Matrix:** Water	
†*Lead*	1030	EPA 200.9	11.7	ppb	2.0	20 ppb	01/09/17 16:28	
7004007-03	**Sample Name:** Rm 21 bubbler **Sampled:** 1/4/17 7:00						**Matrix:** Water	
†*Lead*	1030	EPA 200.9	**25.8**	ppb	4.0	20 ppb	01/10/17 16:19	**MCLE**
7004007-04	**Sample Name:** Rm 21 bubbler flush **Sampled:** 1/4/17 7:00						**Matrix:** Water	
†*Lead*	1030	EPA 200.9	12.3	ppb	2.0	20 ppb	01/09/17 16:28	
7004007-05	**Sample Name:** Kitchen prep sink **Sampled:** 1/4/17 6:00						**Matrix:** Water	
†*Lead*	1030	EPA 200.9	**60.9**	ppb	4.0	20 ppb	01/09/17 16:28	**MCLE**
7004007-06	**Sample Name:** Kitchen prep sink flush **Sampled:** 1/4/17 6:00						**Matrix:** Water	
†*Lead*	1030	EPA 200.9	7.9	ppb	2.0	20 ppb	01/09/17 16:28	

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

This report shows the results of water sampling tests completed in November 2016. Results higher than the EPA's actionable level of 20 ppb were retested in January 2017. The retest results appear on page 1 of this document.

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 11/08/2016
Sampled By: P. Wentz
Work Order: 6313010

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6313010-01	**Sample Name:** Rm 3 Faucet **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	17.7	ppb	2.0	20 ppb	12/14/16 16:30
6313010-02	**Sample Name:** Rm 3 Bubbler **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.4	ppb	2.0	20 ppb	12/14/16 16:30
6313010-03	**Sample Name:** Rm 11 Faucet **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	19.3	ppb	2.0	20 ppb	12/14/16 16:30
6313010-04	**Sample Name:** Rm 11 Bubbler **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	15.8	ppb	2.0	20 ppb	12/14/16 16:30
6313010-05	**Sample Name:** Rm 14 Faucet **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.6	ppb	2.0	20 ppb	12/14/16 16:30
6313010-06	**Sample Name:** Rm 14 Bubbler **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	12.7	ppb	2.0	20 ppb	12/14/16 16:30
6313010-07	**Sample Name:** Rm 21 Faucet **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**30.6**	ppb	2.0	20 ppb	12/14/16 16:30 **MCLE**
6313010-08	**Sample Name:** Rm 21 Bubbler **Sampled:** 11/8/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**33.2**	ppb	2.0	20 ppb	12/14/16 16:30 **MCLE**
6313010-09	**Sample Name:** Kitchen Prep Sink **Sampled:** 11/8/16 5:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**67.8**	ppb	4.0	20 ppb	12/14/16 16:30 **MCLE**

MCLE This analyte exceeds the MCL limit.
ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 12/19/2016
Received: 11/08/2016
Sampled By: P. Wentz
Work Order: 6313010

CLIENT

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Byrom

Lab Number

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.