

**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/07/2017
Received: 01/31/2017
Sampled By:
Work Order: 7031006


C **Tigard-Tualatin SD**
L Attn: Phil Wentz
I 6960 SW Sandburg St.
E Tigard OR, 97223
N Phone: (503) 431-4017
T

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Ed Center

Lab Number

Lab Number	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time	
7031006-01	Sample Name: Main Bldg Mens Restroom F right Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-02	Sample Name: Main Bldg Womens Restroom F right Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-03	Sample Name: Class Wing Lower Fountain Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	7.3	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-04	Sample Name: Class Wing Lower F Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	8.6	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-05	Sample Name: Choices Left Sink F Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-06	Sample Name: Choices Right Sink F Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	18.2	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-07	Sample Name: Erikson/Summers F Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-08	Sample Name: Childcare #5 Left Sink Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-09	Sample Name: Childcare #5 Right Sink Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	03/06/17 17:11	
7031006-10	Sample Name: Childcare #4 Right Sink Sampled: 1/24/17 4:10							Matrix: Water
†Lead	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	03/06/17 17:11	



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 03/07/2017

Received: 01/31/2017

Sampled By:

Work Order: 7031006

C
L
I
E
N
T **Tigard-Tualatin SD**
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Ed Center

Lab Number


ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____

Adriana Gonzalez-Gray
Laboratory Director



Alexin Analytical Laboratories, Inc. Professional Laboratory Services

13035 SW Pacific Hwy Tigard, OR 97223 ph: 503.639.9311 fax: 503.684.1588 email: mail@alexinlabs.com

Chain of Custody Record

Laboratory Job Number:

7031006-0110

Page

1 of 1

Client Contact Information	Results Reporting Information	Invoicing Information
Company/Client Name: Tigard-Tualatin S.D. Address: 6960 SW Sandburg City/State/Zip: Tigard OR 97223 phone: 503-431-4017 fax or email: pwentz@ttsd.k12.or.us	Project Manager: Phil Wentz Mailing Address: -SAME- City/State/Zip: phone: fax or email: pwentz@ttsd.k12.or.us	Accounts Payable Contact: Lisa Cresapp Mailing Address: -SAME- City/State/Zip: phone: fax or email: lcresapp@ttsd.k12.or.us

SAMPLING INFORMATION

Sampling Location: DURHAM ED CENTER P.O. #: _____ PWSID #: _____
 Sampled By: _____ Project Name: _____ Project #: _____ Permit #: _____
 Send results to OR State Health Division? (Please circle) Yes No

Lab ID <small>(Lab use only)</small>	Sample Identification	Date Collected	Time Collected <small>(Begin/End if comp)</small>	Sample Matrix*	# of cont. rec'd	Analysis Requested**	Sample Specific Notes/Field Data <small>for each WW sample, specify Raw / Treated, for each DW sample, specify <u>Grab</u> / <u>Composite</u> Source / Distribution, <u>Single</u> / <u>Combined</u> WHERE APPLICABLE</small>
-01	Main Bldg Mens Restroom Frigh	1/24	4:10	Lead	1		SEE ATTACHED
-02	" " Womens " "						
-03	Classing lower Fountain						
-04	" " " F						
-05	CHOICES LEFT sink F						
-06	" " Right " "						
-07	Ericksen/summers F						
-08	childcare #5 left sink						
-09	" " Right "						
-10	" #4 right "						

Relinquished By (print): _____ Company: _____ Date/Time: _____ Signature: _____
 Relinquished By (print): _____ Company: _____ Date/Time: _____ Signature: _____

The most current revision of SOP-10-003 was used when these samples were collected **Received by Laboratory Log-in Staff:** _____ Date/Time: _____ Temp. on receipt: _____ °C On ice? Y N
 * Drinking water (DW), effluent (EFF), ground water (GW), influent (INF), non-aqueous liquid (NAL), paint chips, raw water (RW), sludge, soil, solid, source water (SOURCE), spring, stormwater (SW), surface water, wastewater (WW), well water (WELL)
 ** Analyses for SOC, Radionuclide, Radon, and Asbestos are subcontracted out to other accredited laboratories.
 COC-90-006rev.0.1