Tigard-Tualatin School District
Results of June 2014 Water Quality Testing

Pursuant to its policy, the Tigard-Tualatin School District conducted voluntary random testing for possible lead levels in drinking water at district schools.

The specific results are listed below and shown in parts per billion ("ppb"). The results were obtained from protocols specified by the U.S. Environmental Protection Agency ("EPA").

Based on this sample event, ***there are NO results that exceed EPA's recommended level of 20 ppb*****.** For this set of data, "ND" means no detection, which represents results that are less than 2 ppb.

Alberta Rider Elementary School
Sampled Date: June 6, 2014

Location	Result
Restroom 129-30	ND
Restroom 218-19	ND

Bridgeport Elementary School
Sampled Date: June 6, 2014

Location	Result
Room 2	ND
Room 12	ND

Edward Byrom Elementary School
Sampled Date: June 6, 2014

Location	Result
Room 15	19 ppb
Room 19	ND

Charles F. Tigard Elementary School
Sampled Date: June 10, 2014

Location	Result
Room 114	ND
Room 214	ND

Deer Creek Elementary School
Sampled Date: June 6, 2014

Location	Result
Counseling	ND
E Custodial	ND

Durham Elementary School
Sampled Date: June 6, 2014

Location	Result
Room 16	ND
Room 2	ND

Metzger Elementary School
Sampled Date: June 10, 2014

Location	Result
Gym	ND
Room 100	ND

James Templeton Elementary School
Sampled Date: June 9, 2014

Location	Result
Room D20	20 ppb*
F10	4 ppb

James Templeton Elementary School *Room D20 Retest
Sampled Date: July 2, 2014

Location	Result
Room D20	ND

Mary Woodward Elementary School
Sampled Date: June 10, 2014

Location	Result
Cafeteria	ND
Room 3	8 ppb

Fowler Middle School
Sampled Date: June 6, 2014

Location	Result
W Commons Fountain	ND
E Commons Fountain	ND

Hazelbrook Middle School
Sampled Date: June 9, 2014

Location	Result
Denali	ND
Whitney	ND

Twality Middle School
Sampled Date: June 6, 2014

Location	Result
Cafeteria	ND
Large Gym	ND

Tigard High School
Sampled Date: June 6, 2014

Location	Result
Lower Rotund 222/224	ND
Athletic Hall	ND

Tualatin Elementary School
Sampled Date: June 6, 2014

Location	Result
Room 103	ND
Room 212	ND

Tualatin High School
Sampled Date: June 10, 2014

Location	Result
Front Door N	ND
Athletic Hall	ND

Durham Education Center (DEC)
Sampled Date: June 6, 2014

Location	Result
Commons	2 ppb
Lower Classroom	ND