Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-01	**Sample Name:** Room 6 BRR 1 **Sampled:** 11/17/16 6:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	01/20/17 16:36
6322019-02	**Sample Name:** Room 6 BRR 2 **Sampled:** 11/17/16 6:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-03	**Sample Name:** Room 6 sink **Sampled:** 11/17/16 6:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-04	**Sample Name:** Room 6 BB **Sampled:** 11/17/16 6:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	01/20/17 16:36
6322019-05	**Sample Name:** Room 3 sink **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**25.8**	ppb	2.0	20 ppb	01/20/17 16:36 **MCLE**
6322019-06	**Sample Name:** Room 3 BB **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**24.0**	ppb	2.0	20 ppb	01/20/17 16:36 **MCLE**
6322019-07	**Sample Name:** Room 5 sink **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.3	ppb	2.0	20 ppb	01/20/17 16:36
6322019-08	**Sample Name:** Room 5 BB **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.1	ppb	2.0	20 ppb	01/20/17 16:36
6322019-09	**Sample Name:** Room 4 sink **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.4	ppb	2.0	20 ppb	01/20/17 16:36
6322019-10	**Sample Name:** Room 22 BRR 1 **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-11	**Sample Name:** Room 22 BRR 2 **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-12	**Sample Name:** Room 22 B5RR **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-13	**Sample Name:** Room 23 sink **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-14	**Sample Name:** Room 23 BB **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-15	**Sample Name:** Room 24 BB **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	01/20/17 16:36
6322019-16	**Sample Name:** Room 24 sink **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-17	**Sample Name:** Room 24 WR sink **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-18	**Sample Name:** Room 25 BB **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-19	**Sample Name:** Room 25 sink **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-20	**Sample Name:** Room 26 sink **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-21	**Sample Name:** Room 26 BB **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-22	**Sample Name:** Room 26 GRR 1 **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-23	**Sample Name:** Room 26 GRR 2 **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	01/20/17 16:36
6322019-24	**Sample Name:** Room 26 GRR Staff **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	02/02/17 16:43
6322019-25	**Sample Name:** Room 27 sink **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-26	**Sample Name:** Room 27 BB **Sampled:** 11/17/16 5:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-27	**Sample Name:** Gym GRR 1 **Sampled:** 11/17/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-28	**Sample Name:** Gym GRR 2 **Sampled:** 11/17/16 5:15						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-29	**Sample Name:** Staff Room **Sampled:** 11/17/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-30	**Sample Name:** Cafe Staff RR **Sampled:** 11/17/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-31	**Sample Name:** Cafe Boys RR **Sampled:** 11/17/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-32	**Sample Name:** Cafe Girls RR **Sampled:** 11/17/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-33	**Sample Name:** Cafe Fountain **Sampled:** 11/17/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-34	**Sample Name:** Kit Prep Island **Sampled:** 11/17/16 5:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-35	**Sample Name:** Kit Sink 1 **Sampled:** 11/17/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	02/03/17 15:33
6322019-36	**Sample Name:** Kit Sink 2 Dish **Sampled:** 11/17/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-37	**Sample Name:** Room 22 BB **Sampled:** 11/17/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	02/03/17 15:33
6322019-38	**Sample Name:** Room 22 sink **Sampled:** 11/17/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-39	**Sample Name:** Gym Fountain 1 **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-40	**Sample Name:** Gym Fountain 2 **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-41	**Sample Name:** Gym BRR 1 **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-42	**Sample Name:** Gym BRR 2 **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-43	**Sample Name:** Room 21 **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-44	**Sample Name:** Work Room Sink **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-45	**Sample Name:** Health Room **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.3	ppb	2.0	20 ppb	02/03/17 15:33
6322019-46	**Sample Name:** Head Start Room **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-47	**Sample Name:** Room 19 GRR 1 **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-48	**Sample Name:** Room 19 GRR 2 **Sampled:** 11/17/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-49	**Sample Name:** Room 19 GRR Staff **Sampled:** 11/17/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-50	**Sample Name:** Room 19 BRR 1 **Sampled:** 11/17/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-51	**Sample Name:** Room 19 BRR 2 **Sampled:** 11/17/16 5:35						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-52	**Sample Name:** Room 19 **Sampled:** 11/17/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-53	**Sample Name:** Room 20 **Sampled:** 11/17/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	**30.0**	ppb	2.0	20 ppb	02/03/17 15:33 **MCLE**
6322019-54	**Sample Name:** Room 20 BB **Sampled:** 11/17/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	02/03/17 15:33
6322019-55	**Sample Name:** Room 18 sink **Sampled:** 11/17/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-56	**Sample Name:** Room 18 BB **Sampled:** 11/17/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-57	**Sample Name:** 17/18 Workroom **Sampled:** 11/17/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.7	ppb	2.0	20 ppb	02/03/17 15:33
6322019-58	**Sample Name:** Room 17 sink **Sampled:** 11/17/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-59	**Sample Name:** Room 17 BB **Sampled:** 11/17/16 5:45						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-60	**Sample Name:** Room 16 sink **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-61	**Sample Name:** Room 16 BB **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-62	**Sample Name:** Room 13 sink **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-63	**Sample Name:** Room 13 BB **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-64	**Sample Name:** Room 15 sink **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-65	**Sample Name:** Room 15 BB **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-66	**Sample Name:** Room 14 sink **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-67	**Sample Name:** Room 14 BB **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-68	**Sample Name:** TAG GRR 1 **Sampled:** 11/17/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-69	**Sample Name:** TAG GRR 2 **Sampled:** 11/17/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-70	**Sample Name:** TAG BRR 1 **Sampled:** 11/17/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-71	**Sample Name:** TAG BRR 2 **Sampled:** 11/17/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-72	**Sample Name:** TAG BRR Staff **Sampled:** 11/17/16 6:00						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-73	**Sample Name:** TAG **Sampled:** 11/17/16 6:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-74	**Sample Name:** Room 12 sink **Sampled:** 11/17/16 6:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-75	**Sample Name:** Room 12 BB **Sampled:** 11/17/16 6:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-76	**Sample Name:** Room 11 sink **Sampled:** 11/17/16 6:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-77	**Sample Name:** Room 11 BB **Sampled:** 11/17/16 6:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-78	**Sample Name:** Room 10 sink **Sampled:** 11/17/16 6:10						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-79	**Sample Name:** Room 10 BB **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	02/03/17 15:33
6322019-80	**Sample Name:** Room 7 sink **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-81	**Sample Name:** Room 7 BB **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-82	**Sample Name:** Room 9 sink **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-83	**Sample Name:** Room 9 BB **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-84	**Sample Name:** Room 8 sink **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-85	**Sample Name:** Room 8 BB **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	02/03/17 15:33
6322019-86	**Sample Name:** Room 6 GRR 1 **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/03/17 15:33
6322019-87	**Sample Name:** Room 6 GRR 2 **Sampled:** 11/17/16 6:30						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.0	ppb	2.0	20 ppb	02/03/17 15:33
6322019-88	**Sample Name:** Room 4 BB **Sampled:** 11/17/16 6:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	8.6	ppb	2.0	20 ppb	02/02/17 16:43
6322019-89	**Sample Name:** Room 1 sink **Sampled:** 11/17/16 6:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-90	**Sample Name:** Room 1 BB **Sampled:** 11/17/16 6:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	02/02/17 16:43

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/06/2017
Received: 11/17/2016
Sampled By: Dani Gavaza
Work Order: 6322019

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Durham Elem.

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6322019-91	**Sample Name:** Room 2 sink **Sampled:** 11/17/16 6:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-92	**Sample Name:** Room 2 BB **Sampled:** 11/17/16 6:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.4	ppb	2.0	20 ppb	02/02/17 16:43
6322019-93	**Sample Name:** Room 3 sink **Sampled:** 11/17/16 6:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43
6322019-94	**Sample Name:** Room 3 BB **Sampled:** 11/17/16 6:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/02/17 16:43

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.