Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/21/2017
Received: 12/01/2016
Sampled By: P Wentz
Work Order: 6336038

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tu HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6336038-01	**Sample Name:** N Lobby Fountain **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/10/17 17:07
6336038-02	**Sample Name:** NW Lobby womens bath right **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	02/10/17 17:07
6336038-03	**Sample Name:** NW Lobby mens bath right **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.9	ppb	2.0	20 ppb	02/10/17 17:07
6336038-04	**Sample Name:** rm 25 sink **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/10/17 17:07
6336038-05	**Sample Name:** rm 26 sink **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/10/17 17:07
6336038-06	**Sample Name:** rm 27 1st sink from hall door **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.8	ppb	2.0	20 ppb	02/10/17 17:07
6336038-07	**Sample Name:** rm 27 middle room station **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.7	ppb	2.0	20 ppb	02/10/17 17:07
6336038-08	**Sample Name:** rm 29 first sink from n hall **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.5	ppb	2.0	20 ppb	02/10/17 17:07
6336038-09	**Sample Name:** rm 29 s wall middle sink **Sampled:** 12/1/16 4:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/10/17 17:07
6336038-10	**Sample Name:** E wall lab work room sink **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/10/17 17:07

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/21/2017
Received: 12/01/2016
Sampled By: P Wentz
Work Order: 6336038

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tu HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6336038-11	**Sample Name:** lab w wall sink **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	02/10/17 17:07
6336038-12	**Sample Name:** rm 33 1st sink right **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/10/17 17:07
6336038-13	**Sample Name:** rm 33 middle sink **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.4	ppb	2.0	20 ppb	02/10/17 17:07
6336038-14	**Sample Name:** Room 34 middle F **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/10/17 17:07
6336038-15	**Sample Name:** Room 34 SW F **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/10/17 17:07
6336038-16	**Sample Name:** Room 35 middle F **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/15/17 16:53
6336038-17	**Sample Name:** Room 35 SE F **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.6	ppb	2.0	20 ppb	02/15/17 16:53
6336038-18	**Sample Name:** NW 36 F **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.9	ppb	2.0	20 ppb	02/15/17 16:53
6336038-19	**Sample Name:** Room 36 NE F **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.9	ppb	2.0	20 ppb	02/15/17 16:53
6336038-20	**Sample Name:** Room 37 teacher work F **Sampled:** 12/1/16 4:55						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.0	ppb	2.0	20 ppb	02/15/17 16:53

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/21/2017
Received: 12/01/2016
Sampled By: P Wentz
Work Order: 6336038

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tu HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6336038-21	**Sample Name:** Room 37 SE F **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.6	ppb	2.0	20 ppb	02/15/17 16:53
6336038-22	**Sample Name:** Room 30 teacher work F **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	12.7	ppb	2.0	20 ppb	02/15/17 16:53
6336038-23	**Sample Name:** NW F **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/15/17 16:53
6336038-24	**Sample Name:** RR S Mens F-1 **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.3	ppb	2.0	20 ppb	02/15/17 16:53
6336038-25	**Sample Name:** RR S Wom F-R **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.4	ppb	2.0	20 ppb	02/15/17 16:53
6336038-26	**Sample Name:** Office workroom F **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.3	ppb	2.0	20 ppb	02/15/17 16:53
6336038-27	**Sample Name:** Staff W F **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/15/17 16:53
6336038-28	**Sample Name:** Room 13 F **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/15/17 16:53
6336038-29	**Sample Name:** Room 203 F **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.1	ppb	2.0	20 ppb	02/15/17 16:53
6336038-30	**Sample Name:** Upstairs fount N **Sampled:** 12/1/16 5:05						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/15/17 16:53

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/21/2017
Received: 12/01/2016
Sampled By: P Wentz
Work Order: 6336038

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tu HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6336038-31	**Sample Name:** (upper) RR Womens F-R **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/15/17 16:53
6336038-32	**Sample Name:** (upper) RR Uni F **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.8	ppb	2.0	20 ppb	02/15/17 16:53
6336038-33	**Sample Name:** (upper) RR mens F-R **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/15/17 16:53
6336038-34	**Sample Name:** (upper) RR uni F **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	02/15/17 16:53
6336038-35	**Sample Name:** South Fountain **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/15/17 16:53
6336038-36	**Sample Name:** Room 224 F **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.6	ppb	2.0	20 ppb	02/15/17 16:53
6336038-37	**Sample Name:** Room 165 F **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/15/17 16:53
6336038-38	**Sample Name:** Room 45 F **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.7	ppb	2.0	20 ppb	02/15/17 16:53
6336038-39	**Sample Name:** Room 40 S F **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.5	ppb	2.0	20 ppb	02/15/17 16:53
6336038-40	**Sample Name:** Room 40 N **Sampled:** 12/1/16 5:20						**Matrix:** Water
†*Lead*	1030	EPA 200.9	5.4	ppb	2.0	20 ppb	02/15/17 16:53

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/21/2017
Received: 12/01/2016
Sampled By: P Wentz
Work Order: 6336038

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tu HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6336038-41	**Sample Name:** Health room F **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	6.3	ppb	2.0	20 ppb	02/15/17 16:53
6336038-42	**Sample Name:** Room 110 S **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	9.2	ppb	2.0	20 ppb	02/15/17 16:53
6336038-43	**Sample Name:** Room 110 E **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.2	ppb	2.0	20 ppb	02/16/17 14:08
6336038-44	**Sample Name:** Commons S fountain **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/16/17 14:08
6336038-45	**Sample Name:** Commons N fountain **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/16/17 14:08
6336038-46	**Sample Name:** RR Commons Boy R F **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/16/17 14:08
6336038-47	**Sample Name:** RR Commons Girl R F **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.5	ppb	2.0	20 ppb	02/17/17 16:11
6336038-48	**Sample Name:** Wolf Cafe N F **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/17/17 16:11
6336038-49	**Sample Name:** Wolf Cafe S F **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	4.0	ppb	2.0	20 ppb	02/17/17 16:11
6336038-50	**Sample Name:** Tech RR Boy R F **Sampled:** 12/1/16 5:40						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.0	ppb	2.0	20 ppb	02/17/17 16:11

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/21/2017
Received: 12/01/2016
Sampled By: P Wentz
Work Order: 6336038

CLIENT
Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tu HS

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
6336038-51	**Sample Name:** Tech RR Girl R F **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	2.1	ppb	2.0	20 ppb	02/17/17 16:11
6336038-52	**Sample Name:** Tech RR Staff F **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/17/17 16:11
6336038-53	**Sample Name:** Tech wtr fountain E. **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/17/17 16:11
6336038-54	**Sample Name:** Tech wtr fountain W **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/17/17 16:11
6336038-55	**Sample Name:** Tech 304 W 1 **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	9.6	ppb	2.0	20 ppb	02/17/17 16:11
6336038-56	**Sample Name:** Rm 304 3 **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	7.1	ppb	2.0	20 ppb	02/17/17 16:11
6336038-57	**Sample Name:** Rm 304 4 **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	3.9	ppb	2.0	20 ppb	02/17/17 16:11
6336038-58	**Sample Name:** Tech 304 #2 **Sampled:** 12/1/16 5:50						**Matrix:** Water
†*Lead*	1030	EPA 200.9	ND	ppb	2.0	20 ppb	02/17/17 16:11

ND = None detected at the MRL **MRL** = Minimum Reporting Limit **MCL** = Maximum Contamination Limit
†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

This report shall not be reproduced, except in full, without the written approval of the laboratory.

Alexin Analytical LABORATORIES, INC.
Professional Laboratory Services
13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

ORELAP Accredited Lab#: OR-100013

Reported: 02/21/2017
Received: 12/01/2016
Sampled By: P Wentz
Work Order: 6336038

CLIENT

Tigard-Tualatin SD
Attn: Phil Wentz
6960 SW Sandburg St.
Tigard OR, 97223
Phone: (503) 431-4017

Project:
Project # : N/A
Sample Type :

Sampling Location: Tu HS

Lab Number

Approved by: _____
Adriana Gonzalez-Gray
Laboratory Director

This report shall not be reproduced, except in full, without the written approval of the laboratory.